

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AES-1231-1A	Adams ES	3rd floor across from classroom 308	12/31/14	<1		
AES-1231-2B	Adams ES	3rd floor across from classroom 308	12/31/14	<1		
AES-1231-3A	Adams ES	3rd floor across from classroom 316	12/31/14	<1		
AES-1231-4B	Adams ES	3rd floor across from classroom 316	12/31/14	<1		
AES-1231-5A	Adams ES	2nd floor across from classroom 206	12/31/14	<1		
AES-1231-6B	Adams ES	2nd floor across from classroom 206	12/31/14	<1		
AES-1231-7A	Adams ES	2nd floor inside gym	12/31/14	<1		
AES-1231-8B	Adams ES	2nd floor inside gym	12/31/14	<1		
AES-1231-9A	Adams ES	2nd floor across from classroom 210	12/31/14	2		
AES-1231-10B	Adams ES	2nd floor across from classroom 210	12/31/14	1,7		
AES-1231-11A	Adams ES	1st floor across from classroom 110	12/31/14	<1		
AES-1231-12B	Adams ES	1st floor across from classroom 110	12/31/14	<1		
AES-1231-13A	Adams ES	1st floor inside cafeteria	12/31/14	<1		
AES-1231-14B	Adams ES	1st floor inside cafeteria	12/31/14	<1		
AES-1231-15A	Adams ES	1st floor adjacent to classroom 102	12/31/14	<1		
AES-1231-16B	Adams ES	1st floor adjacent to classroom 102	12/31/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
MAE-0623-1A	Alton ES	1st Floor main entrance adjacent to women's restroom	6/23/15			
MAE-0623-1B	Alton ES	1st Floor main entrance adjacent to women's restroom	6/23/15			
MAE-0623-2A	Alton ES	1st Floor hallway across health room	6/23/15			
MAE-0623-2B	Alton ES	1st Floor hallway across health room	6/23/15			
MAE-0623-3A	Alton ES	1st Floor inside room kindergarten 1	6/23/15			
MAE-0623-3B	Alton ES	1st Floor inside room kindergarten 1	6/23/15			
MAE-0623-4A	Alton ES	1st Floor inside room kindergarten 2	6/23/15			
MAE-0623-4B	Alton ES	1st Floor inside room kindergarten 2	6/23/15			
MAE-0623-5A	Alton ES	4th Floor hallway adjacent to room 406	6/23/15			
MAE-0623-5B	Alton ES	4th Floor hallway adjacent to room 406	6/23/15			
MAE-0623-6A	Alton ES	4th Floor hallway adjacent to multipurpose room	6/23/15			
MAE-0623-6B	Alton ES	4th Floor hallway adjacent to multipurpose room	6/23/15			
MAE-0623-7A	Alton ES	3rd Floor hallway adjacent to room 305	6/23/15			
MAE-0623-7B	Alton ES	3rd Floor hallway adjacent to room 305	6/23/15			
MAE-0623-8A	Alton ES	3rd Floor hallway adjacent to room 301	6/23/15			
MAE-0623-8B	Alton ES	3rd Floor hallway adjacent to room 301	6/23/15			
MAE-0623-9A	Alton ES	2nd Floor hallway adjacent to room 203	6/23/15			
MAE-0623-9B	Alton ES	2nd Floor hallway adjacent to room 203	6/23/15			
MAE-0623-10A	Alton ES	2nd Floor hallway adjacent to library	6/23/15			
MAE-0623-10B	Alton ES	2nd Floor hallway adjacent to library	6/23/15			
Percentage of Passed Samples						0.00%
Percentage of Failed Samples						0.00%
AE-121-1A	Amidon-Bowen ES	2nd Floor inside classroom A-212	12/1/15	<1		
AE-121-1B	Amidon-Bowen ES	2nd Floor inside classroom A-212	12/1/15	<1		
AE-121-2A	Amidon-Bowen ES	2nd Floor inside classroom A-213	12/1/15	<1		
AE-121-2B	Amidon-Bowen ES	2nd Floor inside classroom A-213	12/1/15	<1		
AE-121-3A	Amidon-Bowen ES	2nd Floor inside classroom A-208	12/1/15	<1		
AE-121-3B	Amidon-Bowen ES	2nd Floor inside classroom A-208	12/1/15	<1		
AE-121-4A	Amidon-Bowen ES	2nd Floor inside classroom A-209	12/1/15	1,9		
AE-121-4B	Amidon-Bowen ES	2nd Floor inside classroom A-209	12/1/15	<1		
AE-121-5A	Amidon-Bowen ES	2nd Floor inside classroom A-202	12/1/15	<1		
AE-121-5B	Amidon-Bowen ES	2nd Floor inside classroom A-202	12/1/15	<1		
AE-121-6A	Amidon-Bowen ES	2nd Floor inside classroom B-223	12/1/15	<1		
AE-121-6B	Amidon-Bowen ES	2nd Floor inside classroom B-223	12/1/15	<1		
AE-121-7A	Amidon-Bowen ES	2nd Floor inside classroom B-225	12/1/15	<1		
AE-121-7B	Amidon-Bowen ES	2nd Floor inside classroom B-225	12/1/15	<1		
AE-121-8A	Amidon-Bowen ES	2nd Floor inside classroom B-230	12/1/15	1,9		
AE-121-8B	Amidon-Bowen ES	2nd Floor inside classroom B-230	12/1/15	1,9		
AE-121-9A	Amidon-Bowen ES	2nd Floor inside classroom B-232	12/1/15	<1		
AE-121-9B	Amidon-Bowen ES	2nd Floor inside classroom B-232	12/1/15	<1		
AE-121-10A	Amidon-Bowen ES	2nd Floor inside classroom B-227	12/1/15	<1		
AE-121-10B	Amidon-Bowen ES	2nd Floor inside classroom B-227	12/1/15	<1		
AE-121-11A	Amidon-Bowen ES	2nd Floor inside classroom A-231	12/1/15	<1		
AE-121-11B	Amidon-Bowen ES	2nd Floor inside classroom A-231	12/1/15	<1		
AE-121-12A	Amidon-Bowen ES	2nd Floor inside classroom A-236	12/1/15	<1		
AE-121-12B	Amidon-Bowen ES	2nd Floor inside classroom A-236	12/1/15	<1		
AE-121-13A	Amidon-Bowen ES	2nd Floor Hallway across the library adjacent to stair area C	12/1/15	<1		
AE-121-13B	Amidon-Bowen ES	2nd Floor Hallway across the library adjacent to stair area C	12/1/15	<1		
AE-121-14A	Amidon-Bowen ES	2nd Floor Inside Ms. Barnes room at the library	12/1/15	1,8		
AE-121-14B	Amidon-Bowen ES	2nd Floor Inside Ms. Barnes room at the library	12/1/15	1,7		
AE-121-15A	Amidon-Bowen ES	1st floor inside classroom 161 KG	12/1/15	<1		
AE-121-15B	Amidon-Bowen ES	1st floor inside classroom 161 KG	12/1/15	<1		
AE-121-16A	Amidon-Bowen ES	1st Floor Hallway to Gym entrance	12/1/15	<1		
AE-121-16B	Amidon-Bowen ES	1st Floor Hallway to Gym entrance	12/1/15	<1		
AE-121-17A	Amidon-Bowen ES	1st Floor inside Gymnasium	12/1/15	<1		
AE-121-17B	Amidon-Bowen ES	1st Floor inside Gymnasium	12/1/15	<1		
AE-121-18A	Amidon-Bowen ES	1st Floor inside classroom B-128	12/1/15	<1		
AE-121-18B	Amidon-Bowen ES	1st Floor inside classroom B-128	12/1/15	<1		
AE-121-19A	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (High)	12/1/15	<1		
AE-121-19B	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (High)	12/1/15	<1		
AE-121-20A	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (Low)	12/1/15	<1		
AE-121-20B	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (Low)	12/1/15	<1		
AE-121-21A	Amidon-Bowen ES	1st floor inside classroom B-126	12/1/15	<1		
AE-121-21B	Amidon-Bowen ES	1st floor inside classroom B-126	12/1/15	<1		
AE-121-22A	Amidon-Bowen ES	1st floor inside classroom B-103 (High)	12/1/15	<1		
AE-121-22B	Amidon-Bowen ES	1st floor inside classroom B-103 (High)	12/1/15	<1		
AE-121-23A	Amidon-Bowen ES	1st Floor inside classroom A-106 (High)	12/1/15	<1		
AE-121-23B	Amidon-Bowen ES	1st Floor inside classroom A-106 (High)	12/1/15	<1		
AE-121-24A	Amidon-Bowen ES	1st Floor inside classroom A-105 (High)	12/1/15	<1		
AE-121-24B	Amidon-Bowen ES	1st Floor inside classroom A-105 (High)	12/1/15	<1		
AE-121-25A	Amidon-Bowen ES	1st Floor inside classroom A-107 (High)	12/1/15	2,1		
AE-121-25B	Amidon-Bowen ES	1st Floor inside classroom A-107 (High)	12/1/15	1,6		
AE-121-26A	Amidon-Bowen ES	1st Floor Hallway adjacent to Health Suite	12/1/15	<1		
AE-121-26B	Amidon-Bowen ES	1st Floor Hallway adjacent to Health Suite	12/1/15	<1		
AE-121-27A	Amidon-Bowen ES	1st Floor Kitchen hallway adjacent to women rest room	12/1/15	<1		
AE-121-27B	Amidon-Bowen ES	1st Floor Kitchen hallway adjacent to women rest room	12/1/15	<1		
AE-121-28A	Amidon-Bowen ES	1st Floor inside classroom A-103 (Low)	12/1/15	<1		
AE-121-28B	Amidon-Bowen ES	1st Floor inside classroom A-103 (Low)	12/1/15	<1		
AE-121-29A	Amidon-Bowen ES	1st Floor inside classroom A-106 (Low)	12/1/15	<1		
AE-121-29B	Amidon-Bowen ES	1st Floor inside classroom A-106 (Low)	12/1/15	<1		
AE-121-30A	Amidon-Bowen ES	1st Floor inside classroom A-105 (Low)	12/1/15	<1		
AE-121-30B	Amidon-Bowen ES	1st Floor inside classroom A-105 (Low)	12/1/15	<1		
AE-121-31A	Amidon-Bowen ES	1st Floor inside classroom A-107 (Low)	12/1/15	<1		
AE-121-31B	Amidon-Bowen ES	1st Floor inside classroom A-107 (Low)	12/1/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
AHS-1230-1A	Anacostia HS	3rd floor hallway adjacent to Classroom M319	12/30/14	<1		
AHS-1230-2B	Anacostia HS	3rd floor hallway adjacent to Classroom M319	12/30/14	<1		
AHS-1230-3A	Anacostia HS	3rd floor hallway adjacent to Classroom M303	12/30/14	<1		
AHS-1230-4B	Anacostia HS	3rd floor hallway adjacent to Classroom M303	12/30/14	<1		
AHS-1230-5A	Anacostia HS	2nd floor hallway adjacent to Computer Lab N203	12/30/14	<1		
AHS-1230-6B	Anacostia HS	2nd floor hallway adjacent to Computer Lab N203	12/30/14	<1		
AHS-1230-7A	Anacostia HS	2nd floor hallway adjacent to Science Lab M220	12/30/14	<1		
AHS-1230-8B	Anacostia HS	2nd floor hallway adjacent to Science Lab M220	12/30/14	<1		
AHS-1230-9A	Anacostia HS	2nd floor hallway adjacent to Classroom S204	12/30/14	<1		
AHS-1230-10B	Anacostia HS	2nd floor hallway adjacent to Classroom S204	12/30/14	<1		
AHS-1230-11A	Anacostia HS	2nd floor hallway adjacent to Work Room G204	12/30/14	<1		
AHS-1230-12B	Anacostia HS	2nd floor hallway adjacent to Work Room G204	12/30/14	<1		
AHS-1230-13A	Anacostia HS	2nd floor hallway across from Computer Lab M212	12/30/14	<1		
AHS-1230-14B	Anacostia HS	2nd floor hallway across from Computer Lab M212	12/30/14	<1		
AHS-1230-15A	Anacostia HS	1st floor hallway across from Work Room N110	12/30/14	<1		
AHS-1230-16B	Anacostia HS	1st floor hallway across from Work Room N110	12/30/14	<1		
AHS-1230-17A	Anacostia HS	1st floor hallway adjacent to M103 (Admin)	12/30/14	<1		
AHS-1230-18B	Anacostia HS	1st floor hallway adjacent to M103 (Admin)	12/30/14	<1		
AHS-1230-19A	Anacostia HS	1st floor hallway adjacent to Classroom S102	12/30/14	<1		
AHS-1230-20B	Anacostia HS	1st floor hallway adjacent to Classroom S102	12/30/14	<1		
AHS-1230-21A	Anacostia HS	1st floor hallway across from Gym G102	12/30/14	<1		
AHS-1230-22B	Anacostia HS	1st floor hallway across from Gym G102	12/30/14	<1		
AHS-1230-23A	Anacostia HS	Basement floor hallway adjacent to Science Lab S007	12/30/14	<1		
AHS-1230-24B	Anacostia HS	Basement floor hallway adjacent to Science Lab S007	12/30/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
BH-0203-1A	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	<1		
BH-0203-1B	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	<1		
BH-0203-2A	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	<1		
BH-0203-2B	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	<1		
BH-0203-3A	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	<1		
BH-0203-3B	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	<1		
BH-0203-4A	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	<1		
BH-0203-4B	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	<1		
BH-0203-5A	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	<1		
BH-0203-5B	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	<1		
BH-0203-6A	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	<1		
BH-0203-6B	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	<1		
BH-0203-7A	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	<1		
BH-0203-7B	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	<1		
BH-0203-8A	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	<1		
BH-0203-8B	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	<1		
BH-0203-9A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	<1		
BH-0203-9B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	<1		
BH-0203-10A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	<1		
BH-0203-10B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	<1		
BH-0203-11A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	<1		
BH-0203-11B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	<1		
BH-0203-12A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-4-24-16B	Burville ES	2nd Floor inside classroom 221	4/24/15	<1		
BES-4-24-17A	Burville ES	1st Floor inside classroom 110	4/24/15	<1		
BES-4-24-17B	Burville ES	1st Floor inside classroom 110	4/24/15	<1		
BES-4-24-18A	Burville ES	1st Floor inside classroom 115	4/24/15	<1		
BES-4-24-18B	Burville ES	1st Floor inside classroom 115	4/24/15	<1		
BES-4-24-19A	Burville ES	1st Floor inside classroom 114	4/24/15	<1		
BES-4-24-19B	Burville ES	1st Floor inside classroom 114	4/24/15	<1		
BES-4-24-20A	Burville ES	1st Floor inside classroom 112	4/24/15	<1		
BES-4-24-20B	Burville ES	1st Floor inside classroom 112	4/24/15	<1		
BES-4-24-21A	Burville ES	1st Floor inside classroom 113	4/24/15	<1		
BES-4-24-21B	Burville ES	1st Floor inside classroom 113	4/24/15	<1		
BES-4-24-22A	Burville ES	1st Floor inside classroom 108	4/24/15	<1		
BES-4-24-22B	Burville ES	1st Floor inside classroom 108	4/24/15	<1		
BES-4-24-23A	Burville ES	1st Floor hallway adjacent to nurse office	4/24/15	1.7		
BES-4-24-23B	Burville ES	1st Floor hallway adjacent to nurse office	4/24/15	3		
BES-4-24-24A	Burville ES	1st Floor adjacent to stairwell 1	4/24/15	7.6		
BES-4-24-24B	Burville ES	1st Floor adjacent to stairwell 1	4/24/15	6.8		
BES-4-24-25A	Burville ES	1st Floor hallway adjacent to mechanical room	4/24/15	<1		
BES-4-24-25B	Burville ES	1st Floor hallway adjacent to mechanical room	4/24/15	<1		
BES-4-24-26A	Burville ES	1st Floor south side of the GYM NW end (high)	4/24/15	<1		
BES-4-24-26B	Burville ES	1st Floor south side of the GYM NW end (high)	4/24/15	<1		
BES-4-24-27A	Burville ES	1st Floor south side of the GYM NW end (low)	4/24/15	<1		
BES-4-24-27B	Burville ES	1st Floor south side of the GYM NW end (low)	4/24/15	<1		
BES-4-24-28A	Burville ES	1st Floor south side of the GYM NE end (high)	4/24/15	<1		
BES-4-24-28B	Burville ES	1st Floor south side of the GYM NE end (high)	4/24/15	2.4		
BES-4-24-29A	Burville ES	1st Floor south side of the GYM NE end (low)	4/24/15	<1		
BES-4-24-29B	Burville ES	1st Floor south side of the GYM NE end (low)	4/24/15	1.1		
BES-4-24-30A	Burville ES	1st Floor inside GYM boys RR	4/24/15	<1		
BES-4-24-30B	Burville ES	1st Floor inside GYM boys RR	4/24/15	<1		
BES-4-24-31A	Burville ES	1st Floor inside GYM girls RR	4/24/15	<1		
BES-4-24-31B	Burville ES	1st Floor inside GYM girls RR	4/24/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
JB-115-1A	Burroughs EC	1st Floor hallway adjacent to classroom 8	1/15/15	<1		
JB-115-1B	Burroughs EC	1st Floor hallway adjacent to classroom 8	1/15/15	<1		
JB-115-2A	Burroughs EC	1st Floor hallway adjacent to classroom 9A	1/15/15	<1		
JB-115-2B	Burroughs EC	1st Floor hallway adjacent to classroom 9A	1/15/15	<1		
JB-115-3A	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (High)	1/15/15	<1		
JB-115-3B	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (High)	1/15/15	<1		
JB-115-4A	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (Low)	1/15/15	<1		
JB-115-4B	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (Low)	1/15/15	<1		
JB-115-5A	Burroughs EC	1st Floor hallway across from classroom 14	1/15/15	<1		
JB-115-5B	Burroughs EC	1st Floor hallway across from classroom 14	1/15/15	<1		
JB-115-6A	Burroughs EC	1st Floor hallway across from classroom 3	1/15/15	<1		
JB-115-6B	Burroughs EC	1st Floor hallway across from classroom 3	1/15/15	<1		
JB-115-7A	Burroughs EC	Ground floor hallway adjacent to classroom 19	1/15/15	<1		
JB-115-7B	Burroughs EC	Ground floor hallway adjacent to classroom 19	1/15/15	<1		
JB-115-8A	Burroughs EC	Ground floor hallway adjacent to classroom 20	1/15/15	<1		
JB-115-8B	Burroughs EC	Ground floor hallway adjacent to classroom 20	1/15/15	<1		
JB-115-9A	Burroughs EC	Ground floor inside classroom 20	1/15/15	<1		
JB-115-9B	Burroughs EC	Ground floor inside classroom 20	1/15/15	<1		
JB-115-10A	Burroughs EC	Ground floor inside classroom 19	1/15/15	<1		
JB-115-10B	Burroughs EC	Ground floor inside classroom 19	1/15/15	<1		
JB-115-11A	Burroughs EC	Ground floor inside classroom 18	1/15/15	<1		
JB-115-11B	Burroughs EC	Ground floor inside classroom 18	1/15/15	<1		
JB-115-12A	Burroughs EC	Ground floor inside classroom 21	1/15/15	<1		
JB-115-12B	Burroughs EC	Ground floor inside classroom 21	1/15/15	<1		
JB-115-13A	Burroughs EC	Ground floor inside classroom 22	1/15/15	<1		
JB-115-13B	Burroughs EC	Ground floor inside classroom 22	1/15/15	<1		
JB-115-14A	Burroughs EC	1st Floor inside classroom 34	1/15/15	<1		
JB-115-14B	Burroughs EC	1st Floor inside classroom 34	1/15/15	<1		
JB-115-15A	Burroughs EC	1st Floor inside classroom 35	1/15/15	<1		
JB-115-15B	Burroughs EC	1st Floor inside classroom 35	1/15/15	<1		
JB-115-16A	Burroughs EC	Ground floor hallway across from class 27	1/15/15	<1		
JB-115-16B	Burroughs EC	Ground floor hallway across from class 27	1/15/15	<1		
JB-115-17A	Burroughs EC	1st Floor inside classroom 25	1/15/15	<1		
JB-115-17B	Burroughs EC	1st Floor inside classroom 25	1/15/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
EE-0630-1A	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 316	6/30/15	<1		
EE-0630-1B	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 316	6/30/15	<1		
EE-0630-2A	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 312	6/30/15	<1		
EE-0630-2B	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 312	6/30/15	<1		
EE-0630-3A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 316	6/30/15	<1		
EE-0630-3B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 316	6/30/15	<1		
EE-0630-4A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 314	6/30/15	<1		
EE-0630-4B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 314	6/30/15	2.3		
EE-0630-5A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 312	6/30/15	1.8		
EE-0630-5B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 312	6/30/15	1.1		
EE-0630-6A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 308	6/30/15	5.9		
EE-0630-6B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 308	6/30/15	<1		
EE-0630-7A	C.H.O.I.C.E Academy @ Emery	Third Floor hallway adjacent to Stairway 1	6/30/15	<1		
EE-0630-7B	C.H.O.I.C.E Academy @ Emery	Third Floor hallway adjacent to Stairway 1	6/30/15	<1		
EE-0630-8A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 218	6/30/15	<1		
EE-0630-8B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 218	6/30/15	<1		
EE-0630-9A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 213	6/30/15	<1		
EE-0630-9B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 213	6/30/15	<1		
EE-0630-10A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 205	6/30/15	<1		
EE-0630-10B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 205	6/30/15	<1		
EE-0630-11A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 200	6/30/15	<1		
EE-0630-11B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 200	6/30/15	<1		
EE-0630-12A	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 113	6/30/15	<1		
EE-0630-12B	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 113	6/30/15	<1		
EE-0630-13A	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 112	6/30/15	<1		
EE-0630-13B	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 112	6/30/15	<1		
EE-0630-14A	C.H.O.I.C.E Academy @ Emery	First Floor Hallway adjacent to Rm 110	6/30/15	<1		
EE-0630-14B	C.H.O.I.C.E Academy @ Emery	First Floor Hallway adjacent to Rm 110	6/30/15	<1		
EE-0630-15A	C.H.O.I.C.E Academy @ Emery	First Floor Hallway across Rm 102	6/30/15	<1		
EE-0630-15B	C.H.O.I.C.E Academy @ Emery	First Floor Hallway across Rm 102	6/30/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
CWH-0121-1A	C.W. Harris ES	Health Suite	12/1/15	<1		
CWH-0121-1B	C.W. Harris ES	Health Suite	12/1/15	<1		
CWH-0121-2A	C.W. Harris ES	1st Floor - Between Teacher's Restroom & Custodian Closet in Hallway adjacent to Room 109	12/1/15	<1		
CWH-0121-2B	C.W. Harris ES	1st Floor - Between Teacher's Restroom & Custodian Closet in Hallway adjacent to Room 109	12/1/15	<1		
CWH-0121-3A	C.W. Harris ES	2nd Floor - Between Boy's Restroom & Custodian Closet in Hallway diagonally from Room 218	12/1/15	<1		
CWH-0121-3B	C.W. Harris ES	2nd Floor - Between Boy's Restroom & Custodian Closet in Hallway diagonally from Room 218	12/1/15	<1		
CWH-0121-4A	C.W. Harris ES	2nd Floor - Between Boy's Restroom & Custodian Closet in Hallway in front of CWHTV-3 and across from Room 246	12/1/15	<1		
CWH-0121-4B	C.W. Harris ES	2nd Floor - Between Boy's Restroom & Custodian Closet in Hallway in front of CWHTV-3 and across from Room 246	12/1/15	<1		
CWH-0121-5A	C.W. Harris ES	1st Floor - Between Boy's Restroom & Girl's Restroom in Hallway before Pre-K Wing Entrance	12/1/15	<1		
CWH-0121-5B	C.W. Harris ES	1st Floor - Between Boy's Restroom & Girl's Restroom in Hallway before Pre-K Wing Entrance	12/1/15	<1		
CWH-0121-6A	C.W. Harris ES	Multi-purpose Room	12/1/15	<1		
CWH-0121-6B	C.W. Harris ES	Multi-purpose Room	12/1/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
CZ-0122-1A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (High)	1/22/15	<1		
CZ-0122-1B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (High)	1/22/15	<1		
CZ-0122-2A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (Low)	1/22/15	<1		
CZ-0122-2B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (Low)	1/22/15	<1		
CZ-0122-3A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (High)	1/22/15	<1		
CZ-0122-3B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (High)	1/22/15	<1		
CZ-0122-4A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (Low)	1/22/15	<1		
CZ-0122-4B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (Low)	1/22/15	<1		
CZ-0122-5A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (High)	1/22/15	<1		
CZ-0122-5B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (High)	1/22/15	<1		
CZ-0122-6A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (Low)	1/22/15	<1		
CZ-0122-6B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (Low)	1/22/15	<1		
CZ-0122-7A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (High)	1/22/15	<1		
CZ-0122-7B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (High)	1/22/15	<1		
CZ-0122-8A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (Low)	1/22/15	<1		
CZ-0122-8B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (Low)	1/22/15	<1		
CZ-0122-9A	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (High)	1/22/15	<1		
CZ-0122-9B	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (High)	1/22/15	<1		
CZ-0122-10A	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (Low)	1/22/15	<1		
CZ-0122-10B	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (Low)	1/22/15	<1		
CZ-0122-11A	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (High)	1/22/15	<1		
CZ-0122-11B	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (High)	1/22/15	<1		
CZ-0122-12A	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (Low)	1/22/15	<1		
CZ-0122-12B	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (Low)	1/22/15	<1		
CZ-0122-13A	Cardozo EC	C Level Hallway adjacent to classroom C205 (High)	1/22/15	<1		
CZ-0122-13B	Cardozo EC	C Level Hallway adjacent to classroom C205 (High)	1/22/15	<1		
CZ-0122-14A	Cardozo EC	C Level Hallway adjacent to classroom C205 (Low)	1/22/15	<1		
CZ-0122-14B	Cardozo EC	C Level Hallway adjacent to classroom C205 (Low)	1/22/15	<1		
CZ-0122-15A	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (High)	1/22/15	<1		
CZ-0122-15B	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (High)	1/22/15	<1		
CZ-0122-16A	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (Low)	1/22/15	<1		
CZ-0122-16B	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (Low)	1/22/15	<1		
CZ-0122-17A	Cardozo EC	LT Level Hallway adjacent to classroom LT58 (High)	1/22/15	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CH-0204-16A	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 173 (Low)	2/4/15	10		
CH-0204-16B	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 173 (Low)	2/4/15	7.6		
CH-0204-17A	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 172	2/4/15		84	Filter Installed
CH-0204-17B	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 172	2/4/15		71	Filter Installed
CH-0204-18A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to G locker	2/4/15	<1		
CH-0204-18B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to G locker	2/4/15	<1		
CH-0204-19A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to stair 1	2/4/15	<1		
CH-0204-19B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to stair 1	2/4/15	<1		
CH-0204-20A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to door 181	2/4/15	<1		
CH-0204-20B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to door 181	2/4/15	<1		
CH-0204-21A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to B locker	2/4/15	<1		
CH-0204-21B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to B locker	2/4/15	<1		
CH-0204-22A	Coolidge HS	Basement floor inside Frank R Williams Activity Center adjacent to room B105	2/4/15	<1		
CH-0204-22B	Coolidge HS	Basement floor inside Frank R Williams Activity Center adjacent to room B105	2/4/15	<1		
CH-0204-23A	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside girl's locker room	2/4/15	1.1		
CH-0204-23B	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside girl's locker room	2/4/15	<1		
CH-0204-24A	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside boy's locker room	2/4/15	<1		
CH-0204-24B	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside boy's locker room	2/4/15	<1		
CH-0204-25A	Coolidge HS	1st floor inside Gym	2/4/15	<1		
CH-0204-25B	Coolidge HS	1st floor inside Gym	2/4/15	<1		
CH-0204-26A	Coolidge HS	Basement floor in front lobby outside Auditorium left	2/4/15		24	Filter Installed
CH-0204-26B	Coolidge HS	Basement floor in front lobby outside Auditorium left	2/4/15		180	Filter Installed
CH-0204-27A	Coolidge HS	Basement floor in front lobby outside Auditorium right	2/4/15		51	Filter Installed
CH-0204-27B	Coolidge HS	Basement floor in front lobby outside Auditorium right	2/4/15		38	Filter Installed
Percentage of Passed Samples						88.89%
Percentage of Failed Samples						11.11%
DCG-0523-1A	DC General	5th floor hallway adjacent to Room 526	5/23/15	<1		
DCG-0523-1B	DC General	5th floor hallway adjacent to Room 526	5/23/15	<1		
DCG-0523-2A	DC General	5th floor hallway adjacent to Men's Bathroom 3	5/23/15	<1		
DCG-0523-2B	DC General	5th floor hallway adjacent to Men's Bathroom 3	5/23/15	<1		
DCG-0523-3A	DC General	5th floor inside Kitchen	5/23/15	<1		
DCG-0523-3B	DC General	5th floor inside Kitchen	5/23/15	<1		
DCG-0523-4A	DC General	4th floor hallway near Men's Bathroom 3	5/23/15	<1		
DCG-0523-4B	DC General	4th floor hallway near Men's Bathroom 3	5/23/15	<1		
DCG-0523-5A	DC General	4th floor inside Kitchen	5/23/15	<1		
DCG-0523-5B	DC General	4th floor inside Kitchen	5/23/15	<1		
DCG-0523-6A	DC General	4th floor hallway adjacent to Room 424	5/23/15	<1		
DCG-0523-6B	DC General	4th floor hallway adjacent to Room 424	5/23/15	<1		
DCG-0523-7A	DC General	3rd floor hallway adjacent to Room 323	5/23/15	<1		
DCG-0523-7B	DC General	3rd floor hallway adjacent to Room 323	5/23/15	<1		
DCG-0523-8A	DC General	3rd floor hallway near Room 309	5/23/15	<1		
DCG-0523-8B	DC General	3rd floor hallway near Room 309	5/23/15	<1		
DCG-0523-9A	DC General	3rd floor inside Cafeteria	5/23/15	<1		
DCG-0523-9B	DC General	3rd floor inside Cafeteria	5/23/15	<1		
DCG-0523-10A	DC General	3rd floor inside Kitchen	5/23/15	1.4		
DCG-0523-10B	DC General	3rd floor inside Kitchen	5/23/15	1.3		
DCG-0523-11A	DC General	2nd floor hallway adjacent to Room 230	5/23/15	<1		
DCG-0523-11B	DC General	2nd floor hallway adjacent to Room 230	5/23/15	<1		
DCG-0523-12A	DC General	2nd floor hallway adjacent to Women's Bathroom 13	5/23/15	<1		
DCG-0523-12B	DC General	2nd floor hallway adjacent to Women's Bathroom 13	5/23/15	<1		
DCG-0523-13A	DC General	2nd floor inside Cafeteria	5/23/15	<1		
DCG-0523-13B	DC General	2nd floor inside Cafeteria	5/23/15	<1		
DCG-0523-14A	DC General	2nd floor inside Kitchen	5/23/15	<1		
DCG-0523-14B	DC General	2nd floor inside Kitchen	5/23/15	<1		
DCG-0523-15A	DC General	2nd floor hallway across from Room 211	5/23/15	<1		
DCG-0523-15B	DC General	2nd floor hallway across from Room 211	5/23/15	<1		
DCG-0523-16A	DC General	2nd floor inside Activity Room	5/23/15	<1		
DCG-0523-16B	DC General	2nd floor inside Activity Room	5/23/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
DM-0205-1A	Deal MS	3rd Floor hallway adjacent to classroom W300	2/5/15	<1		
DM-0205-1A	Deal MS	3rd Floor hallway adjacent to classroom W300	2/5/15	<1		
DM-0205-2A	Deal MS	3rd Floor hallway adjacent to classroom E300 (high)	2/5/15	<1		
DM-0205-2B	Deal MS	3rd Floor hallway adjacent to classroom E300 (high)	2/5/15	<1		
DM-0205-3A	Deal MS	3rd Floor hallway adjacent to classroom W300 (low)	2/5/15	<1		
DM-0205-3B	Deal MS	3rd Floor hallway adjacent to classroom W300 (low)	2/5/15	<1		
DM-0205-4A	Deal MS	2nd Floor hallway adjacent to classroom E200 (high)	2/5/15	<1		
DM-0205-4B	Deal MS	2nd Floor hallway adjacent to classroom E200 (high)	2/5/15	<1		
DM-0205-5A	Deal MS	2nd Floor hallway adjacent to classroom E200 (low)	2/5/15	<1		
DM-0205-5B	Deal MS	2nd Floor hallway adjacent to classroom E200 (low)	2/5/15	<1		
DM-0205-6A	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	<1		
DM-0205-6B	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	<1		
DM-0205-7A	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	<1		
DM-0205-7B	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	<1		
DM-0205-8A	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	<1		
DM-0205-8B	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	<1		
DM-0205-9A	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	<1		
DM-0205-9B	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	<1		
DM-0205-10A	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	<1		
DM-0205-10B	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	<1		
DM-0205-11A	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	<1		
DM-0205-11B	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	<1		
DM-0205-12A	Deal MS	Ground floor hallway at cafeteria NG20	2/5/15	<1		
DM-0205-12B	Deal MS	Ground floor hallway at cafeteria NG20	2/5/15	<1		
DM-0205-13A	Deal MS	Ground floor inside cafeteria	2/5/15	<1		
DM-0205-13B	Deal MS	Ground floor inside cafeteria	2/5/15	<1		
DM-0205-14A	Deal MS	Ground floor inside cafeteria	2/5/15	<1		
DM-0205-14B	Deal MS	Ground floor inside cafeteria	2/5/15	<1		
DM-0205-15A	Deal MS	Ground floor hallway adjacent to office CG42 (high)	2/5/15	<1		
DM-0205-15B	Deal MS	Ground floor hallway adjacent to office CG42 (high)	2/5/15	<1		
DM-0205-16A	Deal MS	Ground floor hallway adjacent to office CG42 (low)	2/5/15	<1		
DM-0205-16B	Deal MS	Ground floor hallway adjacent to office CG42 (low)	2/5/15	<1		
DM-0205-17A	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	<1		
DM-0205-17B	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	<1		
DM-0205-18A	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	<1		
DM-0205-18B	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	<1		
DM-0205-19A	Deal MS	Ground floor inside the Gym	2/5/15	<1		
DM-0205-19B	Deal MS	Ground floor inside the Gym	2/5/15	<1		
DM-0205-20A	Deal MS	Ground floor inside the Gym	2/5/15	<1		
DM-0205-20B	Deal MS	Ground floor inside the Gym	2/5/15	<1		
DM-0205-21A	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	<1		
DM-0205-21B	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	<1		
DM-0205-22A	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	<1		
DM-0205-22B	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	<1		
DM-0205-23A	Deal MS	1st Floor hallway rest room across room R103	2/5/15	<1		
DM-0205-23B	Deal MS	1st Floor hallway rest room across room R103	2/5/15	<1		
DM-0205-24A	Deal MS	1st Floor hallway rest room across room R103	2/5/15	<1		
DM-0205-24B	Deal MS	1st Floor hallway rest room across room R103	2/5/15	<1		
DM-0205-25A	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-25B	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-26A	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-26B	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-27A	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-27B	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-28A	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-28B	Deal MS	1st Floor inside classroom R102	2/5/15	<1		
DM-0205-29A	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	<1		
DM-0205-29B	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	<1		
DM-0205-30A	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	<1		
DM-0205-30B	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	<1		
DM-0205-31A	Deal MS	Ground floor inside classroom RG02	2/5/15	<1		
DM-0205-31B	Deal MS	Ground floor inside classroom RG02	2/5/15	<1		
DM-0205-32A	Deal MS	Ground floor inside classroom RG02	2/5/15	1.2		
DM-0205-32B	Deal MS	Ground floor inside classroom RG02	2/5/15	<1		
DM-0205-33A	Deal MS	Ground floor inside classroom RG02	2/5/15	<1		
DM-0205-33B	Deal MS	Ground floor inside classroom RG02	2/5/15	<1		
DM-0205-34A	Deal MS	Ground floor inside classroom RG02	2/5/15	2.3		
DM-0205-34B	Deal MS	Ground floor inside classroom RG02	2/5/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
DES-1224-1A	Draw ES	4th Floor - Front Room 404	12/24/14	<1		
DES-1224-2B	Draw ES	4th Floor - Front Room 404	12/24/14	<1		
DES-1224-3A	Draw ES	4th Floor - Front Room 404	12/24/14	<1		
DES-1224-4B	Draw ES	4th Floor - Front Room 404	12/24/14	<1		
DES-1224-5A	Draw ES	4th Floor - Front Room 400	12/24/14	3.3		
DES-1224-6B	Draw ES	4th Floor - Front Room 400	12/24/14	<1		
DES-1224-7A	Draw ES	3rd Floor - Front Room 300	12/24/14	<1		
DES-1224-8B	Draw ES	3rd Floor - Front Room 300	12/24/14	<1		
DES-1224-9A	Draw ES	3rd Floor - Front Room 300	12/24/14	<1		
DES-1224-10B	Draw ES	3rd Floor - Front Room 300	12/24/14	<1		
DES-1224-11A	Draw ES	3rd Floor - Next to Room 307	12/24/14	<1		
DES-1224-12B	Draw ES	3rd Floor - Next to Room 307	12/24/14	<1		
DES-1224-13A	Draw ES	3rd Floor - Next to Room 307	12/24/14	<1		
DES-1224-14B	Draw ES	3rd Floor - Next to Room 307	12/24/14	<1		
DES-1224-15A	Draw ES	2nd Floor - In Room 205	12/24/14	<1		
DES-1224-16B	Draw ES	2nd Floor - In Room 205	12/24/14	<1		
DES-1224-17A	Draw ES	2nd Floor - In Room 207	12/24/14	<1		
DES-1224-18B	Draw ES	2nd Floor - In Room 207	12/24/14	<1		
DES-1224-19A	Draw ES	2nd Floor - Front Room 204	12/24/14	<1		
DES-1224-20B	Draw ES	2nd Floor - Front Room 204	12/24/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
DES-1224-21A	Drew ES	2nd Floor - Front Room 204	12/24/14	<1		
DES-1224-22B	Drew ES	2nd Floor - Front Room 204	12/24/14	<1		
DES-1224-23A	Drew ES	2nd Floor - In Room 209	12/24/14	<1		
DES-1224-24B	Drew ES	2nd Floor - In Room 209	12/24/14	<1		
DES-1224-25A	Drew ES	2nd Floor - Front Room 200	12/24/14	<1		
DES-1224-26B	Drew ES	2nd Floor - Front Room 200	12/24/14	<1		
DES-1224-27A	Drew ES	2nd Floor - Front Room 200	12/24/14	<1		
DES-1224-28B	Drew ES	2nd Floor - Front Room 200	12/24/14	<1		
DES-1224-29A	Drew ES	2nd Floor - In Room 213	12/24/14	<1		
DES-1224-30B	Drew ES	2nd Floor - In Room 213	12/24/14	<1		
DES-1224-31A	Drew ES	1st Floor - Front Health Room	12/24/14	<1		
DES-1224-32B	Drew ES	1st Floor - Front Health Room	12/24/14	<1		
DES-1224-33A	Drew ES	1st Floor - Front Health Room	12/24/14	<1		
DES-1224-34B	Drew ES	1st Floor - Front Health Room	12/24/14	<1		
DES-1224-35A	Drew ES	1st Floor - In Room 104	12/24/14	<1		
DES-1224-36B	Drew ES	1st Floor - In Room 104	12/24/14	<1		
DES-1224-37A	Drew ES	1st Floor - In Room 108	12/24/14	<1		
DES-1224-38B	Drew ES	1st Floor - In Room 108	12/24/14	<1		
DES-1224-39A	Drew ES	1st Floor - In Room 105	12/24/14	<1		
DES-1224-40B	Drew ES	1st Floor - In Room 105	12/24/14	<1		
DES-1224-41A	Drew ES	1st Floor - Near Room 105	12/24/14	<1		
DES-1224-42B	Drew ES	1st Floor - Near Room 105	12/24/14	<1		
DES-1224-43A	Drew ES	1st Floor - Near Room 105	12/24/14	<1		
DES-1224-44B	Drew ES	1st Floor - Near Room 105	12/24/14	<1		
DES-1224-45A	Drew ES	1st Floor - In Room 107	12/24/14	<1		
DES-1224-46B	Drew ES	1st Floor - In Room 107	12/24/14	<1		
DES-1224-47A	Drew ES	1st Floor - In Room 106	12/24/14	<1		
DES-1224-48B	Drew ES	1st Floor - In Room 106	12/24/14	<1		
DES-1224-49A	Drew ES	1st Floor - In Cafeteria	12/24/14	<1		
DES-1224-50B	Drew ES	1st Floor - In Cafeteria	12/24/14	<1		
DES-1224-51A	Drew ES	1st Floor - In Auditorium	12/24/14	<1		
DES-1224-52B	Drew ES	1st Floor - In Auditorium	12/24/14	<1		
DES-1224-53A	Drew ES	1st Floor - In Auditorium	12/24/14	<1		
DES-1224-54B	Drew ES	1st Floor - In Auditorium	12/24/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
DHS-0210-1A	Dunbar HS	4th floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-1B	Dunbar HS	4th floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-2A	Dunbar HS	4th floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-2B	Dunbar HS	4th floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-3A	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-3B	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-4A	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-4B	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-5A	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-5B	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-6A	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-6B	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-7A	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (high)	2/10/15	<1		
DHS-0210-7B	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (high)	2/10/15	<1		
DHS-0210-8A	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (low)	2/10/15	<1		
DHS-0210-8B	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (low)	2/10/15	<1		
DHS-0210-9A	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (high)	2/10/15	<1		
DHS-0210-9B	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (high)	2/10/15	<1		
DHS-0210-10A	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (low)	2/10/15	<1		
DHS-0210-10B	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (low)	2/10/15	<1		
DHS-0210-11A	Dunbar HS	1st floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-11B	Dunbar HS	1st floor hallway between Men's and Women's Rooms (high)	2/10/15	<1		
DHS-0210-12A	Dunbar HS	1st floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-12B	Dunbar HS	1st floor hallway between Men's and Women's Rooms (low)	2/10/15	<1		
DHS-0210-13A	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (high)	2/10/15	<1		
DHS-0210-13B	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (high)	2/10/15	<1		
DHS-0210-14A	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (low)	2/10/15	<1		
DHS-0210-14B	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (low)	2/10/15	<1		
DHS-0210-15A	Dunbar HS	1st floor inside Gym (high)	2/10/15	<1		
DHS-0210-15B	Dunbar HS	1st floor inside Gym (high)	2/10/15	<1		
DHS-0210-16A	Dunbar HS	1st floor inside Gym (low)	2/10/15	<1		
DHS-0210-16B	Dunbar HS	1st floor inside Gym (low)	2/10/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
DE-1211-1A	Duke Ellington School of Arts	2nd floor hallway between men's and women's room	12/11/14	<1		
DE-1211-2B	Duke Ellington School of Arts	2nd floor hallway between men's and women's room	12/11/14	<1		
DE-1211-3A	Duke Ellington School of Arts	1st floor hallway adjacent to room 143	12/11/14	<1		
DE-1211-4B	Duke Ellington School of Arts	1st floor hallway adjacent to room 143	12/11/14	<1		
DE-1211-5A	Duke Ellington School of Arts	1st floor hallway across from Cafeteria	12/11/14	<1		
DE-1211-6B	Duke Ellington School of Arts	1st floor hallway across from Cafeteria	12/11/14	<1		
DE-1211-7A	Duke Ellington School of Arts	In B flat building, adjacent to staff restroom	12/11/14	<1		
DE-1211-8B	Duke Ellington School of Arts	In B flat building, adjacent to staff restroom	12/11/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
EHS-0205-1A	Eastern HS	4th floor hallway across from Classroom E415 (high)	2/5/15	<1		
EHS-0205-1B	Eastern HS	4th floor hallway across from Classroom E415 (high)	2/5/15	<1		
EHS-0205-2A	Eastern HS	4th floor hallway across from Classroom E415 (low)	2/5/15	<1		
EHS-0205-2B	Eastern HS	4th floor hallway across from Classroom E415 (low)	2/5/15	<1		
EHS-0205-3A	Eastern HS	3rd floor hallway across from Classroom W311 (high)	2/5/15	<1		
EHS-0205-3B	Eastern HS	3rd floor hallway across from Classroom W311 (high)	2/5/15	<1		
EHS-0205-4A	Eastern HS	3rd floor hallway across from Classroom W311 (low)	2/5/15	<1		
EHS-0205-4B	Eastern HS	3rd floor hallway across from Classroom W311 (low)	2/5/15	<1		
EHS-0205-5A	Eastern HS	3rd floor hallway across from Classroom E316 (high)	2/5/15	<1		
EHS-0205-5B	Eastern HS	3rd floor hallway across from Classroom E316 (high)	2/5/15	<1		
EHS-0205-6A	Eastern HS	3rd floor hallway across from Classroom E316 (low)	2/5/15	<1		
EHS-0205-6B	Eastern HS	3rd floor hallway across from Classroom E316 (low)	2/5/15	<1		
EHS-0205-7A	Eastern HS	2nd floor hallway across from Classroom W212 (high)	2/5/15	<1		
EHS-0205-7B	Eastern HS	2nd floor hallway across from Classroom W212 (high)	2/5/15	<1		
EHS-0205-8A	Eastern HS	2nd floor hallway across from Classroom W212 (low)	2/5/15	<1		
EHS-0205-8B	Eastern HS	2nd floor hallway across from Classroom W212 (low)	2/5/15	<1		
EHS-0205-9A	Eastern HS	2nd floor hallway across from Classroom E218 (high)	2/5/15	<1		
EHS-0205-9B	Eastern HS	2nd floor hallway across from Classroom E218 (high)	2/5/15	<1		
EHS-0205-10A	Eastern HS	2nd floor hallway across from Classroom E218 (low)	2/5/15	<1		
EHS-0205-10B	Eastern HS	2nd floor hallway across from Classroom E218 (low)	2/5/15	<1		
EHS-0205-11A	Eastern HS	1st floor hallway across from Gym (high)	2/5/15	<1		
EHS-0205-11B	Eastern HS	1st floor hallway across from Gym (high)	2/5/15	<1		
EHS-0205-12A	Eastern HS	1st floor hallway across from Gym (low)	2/5/15	<1		
EHS-0205-12B	Eastern HS	1st floor hallway across from Gym (low)	2/5/15	<1		
EHS-0205-13A	Eastern HS	1st floor hallway across from Health Clinic W130 (high)	2/5/15	<1		
EHS-0205-13B	Eastern HS	1st floor hallway across from Health Clinic W130 (high)	2/5/15	<1		
EHS-0205-14A	Eastern HS	1st floor hallway across from Health Clinic W130 (low)	2/5/15	<1		
EHS-0205-14B	Eastern HS	1st floor hallway across from Health Clinic W130 (low)	2/5/15	<1		
EHS-0205-15A	Eastern HS	Basement floor inside Cafeteria (high)	2/5/15	<1		
EHS-0205-15B	Eastern HS	Basement floor inside Cafeteria (high)	2/5/15	<1		
EHS-0205-16A	Eastern HS	Basement floor inside Cafeteria (low)	2/5/15	<1		
EHS-0205-16B	Eastern HS	Basement floor inside Cafeteria (low)	2/5/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
EES W 0518-1A	Eaton ES	3rd Floor hallway	5/18/15	<1		
EES W 0518-1B	Eaton ES	3rd Floor hallway	5/18/15	<1		
EES W 0518-2A	Eaton ES	2nd Floor hallway	5/18/15	<1		
EES W 0518-2B	Eaton ES	2nd Floor hallway	5/18/15	<1		
EES W 0518-3A	Eaton ES	2nd Floor inside class room 209B	5/18/15	<1		
EES W 0518-3B	Eaton ES	2nd Floor inside class room 209B	5/18/15	<1		
EES W 0518-4A	Eaton ES	1st Floor inside office 102D	5/18/15	<1		
EES W 0518-4B	Eaton ES	1st Floor inside office 102D	5/18/15	<1		
EES 0518-5A	Eaton ES	1st Floor hallway at main entrance (High)	5/18/15	<1		
EES 0518-5B	Eaton ES	1st Floor hallway at main entrance (High)	5/18/15	<1		
EES 0518-6A	Eaton ES	1st Floor hallway at main entrance (low)	5/18/15	<1		
EES 0518-6B	Eaton ES	1st Floor hallway at main entrance (low)	5/18/15	<1		
EES E 0518-7A	Eaton ES	3rd Floor hallway adjacent to classroom 313	5/18/15	<1		
EES E 0518-7B	Eaton ES	3rd Floor hallway adjacent to classroom 313	5/18/15	<1		
EES E 0518-8A	Eaton ES	2nd Floor hallway adjacent to classroom 218	5/18/15	<1		
EES E 0518-8B	Eaton ES	2nd Floor hallway adjacent to classroom 218	5/18/15	<1		
EES E 0518-9A	Eaton ES	1st Floor hallway adjacent to classroom 119	5/18/15	<1		
EES E 0518-9B	Eaton ES	1st Floor hallway adjacent to classroom 119	5/18/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
EH-0128-1A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-266	1/28/15	<1		
EH-0128-1B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-266	1/28/15	<1		
EH-0128-2A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-262	1/28/15	<1		
EH-0128-2B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-262	1/28/15	<1		
EH-0128-3A	Eliot-Hine MS	3rd floor hallway adjacent to Staff Resource Room 3-255	1/28/15	<1		
EH-0128-3B	Eliot-Hine MS	3rd floor hallway adjacent to Staff Resource Room 3-255	1/28/15	<1		
EH-0128-4A	Eliot-Hine MS	2nd floor hallway adjacent to Computer Lab 2-198	1/28/15	<1		
EH-0128-4B	Eliot-Hine MS	2nd floor hallway adjacent to Computer Lab 2-198	1/28/15	<1		
EH-0128-5A	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-210	1/28/15	<1		
EH-0128-5B	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-210	1/28/15	<1		
EH-0128-6A	Eliot-Hine MS	1st floor hallway adjacent to Office 1-152	1/28/15	<1		
EH-0128-6B	Eliot-Hine MS	1st floor hallway adjacent to Office 1-152	1/28/15	<1		
EH-0128-7A	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-166	1/28/15	<1		
EH-0128-7B	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-166	1/28/15	<1		
EH-0128-8A	Eliot-Hine MS	1st floor hallway across from Classroom 1-077	1/28/15	<1		
EH-0128-8B	Eliot-Hine MS	1st floor hallway across from Classroom 1-077	1/28/15	<1		
EH-0128-9A	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-070	1/28/15	<1		
EH-0128-9B	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-070	1/28/15	<1		
EH-0128-10A	Eliot-Hine MS	1st floor hallway across from Principal's Office 1-099	1/28/15	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MDL-4-21-14B	Mamie D Lee ES	CLASSROOM 15	4/21/15	<1		
MDL-4-21-15A	Mamie D Lee ES	CLASSROOM 14	4/21/15	<1		
MDL-4-21-15B	Mamie D Lee ES	CLASSROOM 14	4/21/15	<1		
MDL-4-21-16A	Mamie D Lee ES	CLASSROOM 14	4/21/15	<1		
MDL-4-21-16B	Mamie D Lee ES	CLASSROOM 14	4/21/15	<1		
MDL-4-21-17A	Mamie D Lee ES	1ST FLOOR CORRIDOR WEST	4/21/15	<1		
MDL-4-21-17B	Mamie D Lee ES	1ST FLOOR CORRIDOR WEST	4/21/15	<1		
MDL-4-21-18A	Mamie D Lee ES	CLASSROOM 13	4/21/15	<1		
MDL-4-21-18B	Mamie D Lee ES	CLASSROOM 13	4/21/15	<1		
MDL-4-21-19A	Mamie D Lee ES	CLASSROOM 12	4/21/15	<1		
MDL-4-21-19B	Mamie D Lee ES	CLASSROOM 12	4/21/15	<1		
MDL-4-21-20A	Mamie D Lee ES	CLASSROOM 11	4/21/15	<1		
MDL-4-21-20B	Mamie D Lee ES	CLASSROOM 11	4/21/15	<1		
MDL-4-21-21A	Mamie D Lee ES	CLASSROOM 10	4/21/15	<1		
MDL-4-21-21B	Mamie D Lee ES	CLASSROOM 10	4/21/15	<1		
MDL-4-21-22A	Mamie D Lee ES	2ND FLOOR CORRIDOR WEST	4/21/15	<1		
MDL-4-21-22B	Mamie D Lee ES	2ND FLOOR CORRIDOR WEST	4/21/15	<1		
MDL-4-21-23A	Mamie D Lee ES	DENTAL/NURSES OFFICE	4/21/15	<1		
MDL-4-21-23B	Mamie D Lee ES	DENTAL/NURSES OFFICE	4/21/15	<1		
MDL-4-21-24A	Mamie D Lee ES	KITCHEN	4/21/15	<1		
MDL-4-21-24B	Mamie D Lee ES	KITCHEN	4/21/15	<1		
MDL-4-21-25A	Mamie D Lee ES	CAFETERIA	4/21/15	<1		
MDL-4-21-25B	Mamie D Lee ES	CAFETERIA	4/21/15	<1		
MDL-4-21-26A	Mamie D Lee ES	1ST FLOOR EAST CORRIDOR	4/21/15	<1		
MDL-4-21-26B	Mamie D Lee ES	1ST FLOOR EAST CORRIDOR	4/21/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
ME-0622-1A	Mann ES	2nd Floor hallway adjacent to room 229	6/22/15			
ME-0622-1B	Mann ES	2nd Floor hallway adjacent to room 229	6/22/15			
ME-0622-2A	Mann ES	2nd Floor hallway adjacent to room 235	6/22/15			
ME-0622-2B	Mann ES	2nd Floor hallway adjacent to room 235	6/22/15			
ME-0622-3A	Mann ES	2nd Floor hallway adjacent to room 226	6/22/15			
ME-0622-3B	Mann ES	2nd Floor hallway adjacent to room 226	6/22/15			
ME-0622-4A	Mann ES	1st Floor adjacent to room 156 A	6/22/15			
ME-0622-4B	Mann ES	1st Floor hallway adjacent to room 156A	6/22/15			
ME-0622-5A	Mann ES	1st Floor hallway adjacent to room 150	6/22/15			
ME-0622-5B	Mann ES	1st Floor hallway adjacent to room 150	6/22/15			
ME-0622-6A	Mann ES	1st Floor inside classroom 138	6/22/15			
ME-0622-6B	Mann ES	1st Floor inside classroom 138	6/22/15			
ME-0622-7A	Mann ES	1st Floor inside classroom 142	6/22/15			
ME-0622-7B	Mann ES	1st Floor inside classroom 142	6/22/15			
ME-0622-8A	Mann ES	1st Floor inside classroom 146	6/22/15			
ME-0622-8B	Mann ES	1st Floor inside classroom 146	6/22/15			
ME-0622-9A	Mann ES	1st Floor inside classroom 150	6/22/15			
ME-0622-9B	Mann ES	1st Floor inside classroom 150	6/22/15			
ME-0622-10A	Mann ES	1st Floor inside classroom 154	6/22/15			
ME-0622-10B	Mann ES	1st Floor inside classroom 154	6/22/15			
ME-0622-11A	Mann ES	1st Floor hallway adjacent to health suite 157B	6/22/15			
ME-0622-11B	Mann ES	1st Floor hallway adjacent to health suite 157B	6/22/15			
ME-0622-12A	Mann ES	1st Floor hallway adjacent to room 134	6/22/15			
ME-0622-12B	Mann ES	1st Floor hallway adjacent to room 134	6/22/15			
ME-0622-13A	Mann ES	3rd Floor hallway adjacent to Room 303	6/22/15			
ME-0622-13B	Mann ES	3rd Floor hallway adjacent to Room 303	6/22/15			
ME-0622-14A	Mann ES	3rd Floor hallway adjacent to Elevator Machine room 317	6/22/15			
ME-0622-14B	Mann ES	3rd Floor hallway adjacent to Elevator Machine room 317	6/22/15			
Percentage of Passed Samples						0.00%
Percentage of Failed Samples						0.00%
MR-1210-1A	Marie Reed LC	2nd floor adjacent to Teacher's Room	12/10/14	<1		
MR-1210-2B	Marie Reed LC	2nd floor adjacent to Teacher's Room	12/10/14	<1		
MR-1210-3A	Marie Reed LC	2nd floor adjacent to Electric Box H2-WA	12/10/14	<1		
MR-1210-4B	Marie Reed LC	2nd floor adjacent to Electric Box H2-WA	12/10/14	<1		
MR-1210-5A	Marie Reed LC	2nd floor adjacent to Custodian Closet 4	12/10/14	<1		
MR-1210-6B	Marie Reed LC	2nd floor adjacent to Custodian Closet 4	12/10/14	<1		
MR-1210-7A	Marie Reed LC	2nd floor near Arts and Science Room 1	12/10/14	<1		
MR-1210-8B	Marie Reed LC	2nd floor near Arts and Science Room 1	12/10/14	<1		
MR-1210-9A	Marie Reed LC	2nd floor adjacent to Custodian Closet 1	12/10/14	<1		
MR-1210-10B	Marie Reed LC	2nd floor adjacent to Custodian Closet 1	12/10/14	<1		
MR-1210-11A	Marie Reed LC	2nd floor near Arts and Science Room 6	12/10/14	<1		
MR-1210-12B	Marie Reed LC	2nd floor near Arts and Science Room 6	12/10/14	<1		
MR-1210-13A	Marie Reed LC	2nd floor near Arts and Science Room 7	12/10/14	<1		
MR-1210-14B	Marie Reed LC	2nd floor near Arts and Science Room 7	12/10/14	<1		
MR-1210-15A	Marie Reed LC	2nd floor adjacent to Custodian Closet 2	12/10/14	<1		
MR-1210-16B	Marie Reed LC	2nd floor adjacent to Custodian Closet 2	12/10/14	<1		
MR-1210-17A	Marie Reed LC	1st floor inside small Cafeteria	12/10/14	<1		
MR-1210-18B	Marie Reed LC	1st floor inside small Cafeteria	12/10/14	<1		
MR-1210-19A	Marie Reed LC	1st floor near Main Office	12/10/14	<1		
MR-1210-20B	Marie Reed LC	1st floor near Main Office	12/10/14	<1		
MR-1210-21A	Marie Reed LC	1st floor inside Main Office adj to Principal's Office	12/10/14	<1		
MR-1210-22B	Marie Reed LC	1st floor inside Main Office adj to Principal's Office	12/10/14	1B		
MR-1210-23A	Marie Reed LC	1st floor at Main Entrance	12/10/14	<1		
MR-1210-24B	Marie Reed LC	1st floor at Main Entrance	12/10/14	<1		
MR-1210-25A	Marie Reed LC	Basement floor adjacent to Boy's Room	12/10/14	1A		
MR-1210-26B	Marie Reed LC	Basement floor adjacent to Boy's Room	12/10/14	<1		
MR-1210-27A	Marie Reed LC	Basement floor adjacent to Girl's Room	12/10/14	<1		
MR-1210-28B	Marie Reed LC	Basement floor adjacent to Girl's Room	12/10/14	<1		
MR-1210-29A	Marie Reed LC	Basement floor inside Gym	12/10/14	<1		
MR-1210-30B	Marie Reed LC	Basement floor inside Gym	12/10/14	<1		
MR-1210-31A	Marie Reed LC	1st floor at entrance to large Cafeteria	12/10/14	<1		
MR-1210-32B	Marie Reed LC	1st floor at entrance to large Cafeteria	12/10/14	<1		
MR-1210-33A	Marie Reed LC	Basement floor adjacent to Girl's Dressing Room	12/10/14	2.5		
MR-1210-34B	Marie Reed LC	Basement floor adjacent to Girl's Dressing Room	12/10/14	2.8		
MR-1210-35A	Marie Reed LC	1st floor across from Storage Room 11	12/10/14	<1		
MR-1210-36B	Marie Reed LC	1st floor across from Storage Room 11	12/10/14	<1		
MR-1210-37A	Marie Reed LC	1st floor between Stairwell 7 and sink	12/10/14	<1		
MR-1210-38B	Marie Reed LC	1st floor between Stairwell 7 and sink	12/10/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
MES-1231-1A	Mauy ES	1st Floor Hallway adjacent to E121	12/31/14	<1		
MES-1231-2B	Mauy ES	1st floor hallway adjacent to E121	12/31/14	<1		
MES-1231-3A	Mauy ES	1st floor inside Multipurpose room adjacent to Kitchen	12/31/14	<1		
MES-1231-4B	Mauy ES	1st floor inside Multipurpose room adjacent to Kitchen	12/31/14	<1		
MES-1231-5A	Mauy ES	1st Floor inside Classroom E125	12/31/14	<1		
MES-1231-6B	Mauy ES	1st Floor inside Classroom E125	12/31/14	<1		
MES-1231-7A	Mauy ES	1st Floor inside Classroom E140	12/31/14	<1		
MES-1231-8B	Mauy ES	1st Floor inside Classroom E140	12/31/14	<1		
MES-1231-9A	Mauy ES	1st Floor inside Classroom E135	12/31/14	<1		
MES-1231-10B	Mauy ES	1st Floor inside Classroom E135	12/31/14	<1		
MES-1231-11A	Mauy ES	Basement Floor inside Classroom W010	12/31/14	<1		
MES-1231-12B	Mauy ES	Basement Floor inside Classroom W010	12/31/14	<1		
MES-1231-13A	Mauy ES	Basement Floor inside Classroom W030	12/31/14	<1		
MES-1231-14B	Mauy ES	Basement Floor inside Classroom W030	12/31/14	<1		
MES-1231-15A	Mauy ES	Basement floor lobby adjacent to Storage room W022 (high)	12/31/14	<1		
MES-1231-16B	Mauy ES	Basement floor lobby adjacent to Storage room W022 (high)	12/31/14	1.1		
MES-1231-17A	Mauy ES	Basement floor lobby adjacent to Storage room W022 (low)	12/31/14	1.2		
MES-1231-18B	Mauy ES	Basement floor lobby adjacent to Storage room W022 (low)	12/31/14	<1		
MES-1231-19A	Mauy ES	1st Floor in Stairwell ST4	12/31/14	<1		
MES-1231-20B	Mauy ES	1st Floor in Stairwell ST4	12/31/14	<1		
MES-1231-21A	Mauy ES	2nd Floor in Stairwell ST4	12/31/14	<1		
MES-1231-22B	Mauy ES	2nd Floor in Stairwell ST4	12/31/14	<1		
MES-1231-23A	Mauy ES	2nd Floor Hallway adjacent to Class room E213	12/31/14	<1		
MES-1231-24B	Mauy ES	2nd Floor Hallway adjacent to Class room E213	12/31/14	<1		
MES-1231-25A	Mauy ES	2nd Floor inside Classroom E230	12/31/14	<1		
MES-1231-26B	Mauy ES	2nd Floor inside Classroom E230	12/31/14	<1		
MES-1231-27A	Mauy ES	2nd Floor inside Classroom E240	12/31/14	<1		
MES-1231-28B	Mauy ES	2nd Floor inside Classroom E240	12/31/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
MRL-0713-1A	Mary Reed LC	First floor hallway near the main entrance on the left	7/13/15	<1		
MRL-0713-1B	Mary Reed LC	First floor hallway near the main entrance on the left	7/13/15	<1		
MRL-0713-2A	Mary Reed LC	First floor hallway near the general office & girls rest room	7/13/15	<1		
MRL-0713-2B	Mary Reed LC	First floor hallway near the general office & girls rest room	7/13/15	<1		
MRL-0713-3A	Mary Reed LC	First floor inside small cafeteria	7/13/15	1.3		
MRL-0713-3B	Mary Reed LC	First floor hallway small cafeteria	7/13/15	1.1		
MRL-0713-4A	Mary Reed LC	First floor near Auditorium entrance	7/13/15	<1		
MRL-0713-4B	Mary Reed LC	First floor near Auditorium entrance	7/13/15	<1		
MRL-0713-5A	Mary Reed LC	First floor early childhood	7/13/15	<1		
MRL-0713-5B	Mary Reed LC	First floor early childhood	7/13/15	<1		
MRL-0713-6A	Mary Reed LC	First floor early childhood across storage 11	7/13/15	<1		
MRL-0713-6B	Mary Reed LC	First floor early childhood across storage 11	7/13/15	<1		
MRL-0713-7A	Mary Reed LC	First floor inside main office	7/13/15	<1		
MRL-0713-7B	Mary Reed LC	First floor inside main office	7/13/15	<1		
MRL-0713-8A	Mary Reed LC	Second floor near stairwell 1	7/13/15	2.1		
MRL-0713-8B	Mary Reed LC	Second floor near stairwell 1	7/13/15	<1		
MRL-0713-9A	Mary Reed LC	Second floor near stairwell 2	7/13/15	<1		
MRL-0713-9B	Mary Reed LC	Second floor near stairwell 2	7/13/15	<1		
MRL-0713-10A	Mary Reed LC	Second floor near stairwell 3	7/13/15	<1		
MRL-0713-10B	Mary Reed LC	Second floor near stairwell 3	7/13/15	<1		
MRL-0713-11A	Mary Reed LC	Second floor near stairwell 4	7/13/15	<1		
MRL-0713-11B	Mary Reed LC	Second floor near stairwell 4	7/13/15	<1		
MRL-0713-12A	Mary Reed LC	Second floor near stairwell 5	7/13/15	2		
MRL-0713-12B	Mary Reed LC	Second floor near stairwell 5	7/13/15	1.1		
MRL-0713-13A	Mary Reed LC	Second floor near stairwell 6	7/13/15	<1		
MRL-0713-13B	Mary Reed LC	Second floor near stairwell 6	7/13/15	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MRL-0713-14A	Mary Reed LC	Second floor near stairwell 7	7/13/15	<1	<1	
MRL-0713-14B	Mary Reed LC	Second floor near stairwell 7	7/13/15	<1	<1	
MRL-0713-15A	Mary Reed LC	Second floor near stairwell 8	7/13/15	<1	<1	
MRL-0713-15B	Mary Reed LC	Second floor near stairwell 8	7/13/15	<1	<1	
MRL-0713-16A	Mary Reed LC	Auditorium music practice	7/13/15	3.1		
MRL-0713-16B	Mary Reed LC	Auditorium music practice	7/13/15	3.3		
MRL-0713-17A	Mary Reed LC	Medical clinic near reception	7/13/15	<1	<1	
MRL-0713-17B	Mary Reed LC	Medical clinic near reception	7/13/15	1.4		
MRL-0713-18A	Mary Reed LC	Rear of the clinic near women's rest room	7/13/15	1.2		
MRL-0713-18B	Mary Reed LC	Rear of the clinic near women's rest room	7/13/15	2.1		
MRL-0713-19A	Mary Reed LC	UPO	7/13/15	5.9		
MRL-0713-19B	Mary Reed LC	UPO	7/13/15	<1	18	Filter Installed
MRL-0713-20A	Mary Reed LC	Swimming pool	7/13/15	<1	<1	
MRL-0713-20B	Mary Reed LC	Swimming pool	7/13/15	<1	<1	
MRL-0713-21A	Mary Reed LC	Swimming pool near men's rest room	7/13/15	1.3		
MRL-0713-21B	Mary Reed LC	Swimming pool near men's rest room	7/13/15	1.4		
MRL-0713-22A	Mary Reed LC	Swimming pool inside men's locker room	7/13/15	4.4		
MRL-0713-22B	Mary Reed LC	Swimming pool inside men's locker room	7/13/15	7.3		
MRL-0713-23A	Mary Reed LC	Outside Soccerfield (high)	7/13/15	1.1		
MRL-0713-23B	Mary Reed LC	Outside Soccerfield (high)	7/13/15	<1	<1	
MRL-0713-24A	Mary Reed LC	Outside Soccerfield(low)	7/13/15	<1	<1	
MRL-0713-24B	Mary Reed LC	Outside Soccerfield(low)	7/13/15	<1	<1	
MRL-0713-25A	Mary Reed LC	Recreation center gym	7/13/15	<1	<1	
MRL-0713-25B	Mary Reed LC	Recreation center gym	7/13/15	<1	<1	
MRL-0713-26A	Mary Reed LC	Near mail rest room	7/13/15	2.5		
MRL-0713-26B	Mary Reed LC	Near mail rest room	7/13/15	3.3		
MRL-0713-27A	Mary Reed LC	Near women's rest room outside the gym	7/13/15	<1	<1	
MRL-0713-27B	Mary Reed LC	Near women's rest room outside the gym	7/13/15	<1	<1	
				Percentage of Passed Samples		98.15%
				Percentage of Failed Samples		1.85%
MH-0326-1A	McKinley HS	3rd Floor hallway across classroom 366	3/26/15	<1	<1	
MH-0326-1B	McKinley HS	3rd Floor hallway across classroom 366	3/26/15	<1	<1	
MH-0326-2A	McKinley HS	3rd Floor hallway across classroom 3370-A	3/26/15	<1	<1	
MH-0326-2B	McKinley HS	3rd Floor hallway across classroom 3370-A	3/26/15	<1	<1	
MH-0326-3A	McKinley HS	2nd Floor hallway across classroom 266-B	3/26/15	<1	<1	
MH-0326-3B	McKinley HS	2nd Floor hallway across classroom 266-B	3/26/15	<1	<1	
MH-0326-4A	McKinley HS	2nd Floor hallway across classroom 266-A	3/26/15	<1	<1	
MH-0326-4B	McKinley HS	2nd Floor hallway across classroom 266-A	3/26/15	<1	<1	
MH-0326-5A	McKinley HS	1st Floor hallway across classroom 158	3/26/15	<1	<1	
MH-0326-5B	McKinley HS	1st Floor hallway across classroom 158	3/26/15	<1	<1	
MH-0326-6A	McKinley HS	1st Floor hallway girl's rest room adjacent to room 159	3/26/15	<1	<1	
MH-0326-6B	McKinley HS	1st Floor hallway girl's rest room adjacent to room 159	3/26/15	<1	<1	
MH-0326-7A	McKinley HS	2nd Floor hallway at Gym (high)	3/26/15	<1	<1	
MH-0326-7B	McKinley HS	2nd Floor hallway at Gym (high)	3/26/15	<1	<1	
MH-0326-8A	McKinley HS	1st Floor hallway at Gym (high)	3/26/15	<1	<1	
MH-0326-8B	McKinley HS	1st Floor hallway at Gym (high)	3/26/15	<1	<1	
MH-0326-9A	McKinley HS	1st Floor hallway at Gym (low)	3/26/15	<1	<1	
MH-0326-9B	McKinley HS	1st Floor hallway at Gym (low)	3/26/15	<1	<1	
MH-0326-10A	McKinley HS	1st Floor hallway across room G103 (high)	3/26/15	<1	<1	
MH-0326-10B	McKinley HS	1st Floor hallway across room G103 (high)	3/26/15	<1	<1	
MH-0326-11A	McKinley HS	1st Floor hallway across room G103 (low)	3/26/15	<1	<1	
MH-0326-11B	McKinley HS	1st Floor hallway across room G103 (low)	3/26/15	<1	<1	
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
MM-0326-1A	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (high)	3/26/15	<1	<1	
MM-0326-1B	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (high)	3/26/15	<1	<1	
MM-0326-2A	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (low)	3/26/15	<1	<1	
MM-0326-2B	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (low)	3/26/15	<1	<1	
MM-0326-3A	McKinley MS	1st floor hallway adjacent to room 114F (high)	3/26/15	<1	<1	
MM-0326-3B	McKinley MS	1st floor hallway adjacent to room 114F (high)	3/26/15	<1	<1	
MM-0326-4A	McKinley MS	1st floor hallway adjacent to room 114F (low)	3/26/15	<1	<1	
MM-0326-4B	McKinley MS	1st floor hallway adjacent to room 114F (low)	3/26/15	<1	<1	
MM-0326-5A	McKinley MS	1st Floor hallway across 115F (high)	3/26/15	<1	<1	
MM-0326-5B	McKinley MS	1st Floor hallway across 115F (high)	3/26/15	<1	<1	
MM-0326-6A	McKinley MS	1st Floor hallway across 115F (low)	3/26/15	<1	<1	
MM-0326-6B	McKinley MS	1st Floor hallway across 115F (low)	3/26/15	<1	<1	
MM-0326-7A	McKinley MS	3rd Floor hallway adjacent to room 302 (high)	3/26/15	<1	<1	
MM-0326-7B	McKinley MS	3rd Floor hallway adjacent to room 302 (high)	3/26/15	<1	<1	
MM-0326-8A	McKinley MS	3rd Floor hallway adjacent to room 302 (low)	3/26/15	<1	<1	
MM-0326-8B	McKinley MS	3rd Floor hallway adjacent to room 302 (low)	3/26/15	<1	<1	
MM-0326-9A	McKinley MS	2nd Floor hallway adjacent to room 202 (high)	3/26/15	<1	<1	
MM-0326-9B	McKinley MS	2nd Floor hallway adjacent to room 202 (high)	3/26/15	<1	<1	
MM-0326-10A	McKinley MS	2nd Floor hallway adjacent to room 202 (low)	3/26/15	<1	<1	
MM-0326-10B	McKinley MS	2nd Floor hallway adjacent to room 202 (low)	3/26/15	<1	<1	
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
EME-0708-1A	Meyer ES	Second Floor hallway adjacent to Rm 215	7/8/15	<1	<1	
EME-0708-1B	Meyer ES	Second Floor hallway adjacent to Rm 215	7/8/15	<1	<1	
EME-0708-2A	Meyer ES	Second Floor hallway adjacent to women's rest room near Rm 205	7/8/15	<1	<1	
EME-0708-2B	Meyer ES	Second Floor hallway adjacent to women's rest room near Rm 205	7/8/15	<1	<1	
EME-0708-3A	Meyer ES	First Floor hallway adjacent to Rm 143	7/8/15	<1	<1	
EME-0708-3B	Meyer ES	First Floor hallway adjacent to Rm 143	7/8/15	<1	<1	
EME-0708-4A	Meyer ES	First Floor hallway adjacent to women's & men's rest rooms	7/8/15	<1	<1	
EME-0708-4B	Meyer ES	First Floor hallway adjacent to women's & men's rest rooms	7/8/15	<1	<1	
EME-0708-5A	Meyer ES	First Floor Hallway across Rm 115	7/8/15	<1	<1	
EME-0708-5B	Meyer ES	First Floor Hallway across Rm 115	7/8/15	<1	<1	
EME-0708-6A	Meyer ES	Basement Hallway adjacent to rest rooms near Rm 5	7/8/15	<1	<1	
EME-0708-6B	Meyer ES	Basement Hallway adjacent to rest rooms near Rm 5	7/8/15	<1	<1	
EME-0708-7A	Meyer ES	Basement hallway across Rm14	7/8/15	<1	<1	
EME-0708-7B	Meyer ES	Basement hallway across Rm14	7/8/15	<1	<1	
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
MES-0326-1A	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (high)	3/26/15	<1	<1	
MES-0326-1B	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (high)	3/26/15	<1	<1	
MES-0326-2A	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (low)	3/26/15	<1	<1	
MES-0326-2B	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (low)	3/26/15	<1	<1	
MES-0326-3A	Miner ES	2nd floor inside Classroom 215	3/26/15	<1	<1	
MES-0326-3B	Miner ES	2nd floor inside Classroom 215	3/26/15	<1	<1	
MES-0326-4A	Miner ES	2nd floor inside Classroom 217	3/26/15	<1	<1	
MES-0326-4B	Miner ES	2nd floor inside Classroom 217	3/26/15	<1	<1	
MES-0326-5A	Miner ES	2nd floor inside Classroom 219	3/26/15	<1	<1	
MES-0326-5B	Miner ES	2nd floor inside Classroom 219	3/26/15	<1	<1	
MES-0326-6A	Miner ES	2nd floor inside Classroom 213	3/26/15	<1	<1	
MES-0326-6B	Miner ES	2nd floor inside Classroom 213	3/26/15	<1	<1	
MES-0326-7A	Miner ES	2nd floor inside Classroom 231	3/26/15	<1	<1	
MES-0326-7B	Miner ES	2nd floor inside Classroom 231	3/26/15	<1	<1	
MES-0326-8A	Miner ES	2nd floor inside Classroom 233	3/26/15	<1	<1	
MES-0326-8B	Miner ES	2nd floor inside Classroom 233	3/26/15	<1	<1	
MES-0326-9A	Miner ES	2nd floor inside Classroom 251	3/26/15	<1	<1	
MES-0326-9B	Miner ES	2nd floor inside Classroom 251	3/26/15	<1	<1	
MES-0326-10A	Miner ES	2nd floor hallway adjacent to Room 228 Planning, in open area	3/26/15	<1	<1	
MES-0326-10B	Miner ES	2nd floor hallway adjacent to Room 228 Planning, in open area	3/26/15	<1	<1	
MES-0326-11A	Miner ES	2nd floor inside Classroom 253	3/26/15	<1	<1	
MES-0326-11B	Miner ES	2nd floor inside Classroom 253	3/26/15	<1	<1	
MES-0326-12A	Miner ES	2nd floor inside Classroom 234	3/26/15	<1	<1	
MES-0326-12B	Miner ES	2nd floor inside Classroom 234	3/26/15	<1	<1	
MES-0326-13A	Miner ES	2nd floor inside Classroom 238	3/26/15	<1	89	Filter Installed
MES-0326-13B	Miner ES	2nd floor inside Classroom 238	3/26/15	5.1		
MES-0326-14A	Miner ES	2nd floor hallway across from Art Room 255 (high)	3/26/15	<1	<1	
MES-0326-14B	Miner ES	2nd floor hallway across from Art Room 255 (high)	3/26/15	<1	<1	
MES-0326-15A	Miner ES	2nd floor hallway across from Art Room 255 (low)	3/26/15	<1	<1	
MES-0326-15B	Miner ES	2nd floor hallway across from Art Room 255 (low)	3/26/15	<1	<1	
MES-0326-16A	Miner ES	2nd floor inside Classroom 211	3/26/15	<1	<1	
MES-0326-16B	Miner ES	2nd floor inside Classroom 211	3/26/15	<1	<1	
MES-0326-17A	Miner ES	2nd floor inside Classroom 209	3/26/15	<1	<1	
MES-0326-17B	Miner ES	2nd floor inside Classroom 209	3/26/15	<1	<1	
MES-0326-18A	Miner ES	1st floor hallway across from Cafeteria (high)	3/26/15	<1	<1	
MES-0326-18B	Miner ES	1st floor hallway across from Cafeteria (high)	3/26/15	<1	<1	
MES-0326-19A	Miner ES	1st floor hallway across from Cafeteria (low)	3/26/15	<1	<1	
MES-0326-19B	Miner ES	1st floor hallway across from Cafeteria (low)	3/26/15	<1	<1	
MES-0326-20A	Miner ES	1st floor hallway across from Gym (high)	3/26/15	<1	<1	
MES-0326-20B	Miner ES	1st floor hallway across from Gym (high)	3/26/15	<1	<1	
MES-0326-21A	Miner ES	1st floor hallway across from Gym (low)	3/26/15	<1	<1	
MES-0326-21B	Miner ES	1st floor hallway across from Gym (low)	3/26/15	<1	<1	
MES-0326-22A	Miner ES	1st floor inside Classroom 132	3/26/15	<1	<1	
MES-0326-22B	Miner ES	1st floor inside Classroom 132	3/26/15	<1	<1	
MES-0326-23A	Miner ES	1st floor inside Classroom 130	3/26/15	<1	<1	
MES-0326-23B	Miner ES	1st floor inside Classroom 130	3/26/15	<1	<1	
MES-0326-24A	Miner ES	1st floor inside Classroom 137	3/26/15	<1	<1	
MES-0326-24B	Miner ES	1st floor inside Classroom 137	3/26/15	<1	<1	
MES-0326-25A	Miner ES	1st floor inside Classroom 135	3/26/15	<1	<1	
MES-0326-25B	Miner ES	1st floor inside Classroom 135	3/26/15	<1	<1	
MES-0326-26A	Miner ES	1st floor inside Classroom 133	3/26/15	<1	<1	
MES-0326-26B	Miner ES	1st floor inside Classroom 133	3/26/15	<1	<1	
MES-0326-27A	Miner ES	1st floor inside Classroom 131	3/26/15	<1	<1	
MES-0326-27B	Miner ES	1st floor inside Classroom 131	3/26/15	<1	<1	
MES-0326-28A	Miner ES	1st floor inside Classroom 129	3/26/15	<1	<1	
MES-0326-28B	Miner ES	1st floor inside Classroom 129	3/26/15	<1	<1	
MES-0326-29A	Miner ES	1st floor inside Classroom 127	3/26/15	<1	<1	
MES-0326-29B	Miner ES	1st floor inside Classroom 127	3/26/15	<1	<1	
MES-0326-30A	Miner ES	1st floor inside Classroom 121	3/26/15	<1	<1	
MES-0326-30B	Miner ES	1st floor inside Classroom 121	3/26/15	<1	<1	
MES-0326-31A	Miner ES	1st floor inside Classroom 117	3/26/15	<1	<1	

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
RE-0226-7A	Raymond ES	1st Floor inside classroom 116	2/28/15	<1		
RE-0226-7B	Raymond ES	1st Floor inside classroom 116	2/28/15	<1		
RE-0226-8A	Raymond ES	1st Floor hallway across classroom 115	2/28/15	<1		
RE-0226-8B	Raymond ES	1st Floor hallway across classroom 115	2/28/15	<1		
RE-0226-9A	Raymond ES	1st Floor inside classroom 115	2/28/15	1.7		
RE-0226-9B	Raymond ES	1st Floor inside classroom 115	2/28/15	<1		
RE-0226-10A	Raymond ES	1st Floor inside classroom 113	2/28/15	<1		
RE-0226-10B	Raymond ES	1st Floor inside classroom 113	2/28/15	<1		
RE-0226-11A	Raymond ES	1st Floor inside classroom 110	2/28/15	<1		
RE-0226-11B	Raymond ES	1st Floor inside classroom 110	2/28/15	<1		
RE-0226-12A	Raymond ES	1st Floor hallway adjacent to classroom 110	2/28/15	<1		
RE-0226-12B	Raymond ES	1st Floor hallway adjacent to classroom 110	2/28/15	<1		
RE-0226-13A	Raymond ES	1st Floor inside classroom 111	2/28/15	<1		
RE-0226-13B	Raymond ES	1st Floor inside classroom 111	2/28/15	<1		
RE-0226-14A	Raymond ES	1st Floor hallway adjacent to main office	2/28/15	<1		
RE-0226-14B	Raymond ES	1st Floor hallway adjacent to main office	2/28/15	<1		
RE-0226-15A	Raymond ES	1st Floor hallway across the Kitchen	2/28/15	<1		
RE-0226-15B	Raymond ES	1st Floor hallway across the Kitchen	2/28/15	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
RE-0624-1A	Ross ES	Basement inside cafeteria (high)	6/24/15			
RE-0624-1B	Ross ES	Basement inside cafeteria (high)	6/24/15			
RE-0624-2A	Ross ES	Basement inside cafeteria (low)	6/24/15			
RE-0624-2B	Ross ES	Basement inside cafeteria (low)	6/24/15			
RE-0624-3A	Ross ES	Basement hallway across main office (high)	6/24/15			
RE-0624-3B	Ross ES	Basement hallway across main office (high)	6/24/15			
RE-0624-4A	Ross ES	Basement hallway across main office (low)	6/24/15			
RE-0624-4B	Ross ES	Basement hallway across main office (low)	6/24/15			
RE-0624-5A	Ross ES	1st Floor hallway adjacent to room 105 (high)	6/24/15			
RE-0624-5B	Ross ES	1st Floor hallway adjacent to room 105 (high)	6/24/15			
RE-0624-6A	Ross ES	1st Floor hallway adjacent to room 105 (low)	6/24/15			
RE-0624-6B	Ross ES	1st Floor hallway adjacent to room 105 (low)	6/24/15			
RE-0624-7A	Ross ES	2nd Floor hallway adjacent to room 204 (low)	6/24/15			
RE-0624-7B	Ross ES	2nd Floor hallway adjacent to room 204 (low)	6/24/15			
RE-0624-8A	Ross ES	2nd Floor hallway adjacent to room 204 (high)	6/24/15			
RE-0624-8B	Ross ES	2nd Floor hallway adjacent to room 204 (high)	6/24/15			
			Percentage of Passed Samples			0.00%
			Percentage of Failed Samples			0.00%
SES-0602-1A	Savoy ES	3rd Floor hallway across room 300 (high)	6/2/15	<1		
SES-0602-1B	Savoy ES	3rd Floor hallway across room 300 (high)	6/2/15	<1		
SES-0602-2A	Savoy ES	3rd Floor hallway across room 300 (low)	6/2/15	<1		
SES-0602-2B	Savoy ES	3rd Floor hallway across room 300 (low)	6/2/15	<1		
SES-0602-3A	Savoy ES	3rd Floor hallway across room 307 (high)	6/2/15	<1		
SES-0602-3B	Savoy ES	3rd Floor hallway across room 307 (high)	6/2/15	<1		
SES-0602-4A	Savoy ES	3rd Floor hallway across room 307 (low)	6/2/15	<1		
SES-0602-4B	Savoy ES	3rd Floor hallway across room 307 (low)	6/2/15	<1		
SES-0602-5A	Savoy ES	2nd Floor adjacent to room 203 (high)	6/2/15	<1		
SES-0602-5B	Savoy ES	2nd Floor adjacent to room 203 (high)	6/2/15	<1		
SES-0602-6A	Savoy ES	2nd Floor adjacent to room 203 (low)	6/2/15	<1		
SES-0602-6B	Savoy ES	2nd Floor adjacent to room 203 (low)	6/2/15	<1		
SES-0602-7A	Savoy ES	2nd Floor hallway across room 209 (high)	6/2/15	<1		
SES-0602-7B	Savoy ES	2nd Floor hallway across room 209 (high)	6/2/15	<1		
SES-0602-8A	Savoy ES	2nd Floor hallway across room 209 (low)	6/2/15	<1		
SES-0602-8B	Savoy ES	2nd Floor hallway across room 209 (low)	6/2/15	<1		
SES-0602-9A	Savoy ES	1st Floor inside class room 109	6/2/15	<1		
SES-0602-9B	Savoy ES	1st Floor inside class room 109	6/2/15	<1		
SES-0602-10A	Savoy ES	1st Floor inside class room 111	6/2/15	<1		
SES-0602-10B	Savoy ES	1st Floor inside class room 111	6/2/15	<1		
SES-0602-11A	Savoy ES	1st Floor inside class room 113	6/2/15	<1		
SES-0602-11B	Savoy ES	1st Floor inside class room 113	6/2/15	<1		
SES-0602-12A	Savoy ES	1st Floor inside class room 115	6/2/15	<1		
SES-0602-12A	Savoy ES	1st Floor inside class room 115	6/2/15	<1		
SES-0602-13A	Savoy ES	1st Floor inside class room 122	6/2/15	<1		
SES-0602-13B	Savoy ES	1st Floor inside class room 122	6/2/15	<1		
SES-0602-14A	Savoy ES	1st Floor inside class room 120	6/2/15	<1		
SES-0602-14B	Savoy ES	1st Floor inside class room 120	6/2/15	<1		
SES-0602-15A	Savoy ES	1st Floor hallway across room 107 (high)	6/2/15	<1		
SES-0602-15B	Savoy ES	1st Floor hallway across room 107 (high)	6/2/15	<1		
SES-0602-16A	Savoy ES	1st Floor hallway across room 107 (low)	6/2/15	<1		
SES-0602-16B	Savoy ES	1st Floor hallway across room 107 (low)	6/2/15	<1		
SES-0602-17A	Savoy ES	1st Floor hallway adjacent to cafeteria (high)	6/2/15	<1		
SES-0602-17B	Savoy ES	1st Floor hallway adjacent to cafeteria (high)	6/2/15	<1		
SES-0602-18A	Savoy ES	1st Floor hallway adjacent to cafeteria (low)	6/2/15	<1		
SES-0602-18B	Savoy ES	1st Floor hallway adjacent to cafeteria (low)	6/2/15	<1		
SES-0602-19A	Savoy ES	2nd Floor inside library (high)	6/2/15	<1		
SES-0602-19B	Savoy ES	2nd Floor inside library (high)	6/2/15	<1		
SES-0602-20A	Savoy ES	2nd Floor inside library (low)	6/2/15	<1		
SES-0602-20B	Savoy ES	2nd Floor inside library (low)	6/2/15	<1		
SES-0602-21A	Savoy ES	1st Floor lobby at TMA office (high)	6/2/15	<1		
SES-0602-21B	Savoy ES	1st Floor lobby at TMA office (high)	6/2/15	<1		
SES-0602-22A	Savoy ES	1st Floor lobby at TMA office (low)	6/2/15	<1		
SES-0602-22B	Savoy ES	1st Floor lobby at TMA office (low)	6/2/15	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
SWW-0129-1A	School Without Walls HS	3RD Floor Hallway across room 306 (High)	1/29/15	<1		
SWW-0129-1B	School Without Walls HS	3RD Floor Hallway across room 306 (High)	1/29/15	<1		
SWW-0129-2A	School Without Walls HS	3RD Floor Hallway across room 306 (Low)	1/29/15	<1		
SWW-0129-2B	School Without Walls HS	3RD Floor Hallway across room 306 (Low)	1/29/15	<1		
SWW-0129-3A	School Without Walls HS	2nd Floor hallway across room 206 (High)	1/29/15	<1		
SWW-0129-3B	School Without Walls HS	2nd Floor hallway across room 206 (High)	1/29/15	<1		
SWW-0129-4A	School Without Walls HS	2nd Floor hallway across room 206 (Low)	1/29/15	<1		
SWW-0129-4B	School Without Walls HS	2nd Floor hallway across room 206 (Low)	1/29/15	<1		
SWW-0129-5A	School Without Walls HS	1st Floor hallway across room 106 (High)	1/29/15	<1		
SWW-0129-5B	School Without Walls HS	1st Floor hallway across room 106 (High)	1/29/15	<1		
SWW-0129-6A	School Without Walls HS	1st Floor hallway across room 106 (Low)	1/29/15	<1		
SWW-0129-6B	School Without Walls HS	1st Floor hallway across room 106 (Low)	1/29/15	<1		
SWW-0129-7A	School Without Walls HS	Basement floor hallway adjacent to room 07 (High)	1/29/15	<1		
SWW-0129-7B	School Without Walls HS	Basement floor hallway adjacent to room 07 (High)	1/29/15	<1		
SWW-0129-8A	School Without Walls HS	Basement floor hallway adjacent to room 07 (Low)	1/29/15	<1		
SWW-0129-8B	School Without Walls HS	Basement floor hallway adjacent to room 07 (Low)	1/29/15	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
SEG-0423-1A	Seaton ES	3rd floor hallway adjacent to Girls Room	4/23/15	<1		
SEG-0423-1B	Seaton ES	3rd floor hallway adjacent to Girls Room	4/23/15	<1		
SEG-0423-2A	Seaton ES	3rd floor hallway adjacent to Room 306	4/23/15	<1		
SEG-0423-2B	Seaton ES	3rd floor hallway adjacent to Room 306	4/23/15	<1		
SEG-0423-3A	Seaton ES	2nd floor hallway adjacent to Girls Room	4/23/15	<1		
SEG-0423-3B	Seaton ES	2nd floor hallway adjacent to Girls Room	4/23/15	<1		
SEG-0423-4A	Seaton ES	2nd floor hallway adjacent to Room 206	4/23/15	<1		
SEG-0423-4B	Seaton ES	2nd floor hallway adjacent to Room 206	4/23/15	<1		
SEG-0423-5A	Seaton ES	1st floor inside Room 124	4/23/15	<1		
SEG-0423-5B	Seaton ES	1st floor inside Room 124	4/23/15	<1		
SEG-0423-6A	Seaton ES	1st floor inside Room 127	4/23/15	<1		
SEG-0423-6B	Seaton ES	1st floor inside Room 127	4/23/15	<1		
SEG-0423-7A	Seaton ES	1st floor inside Room 122	4/23/15	<1		
SEG-0423-7B	Seaton ES	1st floor inside Room 122	4/23/15	<1		
SEG-0423-8A	Seaton ES	1st floor inside Room 125	4/23/15	<1		
SEG-0423-8B	Seaton ES	1st floor inside Room 125	4/23/15	<1		
SEG-0423-9A	Seaton ES	1st floor inside Cafe/Gym	4/23/15	<1		
SEG-0423-9B	Seaton ES	1st floor inside Cafe/Gym	4/23/15	<1		
SEG-0423-10A	Seaton ES	1st floor inside Room 109	4/23/15	<1		
SEG-0423-10B	Seaton ES	1st floor inside Room 109	4/23/15	<1		
SEG-0423-11A	Seaton ES	1st floor hallway adjacent to Girls Room	4/23/15	<1		
SEG-0423-11B	Seaton ES	1st floor hallway adjacent to Girls Room	4/23/15	<1		
SEG-0423-12A	Seaton ES	1st floor hallway adjacent to Room 106	4/23/15	1.8		
SEG-0423-12B	Seaton ES	1st floor hallway adjacent to Room 106	4/23/15	<1		
SEG-0423-13A	Seaton ES	1st floor inside Room 111	4/23/15	<1		
SEG-0423-13B	Seaton ES	1st floor inside Room 111	4/23/15	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
SE-0701-1A	Seaton ES	Third Floor inside Rm 307	7/1/15	<1		
SE-0701-1B	Seaton ES	Third Floor inside Rm 307	7/1/15	<1		
SE-0701-2A	Seaton ES	Third Floor inside Rm 309	7/1/15	<1		
SE-0701-2B	Seaton ES	Third Floor inside Rm 309	7/1/15	<1		
SE-0701-3A	Seaton ES	Third Floor Hallway adjacent to Rm 306	7/1/15	1.1		
SE-0701-3B	Seaton ES	Third Floor Hallway adjacent to Rm 306	7/1/15	<1		
SE-0701-4A	Seaton ES	Third Floor Hallway adjacent to Girls' room	7/1/15	<1		
SE-0701-4B	Seaton ES	Third Floor Hallway adjacent to Girls' room	7/1/15	<1		
SE-0701-5A	Seaton ES	Second Floor Hallway adjacent to Rm 206	7/1/15	<1		
SE-0701-5B	Seaton ES	Second Floor Hallway adjacent to Rm 206	7/1/15	<1		
SE-0701-6A	Seaton ES	Second Floor Hallway adjacent to girls' room	7/1/15	<1		
SE-0701-6B	Seaton ES	Second Floor Hallway adjacent to girls' room	7/1/15	<1		
SE-0701-7A	Seaton ES	First Floor Hallway adjacent to Rm 106	7/1/15	<1		
SE-0701-7B	Seaton ES	First Floor Hallway adjacent to Rm 106	7/1/15	<1		
SE-0701-8A	Seaton ES	First Floor Hallway adjacent to restrooms	7/1/15	<1		
SE-0701-8B	Seaton ES	First Floor Hallway adjacent to restrooms	7/1/15	<1		
SE-0701-9A	Seaton ES	First Floor Hallway adjacent to Rm 109	7/1/15	<1		
SE-0701-9B	Seaton ES	First Floor Hallway adjacent to Rm 109	7/1/15	<1		
SE-0701-10A	Seaton ES	First Floor Hallway adjacent to Rm 111	7/1/15	<1		
SE-0701-10B	Seaton ES	First Floor Hallway adjacent to Rm 111	7/1/15	<1		
SE-0701-11A	Seaton ES	First Floor inside nurse's room	7/1/15	<1		
SE-0701-11B	Seaton ES	First Floor inside nurse's room	7/1/15	<1		
SE-0701-12A	Seaton ES	First Floor inside cafeteria	7/1/15	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SM-0310-28A	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 5)	3/10/15	<1		
SM-0310-28B	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 5)	3/10/15	<1		
SM-0310-29A	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 6)	3/10/15	<1		
SM-0310-29B	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 6)	3/10/15	<1		
SM-0310-30A	Sousa MS	2nd Floor hallway across classroom A202 (high)	3/10/15	<1		
SM-0310-30B	Sousa MS	2nd Floor hallway across classroom A202 (high)	3/10/15	<1		
SM-0310-31A	Sousa MS	2nd Floor hallway across classroom A202 (low)	3/10/15	<1		
SM-0310-31B	Sousa MS	2nd Floor hallway across classroom A202 (low)	3/10/15	<1		
SM-0310-32A	Sousa MS	1st Floor hallway adjacent to classroom C101 (high)	3/10/15	<1		
SM-0310-32B	Sousa MS	1st Floor hallway adjacent to classroom C101 (high)	3/10/15	<1		
SM-0310-33A	Sousa MS	1st Floor hallway adjacent to classroom C101 (low)	3/10/15	<1		
SM-0310-33B	Sousa MS	1st Floor hallway adjacent to classroom C101 (low)	3/10/15	<1		
SM-0310-34A	Sousa MS	1st Floor hallway across classroom A102 (high)	3/10/15	<1		
SM-0310-34B	Sousa MS	1st Floor hallway across classroom A102 (high)	3/10/15	<1		
SM-0310-35A	Sousa MS	1st Floor hallway across classroom A102 (low)	3/10/15	<1		
SM-0310-35B	Sousa MS	1st Floor hallway across classroom A102 (low)	3/10/15	<1		
SM-0310-36A	Sousa MS	1st Floor inside classroom B104 (science room- clockwise sink 1)	3/10/15	11		
SM-0310-36B	Sousa MS	1st Floor inside classroom B104 (science room- clockwise sink 1)	3/10/15	<1		
SM-0310-37A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 2)	3/10/15	7.5		
SM-0310-37B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 2)	3/10/15	<1		
SM-0310-38A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 3)	3/10/15	3.2		
SM-0310-38B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 3)	3/10/15	3.8		
SM-0310-39A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 4)	3/10/15		250	Filter Installed
SM-0310-39B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 4)	3/10/15		19	Filter Installed
SM-0310-40A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 5)	3/10/15	6.7		
SM-0310-40B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 5)	3/10/15	1.8		
SM-0310-41A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 6)	3/10/15	<1		
SM-0310-41B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 6)	3/10/15	<1		
SM-0310-42A	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (high)	3/10/15	<1		
SM-0310-42B	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (high)	3/10/15	<1		
SM-0310-43A	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (low)	3/10/15	<1		
SM-0310-43B	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (low)	3/10/15	<1		
SM-0310-44A	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	<1		
SM-0310-44B	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	<1		
SM-0310-45A	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	<1		
SM-0310-45B	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	<1		
Percentage of Passed Samples						94.44%
Percentage of Failed Samples						5.56%
STE-0603-1A	Stanton ES	3rd Floor hallway across class room 314 (high)	6/3/15	<1		
STE-0603-1B	Stanton ES	3rd Floor hallway across class room 314 (high)	6/3/15	<1		
STE-0603-2A	Stanton ES	3rd Floor hallway across class room 314 (low)	6/3/15	<1		
STE-0603-2B	Stanton ES	3rd Floor hallway across class room 314 (low)	6/3/15	<1		
STE-0603-3A	Stanton ES	3rd Floor hallway across class room 310 (high)	6/3/15	<1		
STE-0603-3B	Stanton ES	3rd Floor hallway across class room 310 (high)	6/3/15	<1		
STE-0603-4A	Stanton ES	3rd Floor hallway across class room 310 (low)	6/3/15	<1		
STE-0603-4B	Stanton ES	3rd Floor hallway across class room 310 (low)	6/3/15	<1		
STE-0603-5A	Stanton ES	2nd Floor hallway across class room 207 (high)	6/3/15	<1		
STE-0603-5B	Stanton ES	2nd Floor hallway across class room 207 (high)	6/3/15	<1		
STE-0603-6A	Stanton ES	2nd Floor hallway across class room 207 (low)	6/3/15	<1		
STE-0603-6B	Stanton ES	2nd Floor hallway across class room 207 (low)	6/3/15	<1		
STE-0603-7A	Stanton ES	2nd Floor hallway adjacent to class room 212 (high)	6/3/15	<1		
STE-0603-7B	Stanton ES	2nd Floor hallway adjacent to class room 212 (high)	6/3/15	<1		
STE-0603-8A	Stanton ES	2nd Floor hallway adjacent to class room 212 (low)	6/3/15	<1		
STE-0603-8B	Stanton ES	2nd Floor hallway adjacent to class room 212 (low)	6/3/15	<1		
STE-0603-9A	Stanton ES	1st Floor hallway across room 116 (high)	6/3/15	<1		
STE-0603-9B	Stanton ES	1st Floor hallway across room 116 (high)	6/3/15	<1		
STE-0603-10A	Stanton ES	1st Floor hallway across room 116 (low)	6/3/15	<1		
STE-0603-10B	Stanton ES	1st Floor hallway across room 116 (low)	6/3/15	<1		
STE-0603-11A	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (high)	6/3/15	<1		
STE-0603-11B	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (high)	6/3/15	<1		
STE-0603-12A	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (low)	6/3/15	<1		
STE-0603-12B	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (low)	6/3/15	<1		
STE-0603-13A	Stanton ES	Basement Floor hallway adjacent to B106A/janitor closet (high)	6/3/15	<1		
STE-0603-13B	Stanton ES	Basement Floor hallway adjacent to B106A/janitor closet (high)	6/3/15	<1		
STE-0603-14A	Stanton ES	Basement Floor hallway adjacent to B106A/janitor closet (low)	6/3/15	<1		
STE-0603-14B	Stanton ES	Basement Floor hallway adjacent to B106A/janitor closet (low)	6/3/15	<1		
STE-0603-15A	Stanton ES	Basement Floor inside cafeteria	6/3/15	<1		
STE-0603-15B	Stanton ES	Basement Floor inside cafeteria	6/3/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SE-0320-1A	Stoddert ES	1st Floor inside classroom 142	3/20/15	<1		
SE-0320-1B	Stoddert ES	1st Floor inside classroom 142	3/20/15	<1		
SE-0320-2A	Stoddert ES	1st Floor inside classroom 144	3/20/15	<1		
SE-0320-2B	Stoddert ES	1st Floor inside classroom 144	3/20/15	<1		
SE-0320-3A	Stoddert ES	1st Floor inside classroom 147	3/20/15	<1		
SE-0320-3B	Stoddert ES	1st Floor inside classroom 147	3/20/15	<1		
SE-0320-4A	Stoddert ES	1st Floor inside classroom 145	3/20/15	<1		
SE-0320-4B	Stoddert ES	1st Floor inside classroom 145	3/20/15	<1		
SE-0320-5A	Stoddert ES	1st Floor inside classroom 146	3/20/15	<1		
SE-0320-5B	Stoddert ES	1st Floor inside classroom 146	3/20/15	<1		
SE-0320-6A	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	<1		
SE-0320-6B	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	<1		
SE-0320-7A	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	<1		
SE-0320-7B	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	<1		
SE-0320-8A	Stoddert ES	1st Floor inside classroom 132	3/20/15	<1		
SE-0320-8B	Stoddert ES	1st Floor inside classroom 132	3/20/15	<1		
SE-0320-9A	Stoddert ES	1st Floor inside classroom 133	3/20/15	<1		
SE-0320-9B	Stoddert ES	1st Floor inside classroom 133	3/20/15	<1		
SE-0320-10A	Stoddert ES	1st Floor inside classroom 134	3/20/15	<1		
SE-0320-10B	Stoddert ES	1st Floor inside classroom 134	3/20/15	<1		
SE-0320-11A	Stoddert ES	1st Floor inside classroom 131	3/20/15	<1		
SE-0320-11B	Stoddert ES	1st Floor inside classroom 131	3/20/15	<1		
SE-0320-12A	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	<1		
SE-0320-12B	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	<1		
SE-0320-13A	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	<1		
SE-0320-13B	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	<1		
SE-0320-14A	Stoddert ES	2nd Floor inside classroom 230	3/20/15	<1		
SE-0320-14B	Stoddert ES	2nd Floor inside classroom 230	3/20/15	<1		
SE-0320-15A	Stoddert ES	2nd Floor inside classroom 231	3/20/15	<1		
SE-0320-15B	Stoddert ES	2nd Floor inside classroom 231	3/20/15	<1		
SE-0320-16A	Stoddert ES	2nd Floor inside classroom 232	3/20/15	<1		
SE-0320-16B	Stoddert ES	2nd Floor inside classroom 232	3/20/15	<1		
SE-0320-17A	Stoddert ES	2nd Floor inside classroom 233	3/20/15	<1		
SE-0320-17B	Stoddert ES	2nd Floor inside classroom 233	3/20/15	<1		
SE-0320-18A	Stoddert ES	2nd Floor inside classroom 234	3/20/15	<1		
SE-0320-18B	Stoddert ES	2nd Floor inside classroom 234	3/20/15	<1		
SE-0320-19A	Stoddert ES	2nd Floor inside classroom 245	3/20/15	<1		
SE-0320-19B	Stoddert ES	2nd Floor inside classroom 245	3/20/15	<1		
SE-0320-20A	Stoddert ES	2nd Floor inside classroom 246	3/20/15	<1		
SE-0320-20B	Stoddert ES	2nd Floor inside classroom 246	3/20/15	<1		
SE-0320-21A	Stoddert ES	2nd Floor inside classroom 247	3/20/15	1		
SE-0320-21B	Stoddert ES	2nd Floor inside classroom 247	3/20/15	2.1		
SE-0320-22A	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	<1		
SE-0320-22B	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	<1		
SE-0320-23A	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	<1		
SE-0320-23B	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SH-0702-1A	Stuart Hobson MS	Second Floor Hallway adjacent to Rm 218	7/2/15	<1		
SH-0702-1B	Stuart Hobson MS	Second Floor Hallway adjacent to Rm 218	7/2/15	<1		
SH-0702-2A	Stuart Hobson MS	Second Floor Hallway across Rm 205	7/2/15	<1		
SH-0702-2B	Stuart Hobson MS	Second Floor Hallway across Rm 205	7/2/15	<1		
SH-0702-3A	Stuart Hobson MS	Third Floor Hallway adjacent to Rm 312	7/2/15	<1		
SH-0702-3B	Stuart Hobson MS	Third Floor Hallway adjacent to Rm 312	7/2/15	<1		
SH-0702-4A	Stuart Hobson MS	First Floor Hallway across Rm 109	7/2/15	<1		
SH-0702-4B	Stuart Hobson MS	First Floor Hallway across Rm 109	7/2/15	<1		
SH-0702-5A	Stuart Hobson MS	First Floor Hallway across Rm 118	7/2/15	1.1		
SH-0702-5B	Stuart Hobson MS	First Floor Hallway across Rm 118	7/2/15	1.2		
SH-0702-6A	Stuart Hobson MS	First Floor Hallway across Rm 105	7/2/15	<1		
SH-0702-6B	Stuart Hobson MS	First Floor Hallway across Rm 105	7/2/15	<1		
SH-0702-7A	Stuart Hobson MS	First Floor inside Health Room 104	7/2/15	<1		
SH-0702-7B	Stuart Hobson MS	First Floor inside Health Room 104	7/2/15	<1		
SH-0702-8A	Stuart Hobson MS	Basement Hallway near Rm G-09	7/2/15	<1		
SH-0702-8B	Stuart Hobson MS	Basement Hallway near Rm G-09	7/2/15	<1		
SH-0702-9A	Stuart Hobson MS	Inside Cafeteria Left	7/2/15	<1		
SH-0702-9B	Stuart Hobson MS	Inside Cafeteria Left	7/2/15	<1		
SH-0702-10A	Stuart Hobson MS	Inside Cafeteria Right	7/2/15	<1		
SH-0702-10B	Stuart Hobson MS	Inside Cafeteria Right	7/2/15	<1		
SH-0702-11A	Stuart Hobson MS	Basement Hallway near Rm G-05	7/2/15	<1		
SH-0702-11B	Stuart Hobson MS	Basement Hallway near Rm G-05	7/2/15	<1		
SH-0702-12A	Stuart Hobson MS	Basement Hallway near Gym G-15 H	7/2/15	<1		
SH-0702-12B	Stuart Hobson MS	Basement Hallway near Gym G-15 H	7/2/15	<1		
SH-0702-13A	Stuart Hobson MS	Basement Hallway near Gym G-15 L	7/2/15	<1		
SH-0702-13B	Stuart Hobson MS	Basement Hallway near Gym G-15 L	7/2/15	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
TEC-0709-1A	Takoma EC	Third Floor hallway between stair 2 & elevator 323 high	7/9/15	<1		
TEC-0709-1B	Takoma EC	Third Floor hallway between stair 2 & elevator 323 high	7/9/15	<1		
TEC-0709-2A	Takoma EC	Third Floor hallway between stair 2 & elevator 323 low	7/9/15	<1		
TEC-0709-2B	Takoma EC	Third Floor hallway between stair 2 & elevator 323 low	7/9/15	<1		
TEC-0709-3A	Takoma EC	Third Floor hallway between stair 4 & elevator 327 high	7/9/15	<1		
TEC-0709-3B	Takoma EC	Third Floor hallway between stair 4 & elevator 327 high	7/9/15	<1		
TEC-0709-4A	Takoma EC	Third Floor hallway between stair 4 & elevator 327 low	7/9/15	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WHS-0723-37B	Wilson HS	Second floor inside fitness center (low)	7/23/15			
WHS-0723-38A	Wilson HS	First floor inside girls' locker room (high)	7/23/15			
WHS-0723-38B	Wilson HS	First floor inside girls' locker room (high)	7/23/15			
WHS-0723-39A	Wilson HS	First floor inside girls' locker room (low)	7/23/15			
WHS-0723-39B	Wilson HS	First floor inside girls' locker room (low)	7/23/15			
				Percentage of Passed Samples		0.00%
				Percentage of Failed Samples		0.00%
HDW-0324-1A	Woodson SHS (H.D.) HS	3rd floor hallway adjacent to Lab 342	3/24/15	<1		
HDW-0324-1B	Woodson SHS (H.D.) HS	3rd floor hallway adjacent to Lab 342	3/24/15	<1		
HDW-0324-2A	Woodson SHS (H.D.) HS	3rd floor hallway adjacent to Lab 333	3/24/15	<1		
HDW-0324-2B	Woodson SHS (H.D.) HS	3rd floor hallway adjacent to Lab 333	3/24/15	<1		
HDW-0324-3A	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Main Office (high)	3/24/15	<1		
HDW-0324-3B	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Main Office (high)	3/24/15	<1		
HDW-0324-4A	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Main Office (low)	3/24/15	<1		
HDW-0324-4B	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Main Office (low)	3/24/15	<1		
HDW-0324-5A	Woodson SHS (H.D.) HS	1st floor inside Cafeteria (high)	3/24/15	<1		
HDW-0324-5B	Woodson SHS (H.D.) HS	1st floor inside Cafeteria (high)	3/24/15	<1		
HDW-0324-6A	Woodson SHS (H.D.) HS	1st floor inside Cafeteria (low)	3/24/15	<1		
HDW-0324-6B	Woodson SHS (H.D.) HS	1st floor inside Cafeteria (low)	3/24/15	<1		
HDW-0324-7A	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Ticket Room 153 (high)	3/24/15	<1		
HDW-0324-7B	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Ticket Room 153 (high)	3/24/15	<1		
HDW-0324-8A	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Ticket Room 153 (low)	3/24/15	<1		
HDW-0324-8B	Woodson SHS (H.D.) HS	1st floor hallway adjacent to Ticket Room 153 (low)	3/24/15	<1		
HDW-0324-9A	Woodson SHS (H.D.) HS	Lower level inside Pool Room (high)	3/24/15	<1		
HDW-0324-9B	Woodson SHS (H.D.) HS	Lower level inside Pool Room (high)	3/24/15	<1		
HDW-0324-10A	Woodson SHS (H.D.) HS	Lower level inside Pool Room (low)	3/24/15	<1		
HDW-0324-10B	Woodson SHS (H.D.) HS	Lower level inside Pool Room (low)	3/24/15	<1		
HDW-0324-11A	Woodson SHS (H.D.) HS	Lower level hallway near Stair 3 (high)	3/24/15	<1		
HDW-0324-11B	Woodson SHS (H.D.) HS	Lower level hallway near Stair 3 (high)	3/24/15	<1		
HDW-0324-12A	Woodson SHS (H.D.) HS	Lower level hallway near Stair 3 (low)	3/24/15	<1		
HDW-0324-12B	Woodson SHS (H.D.) HS	Lower level hallway near Stair 3 (low)	3/24/15	<1		
HDW-0324-13A	Woodson SHS (H.D.) HS	Lower level inside Big Gym (high)	3/24/15	<1		
HDW-0324-13B	Woodson SHS (H.D.) HS	Lower level inside Big Gym (high)	3/24/15	<1		
HDW-0324-14A	Woodson SHS (H.D.) HS	Lower level inside Big Gym (low)	3/24/15	<1		
HDW-0324-14B	Woodson SHS (H.D.) HS	Lower level inside Big Gym (low)	3/24/15	<1		
HDW-0324-15A	Woodson SHS (H.D.) HS	Lower level inside Small Gym (high)	3/24/15	<1		
HDW-0324-15B	Woodson SHS (H.D.) HS	Lower level inside Small Gym (high)	3/24/15	<1		
HDW-0324-16A	Woodson SHS (H.D.) HS	Lower level inside Small Gym (low)	3/24/15	<1		
HDW-0324-16B	Woodson SHS (H.D.) HS	Lower level inside Small Gym (low)	3/24/15	<1		
HDW-0324-17A	Woodson SHS (H.D.) HS	Lower level inside Weight Room (high)	3/24/15	<1		
HDW-0324-17B	Woodson SHS (H.D.) HS	Lower level inside Weight Room (high)	3/24/15	<1		
HDW-0324-18A	Woodson SHS (H.D.) HS	Lower level inside Weight Room (low)	3/24/15	<1		
HDW-0324-18B	Woodson SHS (H.D.) HS	Lower level inside Weight Room (low)	3/24/15	<1		
HDW-0324-19A	Woodson SHS (H.D.) HS	2nd floor hallway adjacent to Electric Room 222 (high)	3/24/15	<1		
HDW-0324-19B	Woodson SHS (H.D.) HS	2nd floor hallway adjacent to Electric Room 222 (high)	3/24/15	<1		
HDW-0324-20A	Woodson SHS (H.D.) HS	2nd floor hallway adjacent to Electric Room 222 (low)	3/24/15	<1		
HDW-0324-20B	Woodson SHS (H.D.) HS	2nd floor hallway adjacent to Electric Room 222 (low)	3/24/15	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
Totals/Percentages of All Tested Schools						
			Total Number of Schools Tested	96		
			Total Passed Samples	3536		
			Total Failed Samples	19		
			Total Samples Collected	3555		
			Percentage of Passed Samples	99.47%		
			Percentage of Failed Samples	0.53%		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AES-0501-1A	Adams ES	3rd floor hallway across from Classroom 312	5/1/14	<1		
AES-0501-1B	Adams ES	3rd floor hallway across from Classroom 312	5/1/14	<1		
AES-0501-2A	Adams ES	3rd floor hallway across from Classroom 316	5/1/14	<1		
AES-0501-2B	Adams ES	3rd floor hallway across from Classroom 316	5/1/14	<1		
AES-0501-3A	Adams ES	2nd floor hallway adjacent to Classroom 201	5/1/14	<1		
AES-0501-3B	Adams ES	2nd floor hallway adjacent to Classroom 201	5/1/14	<1		
AES-0501-4A	Adams ES	2nd floor at Gym exit (left)	5/1/14	<1		
AES-0501-4B	Adams ES	2nd floor at Gym exit (left)	5/1/14	<1		
AES-0501-5A	Adams ES	2nd floor hallway adjacent to Classroom 202	5/1/14	<1		
AES-0501-5B	Adams ES	2nd floor hallway adjacent to Classroom 202	5/1/14	<1		
AES-0501-6A	Adams ES	Ground floor inside Classroom 102	5/1/14	<1		
AES-0501-6B	Adams ES	Ground floor inside Classroom 102	5/1/14	<1		
AES-0501-7A	Adams ES	Ground floor inside Cafeteria	5/1/14	<1		
AES-0501-7B	Adams ES	Ground floor inside Cafeteria	5/1/14	<1		
AES-0501-8A	Adams ES	Ground floor across from Classroom 110	5/1/14	<1		
AES-0501-8B	Adams ES	Ground floor across from Classroom 110	5/1/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
AES-0115-1A	Aiton ES	4th Fl hall across from elevator	1/15/14	<1		
AES-0115-1B	Aiton ES	4th Fl hall across from elevator	1/15/14	<1		
AES-0115-2A	Aiton ES	2nd floor hallway adjacent to Room 234 Assistant Principal (high)	1/15/14	<1		
AES-0115-2B	Aiton ES	4th Fl across from North Stairwell	1/15/14	<1		
AES-0115-3A	Aiton ES	3rd Fl hall across from elevator	1/15/14	<1		
AES-0115-3B	Aiton ES	3rd Fl hall across from elevator	1/15/14	<1		
AES-0115-4A	Aiton ES	3rd Fl hall across from North Stairwell	1/15/14	<1		
AES-0115-4B	Aiton ES	3rd Fl hall across from North Stairwell	1/15/14	<1		
AES-0115-5A	Aiton ES	2nd Fl hall across from elevator	1/15/14	<1		
AES-0115-5B	Aiton ES	2nd Fl hall across from elevator	1/15/14	<1		
AES-0115-6A	Aiton ES	2nd Fl hall across from North Stairwell	1/15/14	<1		
AES-0115-6B	Aiton ES	2nd Fl hall across from North Stairwell	1/15/14	<1		
AES-0115-7A	Aiton ES	1st Fl in Classroom Kindergarten 2	1/15/14	<1		
AES-0115-7B	Aiton ES	1st Fl in Classroom Kindergarten 2	1/15/14	<1		
AES-0115-8A	Aiton ES	1st Fl in Classroom Kindergarten 1	1/15/14	<1		
AES-0115-8B	Aiton ES	1st Fl in Classroom Kindergarten 1	1/15/14	<1		
AES-0115-9A	Aiton ES	1st Fl hall adj to Custodian Closet	1/15/14	<1		
AES-0115-9B	Aiton ES	1st Fl hall adj to Custodian Closet	1/15/14	<1		
AES-0115-10A	Aiton ES	1st Fl in Main Lobby	1/15/14	<1		
AES-0115-10B	Aiton ES	1st Fl in Main Lobby	1/15/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
AES-0211-1A	Amidon ES	2nd floor inside Classroom A212	2/11/14	<1		
AES-0211-1B	Amidon ES	2nd floor inside Classroom A212	2/11/14	<1		
AES-0211-2A	Amidon ES	2nd floor inside Classroom A213	2/11/14	<1		
AES-0211-2B	Amidon ES	2nd floor inside Classroom A213	2/11/14	<1		
AES-0211-3A	Amidon ES	2nd floor inside Classroom A208	2/11/14	<1		
AES-0211-3B	Amidon ES	2nd floor inside Classroom A208	2/11/14	<1		
AES-0211-4A	Amidon ES	2nd floor inside Classroom A209	2/11/14	<1		
AES-0211-4B	Amidon ES	2nd floor inside Classroom A209	2/11/14	<1		
AES-0211-5A	Amidon ES	2nd floor inside Classroom A202	2/11/14	<1		
AES-0211-5B	Amidon ES	2nd floor inside Classroom A202	2/11/14	<1		
AES-0211-6A	Amidon ES	2nd floor inside Classroom B230	2/11/14	<1		
AES-0211-6B	Amidon ES	2nd floor inside Classroom B230	2/11/14	<1		
AES-0211-7A	Amidon ES	2nd floor inside Classroom B223	2/11/14	<1		
AES-0211-7B	Amidon ES	2nd floor inside Classroom B223	2/11/14	<1		
AES-0211-8A	Amidon ES	2nd floor inside Classroom B225	2/11/14	<1		
AES-0211-8B	Amidon ES	2nd floor inside Classroom B225	2/11/14	<1		
AES-0211-9A	Amidon ES	2nd floor inside Classroom B232	2/11/14	<1		
AES-0211-9B	Amidon ES	2nd floor inside Classroom B232	2/11/14	<1		
AES-0211-10A	Amidon ES	2nd floor inside Classroom B227	2/11/14	<1		
AES-0211-10B	Amidon ES	2nd floor inside Classroom B227	2/11/14	<1		
AES-0211-11A	Amidon ES	2nd floor inside Classroom B236	2/11/14	<1		
AES-0211-11B	Amidon ES	2nd floor inside Classroom B236	2/11/14	<1		
AES-0211-12A	Amidon ES	2nd floor inside Classroom B231	2/11/14	<1		
AES-0211-12B	Amidon ES	2nd floor inside Classroom B231	2/11/14	<1		
AES-0211-13A	Amidon ES	2nd floor across from Library	2/11/14	<1		
AES-0211-13B	Amidon ES	2nd floor across from Library	2/11/14	<1		
AES-0211-14A	Amidon ES	1st floor inside Classroom D161	2/11/14	<1		
AES-0211-14B	Amidon ES	1st floor inside Classroom D161	2/11/14	<1		
AES-0211-15A	Amidon ES	1st floor near Gym entrance	2/11/14	<1		
AES-0211-15B	Amidon ES	1st floor near Gym entrance	2/11/14	<1		
AES-0211-16A	Amidon ES	1st floor inside Gym	2/11/14	<1		
AES-0211-16B	Amidon ES	1st floor inside Gym	2/11/14	<1		
AES-0211-17A	Amidon ES	1st floor inside Multi-Purpose Room	2/11/14	<1		
AES-0211-17B	Amidon ES	1st floor inside Multi-Purpose Room	2/11/14	<1		
AES-0211-18A	Amidon ES	1st floor adjacent to Health Suite	2/11/14	<1		
AES-0211-18B	Amidon ES	1st floor adjacent to Health Suite	2/11/14	<1		
AES-0211-19A	Amidon ES	1st floor inside Classroom A107	2/11/14	2		
AES-0211-19B	Amidon ES	1st floor inside Classroom A107	2/11/14	<1		
AES-0211-20A	Amidon ES	1st floor inside Classroom A105 (high)	2/11/14	1		
AES-0211-20B	Amidon ES	1st floor inside Classroom A105 (high)	2/11/14	<1		
AES-0211-21A	Amidon ES	1st floor inside Classroom A105 (low)	2/11/14	1.1		
AES-0211-21B	Amidon ES	1st floor inside Classroom A105 (low)	2/11/14	<1		
AES-0211-22A	Amidon ES	1st floor inside Classroom A103 (high)	2/11/14	<1		
AES-0211-22B	Amidon ES	1st floor inside Classroom A103 (high)	2/11/14	<1		
AES-0211-23A	Amidon ES	1st floor inside Classroom A103 (low)	2/11/14	<1		
AES-0211-23B	Amidon ES	1st floor inside Classroom A103 (low)	2/11/14	<1		
AES-0211-24A	Amidon ES	1st floor inside Classroom A106 (high)	2/11/14	<1		
AES-0211-24B	Amidon ES	1st floor inside Classroom A106 (high)	2/11/14	<1		
AES-0211-25A	Amidon ES	1st floor inside Classroom A106 (low)	2/11/14	<1		
AES-0211-25B	Amidon ES	1st floor inside Classroom A106 (low)	2/11/14	<1		
AES-0211-26A	Amidon ES	1st floor inside Classroom B126	2/11/14	1.9		
AES-0211-26B	Amidon ES	1st floor inside Classroom B126	2/11/14	<1		
AES-0211-27A	Amidon ES	1st floor inside Classroom B128	2/11/14	<1		
AES-0211-27B	Amidon ES	1st floor inside Classroom B128	2/11/14	<1		
AES-0211-28A	Amidon ES	1st floor hallway adjacent to Classroom B128 (high)	2/11/14	<1		
AES-0211-28B	Amidon ES	1st floor hallway adjacent to Classroom B128 (high)	2/11/14	<1		
AES-0211-29A	Amidon ES	1st floor hallway adjacent to Classroom B128 (low)	2/11/14	<1		
AES-0211-29B	Amidon ES	1st floor hallway adjacent to Classroom B128 (low)	2/11/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
AES-0220-1A	Anacostia SHS	3rd floor hallway adjacent to Classroom M319	2/20/14	<1		
AES-0220-1B	Anacostia SHS	3rd floor hallway adjacent to Classroom M319	2/20/14	<1		
AES-0220-2A	Anacostia SHS	3rd floor hallway adjacent to Classroom M303	2/20/14	<1		
AES-0220-2B	Anacostia SHS	3rd floor hallway adjacent to Classroom M303	2/20/14	<1		
AES-0220-3A	Anacostia SHS	2nd floor hallway adjacent to Classroom M220	2/20/14	<1		
AES-0220-3B	Anacostia SHS	2nd floor hallway adjacent to Classroom M220	2/20/14	<1		
AES-0220-4A	Anacostia SHS	2nd floor hallway adjacent to Classroom M203	2/20/14	<1		
AES-0220-4B	Anacostia SHS	2nd floor hallway adjacent to Classroom M203	2/20/14	<1		
AES-0220-5A	Anacostia SHS	2nd floor hallway adjacent to Computer Lab N203	2/20/14	<1		
AES-0220-5B	Anacostia SHS	2nd floor hallway adjacent to Computer Lab N203	2/20/14	<1		
AES-0220-6A	Anacostia SHS	2nd floor hallway across from Computer Lab M212	2/20/14	<1		
AES-0220-6B	Anacostia SHS	2nd floor hallway across from Computer Lab M212	2/20/14	<1		
AES-0220-7A	Anacostia SHS	2nd floor hallway adjacent to Classroom S204	2/20/14	<1		
AES-0220-7B	Anacostia SHS	2nd floor hallway adjacent to Classroom S204	2/20/14	<1		
AES-0220-8A	Anacostia SHS	2nd floor hallway adjacent to Work Room G204	2/20/14	<1		
AES-0220-8B	Anacostia SHS	2nd floor hallway adjacent to Work Room G204	2/20/14	<1		
AES-0220-9A	Anacostia SHS	1st floor hallway across from Gym G102	2/20/14	<1		
AES-0220-9B	Anacostia SHS	1st floor hallway across from Gym G102	2/20/14	<1		
AES-0220-10A	Anacostia SHS	1st floor hallway adjacent to M103 (Admin)	2/20/14	<1		
AES-0220-10B	Anacostia SHS	1st floor hallway adjacent to M103 (Admin)	2/20/14	<1		
AES-0220-11A	Anacostia SHS	1st floor hallway adjacent to M115 (Parent Resource)	2/20/14	<1		
AES-0220-11B	Anacostia SHS	1st floor hallway adjacent to M115 (Parent Resource)	2/20/14	<1		
AES-0220-12A	Anacostia SHS	1st floor hallway across from Work Room N110	2/20/14	<1		
AES-0220-12B	Anacostia SHS	1st floor hallway across from Work Room N110	2/20/14	<1		
AES-0220-13A	Anacostia SHS	Ground floor Hallway adjacent to Boy's Room	2/20/14	<1		
AES-0220-13B	Anacostia SHS	Ground floor Hallway adjacent to Boy's Room	2/20/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
BHS-0701-1A	Ballou HS	3rd floor hallway across from elevator (Main Bldg.)	7/1/14	<1		
BHS-0701-1B	Ballou HS	3rd floor hallway across from elevator (Main Bldg.)	7/1/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-0327-3A	Bunker Hill ES	2nd floor hallway adjacent to Classroom 220	3/27/14	<1		
BES-0327-3B	Bunker Hill ES	2nd floor hallway adjacent to Classroom 220	3/27/14	<1		
BES-0327-4A	Bunker Hill ES	1st floor hallway adjacent to Classroom 124	3/27/14	<1		
BES-0327-4B	Bunker Hill ES	1st floor hallway adjacent to Classroom 124	3/27/14	<1		
BES-0327-5A	Bunker Hill ES	1st floor hallway adjacent to Teacher's Restroom	3/27/14	<1		
BES-0327-5B	Bunker Hill ES	1st floor hallway adjacent to Teacher's Restroom	3/27/14	<1		
BES-0327-6A	Bunker Hill ES	1st floor inside Classroom 119	3/27/14	<1		
BES-0327-6B	Bunker Hill ES	1st floor inside Classroom 119	3/27/14	<1		
BES-0327-7A	Bunker Hill ES	1st floor inside Classroom 124	3/27/14	<1		
BES-0327-7B	Bunker Hill ES	1st floor inside Classroom 124	3/27/14	<1		
BES-0327-8A	Bunker Hill ES	1st floor inside Classroom 118	3/27/14	<1		
BES-0327-8B	Bunker Hill ES	1st floor inside Classroom 118	3/27/14	<1		
BES-0327-9A	Bunker Hill ES	1st floor inside Classroom 126	3/27/14	<1		
BES-0327-9B	Bunker Hill ES	1st floor inside Classroom 126	3/27/14	<1		
BES-0327-10A	Bunker Hill ES	1st floor inside Health Suite	3/27/14	<1		
BES-0327-10B	Bunker Hill ES	1st floor inside Health Suite	3/27/14	<1		
BES-0327-11A	Bunker Hill ES	2nd floor hallway adjacent to Custodian Closet 204	3/27/14	<1		
BES-0327-11B	Bunker Hill ES	2nd floor hallway adjacent to Custodian Closet 204	3/27/14	1.8		
BES-0327-12A	Bunker Hill ES	1st floor hallway at entrance to Auditorium	3/27/14	<1		
BES-0327-12B	Bunker Hill ES	1st floor hallway at entrance to Auditorium	3/27/14	<1		
BES-0327-13A	Bunker Hill ES	1st floor inside Classroom 103	3/27/14	<1		
BES-0327-13B	Bunker Hill ES	1st floor inside Classroom 103	3/27/14	<1		
BES-0327-14A	Bunker Hill ES	1st floor inside Staff Development Room	3/27/14	<1		
BES-0327-14B	Bunker Hill ES	1st floor inside Staff Development Room	3/27/14	<1		
BES-0327-15A	Bunker Hill ES	1st floor inside Classroom 106	3/27/14	<1		
BES-0327-15B	Bunker Hill ES	1st floor inside Classroom 106	3/27/14	<1		
BES-0327-16A	Bunker Hill ES	Basement floor inside Cafeteria	3/27/14	<1		
BES-0327-16B	Bunker Hill ES	Basement floor inside Cafeteria	3/27/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
BES-0116-1A	Burrville ES	2nd floor hallway across from elevator (high)	1/16/14	<1		
BES-0116-1B	Burrville ES	2nd floor hallway across from elevator (high)	1/16/14	<1		
BES-0116-2A	Burrville ES	2nd floor hallway across from elevator (low)	1/16/14	<1		
BES-0116-2B	Burrville ES	2nd floor hallway across from elevator (low)	1/16/14	<1		
BES-0116-3A	Burrville ES	2nd floor hallway adjacent to Gym	1/16/14	<1		
BES-0116-3B	Burrville ES	2nd floor hallway adjacent to Gym	1/16/14	<1		
BES-0116-4A	Burrville ES	2nd floor inside Gym, adjacent to Kitchen	1/16/14	<1		
BES-0116-4B	Burrville ES	2nd floor inside Gym, adjacent to Kitchen	1/16/14	<1		
BES-0116-5A	Burrville ES	2nd floor hallway #5 adjacent to Gym (high)	1/16/14	<1		
BES-0116-5B	Burrville ES	2nd floor hallway #5 adjacent to Gym (high)	1/16/14	<1		
BES-0116-6A	Burrville ES	2nd floor hallway #5 adjacent to Gym (low)	1/16/14	<1		
BES-0116-6B	Burrville ES	2nd floor hallway #5 adjacent to Gym (low)	1/16/14	<1		
BES-0116-7A	Burrville ES	2nd floor hallway #5 across from Custodian Closet (high)	1/16/14	<1		
BES-0116-7B	Burrville ES	2nd floor hallway #5 across from Custodian Closet (high)	1/16/14	<1		
BES-0116-8A	Burrville ES	2nd floor hallway #5 across from Custodian Closet (low)	1/16/14	<1		
BES-0116-8B	Burrville ES	2nd floor hallway #5 across from Custodian Closet (low)	1/16/14	<1		
BES-0116-9A	Burrville ES	2nd floor hallway near Stairwell 1 (high)	1/16/14	<1		
BES-0116-9B	Burrville ES	2nd floor hallway near Stairwell 1 (high)	1/16/14	<1		
BES-0116-10A	Burrville ES	2nd floor hallway near Stairwell 1 (low)	1/16/14	<1		
BES-0116-10B	Burrville ES	2nd floor hallway near Stairwell 1 (low)	1/16/14	<1		
BES-0116-11A	Burrville ES	2nd floor inside Classroom 227 Kindergarten	1/16/14	<1		
BES-0116-11B	Burrville ES	2nd floor inside Classroom 227 Kindergarten	1/16/14	<1		
BES-0116-12A	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (high)	1/16/14	<1		
BES-0116-12B	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (high)	1/16/14	<1		
BES-0116-13A	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (low)	1/16/14	<1		
BES-0116-13B	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (low)	1/16/14	<1		
BES-0116-14A	Burrville ES	2nd floor inside Classroom 228 Kindergarten	1/16/14	<1		
BES-0116-14B	Burrville ES	2nd floor inside Classroom 228 Kindergarten	1/16/14	<1		
BES-0116-15A	Burrville ES	1st floor between Girls & Boy's RR, near Stairwell 1	1/16/14	<1		
BES-0116-15B	Burrville ES	1st floor between Girls & Boy's RR, near Stairwell 1	1/16/14	<1		
BES-0116-16A	Burrville ES	1st floor inside Classroom 108	1/16/14	<1		
BES-0116-16B	Burrville ES	1st floor inside Classroom 108	1/16/14	<1		
BES-0116-17A	Burrville ES	1st floor inside Classroom 110	1/16/14	<1		
BES-0116-17B	Burrville ES	1st floor inside Classroom 110	1/16/14	<1		
BES-0116-18A	Burrville ES	1st floor inside Classroom 115	1/16/14	<1		
BES-0116-18B	Burrville ES	1st floor inside Classroom 115	1/16/14	<1		
BES-0116-19A	Burrville ES	1st floor inside Classroom 114	1/16/14	<1		
BES-0116-19B	Burrville ES	1st floor inside Classroom 114	1/16/14	<1		
BES-0116-20A	Burrville ES	1st floor inside Classroom 113	1/16/14	<1		
BES-0116-20B	Burrville ES	1st floor inside Classroom 113	1/16/14	<1		
BES-0116-21A	Burrville ES	1st floor inside Classroom Pre-school	1/16/14	<1		
BES-0116-21B	Burrville ES	1st floor inside Classroom Pre-school	1/16/14	<1		
BES-0116-22A	Burrville ES	1st floor hallway across from Classroom 113 (high)	1/16/14	<1		
BES-0116-22B	Burrville ES	1st floor hallway across from Classroom 113 (high)	1/16/14	<1		
BES-0116-23A	Burrville ES	1st floor hallway across from Classroom 113 (low)	1/16/14	<1		
BES-0116-23B	Burrville ES	1st floor hallway across from Classroom 113 (low)	1/16/14	<1		
BES-0116-24A	Burrville ES	Inside Girl's Locker Room	1/16/14	<1		
BES-0116-24B	Burrville ES	Inside Girl's Locker Room	1/16/14	<1		
BES-0116-25A	Burrville ES	Inside Boy's Locker Room	1/16/14	3.8		
BES-0116-25B	Burrville ES	Inside Boy's Locker Room	1/16/14	3.8		
BES-0116-26A	Burrville ES	Inside Teacher's Lounge	1/16/14	1		
BES-0116-26B	Burrville ES	Inside Teacher's Lounge	1/16/14	<1		
BES-0116-27A	Burrville ES	2nd floor inside Art Room 241	1/16/14	1.9		
BES-0116-27B	Burrville ES	2nd floor inside Art Room 241	1/16/14	2.8		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
BES-0324-1A	Burroughs ES	1st floor inside Classroom 25	3/24/14	<1		
BES-0324-1B	Burroughs ES	1st floor inside Classroom 25	3/24/14	<1		
BES-0324-2A	Burroughs ES	1st floor inside Classroom 35	3/24/14	<1		
BES-0324-2B	Burroughs ES	1st floor inside Classroom 35	3/24/14	<1		
BES-0324-3A	Burroughs ES	1st floor inside Classroom 34	3/24/14	1		
BES-0324-3B	Burroughs ES	1st floor inside Classroom 34	3/24/14	<1		
BES-0324-4A	Burroughs ES	1st floor hallway at entrance to Cafeteria (high)	3/24/14	3.7		
BES-0324-4B	Burroughs ES	1st floor hallway at entrance to Cafeteria (high)	3/24/14	<1		
BES-0324-5A	Burroughs ES	1st floor hallway at entrance to Cafeteria (low)	3/24/14	<1		
BES-0324-5B	Burroughs ES	1st floor hallway at entrance to Cafeteria (low)	3/24/14	<1		
BES-0324-6A	Burroughs ES	1st floor hallway across from Classroom 27	3/24/14	<1		
BES-0324-6B	Burroughs ES	1st floor hallway across from Classroom 27	3/24/14	<1		
BES-0324-7A	Burroughs ES	1st floor hallway across from Classroom 14	3/24/14	<1		
BES-0324-7B	Burroughs ES	1st floor hallway across from Classroom 14	3/24/14	<1		
BES-0324-8A	Burroughs ES	1st floor hallway adjacent to Classroom 9A	3/24/14	<1		
BES-0324-8B	Burroughs ES	1st floor hallway adjacent to Classroom 9A	3/24/14	<1		
BES-0324-9A	Burroughs ES	1st floor hallway adjacent to Classroom 8	3/24/14	<1		
BES-0324-9B	Burroughs ES	1st floor hallway adjacent to Classroom 8	3/24/14	<1		
BES-0324-10A	Burroughs ES	1st floor hallway across from Classroom 3	3/24/14	<1		
BES-0324-10B	Burroughs ES	1st floor hallway across from Classroom 3	3/24/14	<1		
BES-0324-11A	Burroughs ES	Basement floor inside Classroom 21	3/24/14	<1		
BES-0324-11B	Burroughs ES	Basement floor inside Classroom 21	3/24/14	<1		
BES-0324-12A	Burroughs ES	Basement floor inside Classroom 22	3/24/14	<1		
BES-0324-12B	Burroughs ES	Basement floor inside Classroom 22	3/24/14	<1		
BES-0324-13A	Burroughs ES	Basement floor inside Classroom 20	3/24/14	<1		
BES-0324-13B	Burroughs ES	Basement floor inside Classroom 20	3/24/14	<1		
BES-0324-14A	Burroughs ES	Basement floor inside Classroom 19	3/24/14	<1		
BES-0324-14B	Burroughs ES	Basement floor inside Classroom 19	3/24/14	<1		
BES-0324-15A	Burroughs ES	Basement floor inside Classroom 18	3/24/14	<1		
BES-0324-15B	Burroughs ES	Basement floor inside Classroom 18	3/24/14	<1		
BES-0324-16A	Burroughs ES	Basement floor hallway adjacent to Classroom 20	3/24/14	<1		
BES-0324-16B	Burroughs ES	Basement floor hallway adjacent to Classroom 20	3/24/14	<1		
BES-0324-17A	Burroughs ES	Basement floor hallway adjacent to Classroom 19	3/24/14	<1		
BES-0324-17B	Burroughs ES	Basement floor hallway adjacent to Classroom 19	3/24/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
CAE-0522-1A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 1	5/22/14	<1		
CAE-0522-1B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 1	5/22/14	<1		
CAE-0522-2A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway adjacent to Men's Restroom	5/22/14	<1		
CAE-0522-2B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway adjacent to Men's Restroom	5/22/14	<1		
CAE-0522-3A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway adjacent to Classroom 315	5/22/14	<1		
CAE-0522-3B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway adjacent to Classroom 315	5/22/14	<1		
CAE-0522-4A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 3	5/22/14	<1		
CAE-0522-4B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 3	5/22/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CAE-0522-5A	C.H.O.I.C.E Academy @ Emery	2nd floor hallway adjacent to Girl's Room	5/22/14	<1		
CAE-0522-5B	C.H.O.I.C.E Academy @ Emery	2nd floor hallway adjacent to Girl's Room	5/22/14	<1		
CAE-0522-6A	C.H.O.I.C.E Academy @ Emery	2nd floor hallway across from Classroom 6	5/22/14	<1		
CAE-0522-6B	C.H.O.I.C.E Academy @ Emery	2nd floor hallway across from Classroom 6	5/22/14	<1		
CAE-0522-7A	C.H.O.I.C.E Academy @ Emery	2nd floor hallway at Startwell 1	5/22/14	<1		
CAE-0522-7B	C.H.O.I.C.E Academy @ Emery	2nd floor hallway at Startwell 1	5/22/14	<1		
CAE-0522-8A	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Classroom 110	5/22/14	<1		
CAE-0522-8B	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Classroom 110	5/22/14	<1		
CAE-0522-9A	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Men's Restroom	5/22/14	<1		
CAE-0522-9B	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Men's Restroom	5/22/14	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
CWH-0402-1A	C.W. Harris ES	2nd floor hallway across from Classroom 246	4/2/14	<1		
CWH-0402-1B	C.W. Harris ES	2nd floor hallway across from Classroom 246	4/2/14	<1		
CWH-0402-2A	C.W. Harris ES	2nd floor hallway across from Classroom 218	4/2/14	<1		
CWH-0402-2B	C.W. Harris ES	2nd floor hallway across from Classroom 218	4/2/14	<1		
CWH-0402-3A	C.W. Harris ES	1st floor hallway across from Storage Room	4/2/14	<1		
CWH-0402-3B	C.W. Harris ES	1st floor hallway across from Storage Room	4/2/14	<1		
CWH-0402-4A	C.W. Harris ES	1st floor inside Health Suite	4/2/14	<1		
CWH-0402-4B	C.W. Harris ES	1st floor inside Health Suite	4/2/14	<1		
CWH-0402-5A	C.W. Harris ES	1st floor inside Multi-Purpose Room	4/2/14	<1		
CWH-0402-5B	C.W. Harris ES	1st floor inside Multi-Purpose Room	4/2/14	<1		
CWH-0402-6A	C.W. Harris ES	1st floor hallway across from Custodian Closet	4/2/14	<1		
CWH-0402-6B	C.W. Harris ES	1st floor hallway across from Custodian Closet	4/2/14	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
CEC-0617-1A	Cardozo EC	3rd floor hallway between Men's and Women's Rooms east side (high)	6/17/14	<1		
CEC-0617-1B	Cardozo EC	3rd floor hallway between Men's and Women's Rooms east side (high)	6/17/14	<1		
CEC-0617-2A	Cardozo EC	3rd floor hallway between Men's and Women's Rooms east side (low)	6/17/14	<1		
CEC-0617-2B	Cardozo EC	3rd floor hallway between Men's and Women's Rooms east side (low)	6/17/14	<1		
CEC-0617-3A	Cardozo EC	3rd floor hallway across from Classroom 3502 (high)	6/17/14	<1		
CEC-0617-3B	Cardozo EC	3rd floor hallway across from Classroom 3502 (high)	6/17/14	<1		
CEC-0617-4A	Cardozo EC	3rd floor hallway across from Classroom 3502 (low)	6/17/14	<1		
CEC-0617-4B	Cardozo EC	3rd floor hallway across from Classroom 3502 (low)	6/17/14	<1		
CEC-0617-5A	Cardozo EC	2nd floor hallway across from Classroom 2602 (high)	6/17/14	<1		
CEC-0617-5B	Cardozo EC	2nd floor hallway across from Classroom 2602 (high)	6/17/14	<1		
CEC-0617-6A	Cardozo EC	2nd floor hallway across from Classroom 2602 (low)	6/17/14	<1		
CEC-0617-6B	Cardozo EC	2nd floor hallway across from Classroom 2602 (low)	6/17/14	<1		
CEC-0617-7A	Cardozo EC	2nd floor hallway across from Classroom 2204 (high)	6/17/14	<1		
CEC-0617-7B	Cardozo EC	2nd floor hallway across from Classroom 2204 (high)	6/17/14	<1		
CEC-0617-8A	Cardozo EC	2nd floor hallway across from Classroom 2204 (low)	6/17/14	<1		
CEC-0617-8B	Cardozo EC	2nd floor hallway across from Classroom 2204 (low)	6/17/14	<1		
CEC-0617-9A	Cardozo EC	1st floor hallway across from Classroom 1203 (high)	6/17/14	<1		
CEC-0617-9B	Cardozo EC	1st floor hallway across from Classroom 1203 (high)	6/17/14	<1		
CEC-0617-10A	Cardozo EC	1st floor hallway across from Classroom 1203 (low)	6/17/14	<1		
CEC-0617-10B	Cardozo EC	1st floor hallway across from Classroom 1203 (low)	6/17/14	<1		
CEC-0617-11A	Cardozo EC	1st floor hallway across from Classroom 1603 (high)	6/17/14	<1		
CEC-0617-11B	Cardozo EC	1st floor hallway across from Classroom 1603 (high)	6/17/14	<1		
CEC-0617-12A	Cardozo EC	1st floor hallway across from Classroom 1603 (low)	6/17/14	<1		
CEC-0617-12B	Cardozo EC	1st floor hallway across from Classroom 1603 (low)	6/17/14	<1		
CEC-0617-13A	Cardozo EC	C floor hallway across from Classroom C205 (high)	6/17/14	<1		
CEC-0617-13B	Cardozo EC	C floor hallway across from Classroom C205 (high)	6/17/14	<1		
CEC-0617-14A	Cardozo EC	C floor hallway across from Classroom C205 (low)	6/17/14	<1		
CEC-0617-14B	Cardozo EC	C floor hallway across from Classroom C205 (low)	6/17/14	<1		
CEC-0617-15A	Cardozo EC	T floor hallway across from Storage Room T210	6/17/14	<1		
CEC-0617-15B	Cardozo EC	T floor hallway across from Storage Room T210	6/17/14	<1		
CEC-0617-16A	Cardozo EC	T floor in Gym Lobby (high)	6/17/14	<1		
CEC-0617-16B	Cardozo EC	T floor in Gym Lobby (high)	6/17/14	<1		
CEC-0617-17A	Cardozo EC	T floor in Gym Lobby (low)	6/17/14	<1		
CEC-0617-17B	Cardozo EC	T floor in Gym Lobby (low)	6/17/14	<1		
CEC-0617-18A	Cardozo EC	T floor inside Gym across from Girl's Locker Room (high)	6/17/14	<1		
CEC-0617-18B	Cardozo EC	T floor inside Gym across from Girl's Locker Room (high)	6/17/14	<1		
CEC-0617-19A	Cardozo EC	T floor inside Gym across from Girl's Locker Room (low)	6/17/14	<1		
CEC-0617-19B	Cardozo EC	T floor inside Gym across from Girl's Locker Room (low)	6/17/14	<1		
CEC-0617-20A	Cardozo EC	T floor inside Gym across from Custodian Closet LT58 (high)	6/17/14	<1		
CEC-0617-20B	Cardozo EC	T floor inside Gym across from Custodian Closet LT58 (high)	6/17/14	<1		
CEC-0617-21A	Cardozo EC	T floor inside Gym across from Custodian Closet LT58 (low)	6/17/14	<1		
CEC-0617-21B	Cardozo EC	T floor inside Gym across from Custodian Closet LT58 (low)	6/17/14	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
CES-0421-1A	Cleveland ES	3rd floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-1B	Cleveland ES	3rd floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-2A	Cleveland ES	3rd floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-2B	Cleveland ES	3rd floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-3A	Cleveland ES	3rd floor inside Classroom 304	4/21/14	1.7		
CES-0421-3B	Cleveland ES	3rd floor inside Classroom 304	4/21/14	<1		
CES-0421-4A	Cleveland ES	3rd floor inside Classroom 308	4/21/14	1.5		
CES-0421-4B	Cleveland ES	3rd floor inside Classroom 308	4/21/14	<1		
CES-0421-5A	Cleveland ES	3rd floor inside Classroom 302	4/21/14	<1		
CES-0421-5B	Cleveland ES	3rd floor inside Classroom 302	4/21/14	<1		
CES-0421-6A	Cleveland ES	3rd floor inside Teacher's Lounge	4/21/14	<1		
CES-0421-6B	Cleveland ES	3rd floor inside Teacher's Lounge	4/21/14	<1		
CES-0421-7A	Cleveland ES	3rd floor inside Classroom 301	4/21/14	<1		
CES-0421-7B	Cleveland ES	3rd floor inside Classroom 301	4/21/14	<1		
CES-0421-8A	Cleveland ES	3rd floor inside Classroom 315	4/21/14	<1		
CES-0421-8B	Cleveland ES	3rd floor inside Classroom 315	4/21/14	<1		
CES-0421-9A	Cleveland ES	2nd floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-9B	Cleveland ES	2nd floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-10A	Cleveland ES	2nd floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-10B	Cleveland ES	2nd floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-11A	Cleveland ES	2nd floor inside Classroom 207	4/21/14	<1		
CES-0421-11B	Cleveland ES	2nd floor inside Classroom 207	4/21/14	<1		
CES-0421-12A	Cleveland ES	2nd floor inside Classroom 212	4/21/14	<1		
CES-0421-12B	Cleveland ES	2nd floor inside Classroom 212	4/21/14	<1		
CES-0421-13A	Cleveland ES	2nd floor inside Classroom 203	4/21/14	4.6		
CES-0421-13B	Cleveland ES	2nd floor inside Classroom 203	4/21/14	<1		
CES-0421-14A	Cleveland ES	2nd floor inside Classroom 201	4/21/14	<1		
CES-0421-14B	Cleveland ES	2nd floor inside Classroom 201	4/21/14	<1		
CES-0421-15A	Cleveland ES	2nd floor inside Classroom 218	4/21/14	<1		
CES-0421-15B	Cleveland ES	2nd floor inside Classroom 218	4/21/14	<1		
CES-0421-16A	Cleveland ES	2nd floor inside Science Room 216 (1) (Clockwise from left)	4/21/14	2.4		
CES-0421-16B	Cleveland ES	2nd floor inside Science Room 216 (1)	4/21/14	<1		
CES-0421-17A	Cleveland ES	2nd floor inside Science Room 216 (2)	4/21/14	<1		
CES-0421-17B	Cleveland ES	2nd floor inside Science Room 216 (2)	4/21/14	<1		
CES-0421-18A	Cleveland ES	2nd floor inside Science Room 216 (3)	4/21/14	<1		
CES-0421-18B	Cleveland ES	2nd floor inside Science Room 216 (3)	4/21/14	<1		
CES-0421-19A	Cleveland ES	2nd floor inside Science Room 216 (4)	4/21/14	2.1		
CES-0421-19B	Cleveland ES	2nd floor inside Science Room 216 (4)	4/21/14	<1		
CES-0421-20A	Cleveland ES	1st floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-20B	Cleveland ES	1st floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-21A	Cleveland ES	1st floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-21B	Cleveland ES	1st floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-22A	Cleveland ES	1st floor inside Classroom 111	4/21/14	<1		
CES-0421-22B	Cleveland ES	1st floor inside Classroom 111	4/21/14	<1		
CES-0421-23A	Cleveland ES	1st floor inside Classroom 106	4/21/14	<1		
CES-0421-23B	Cleveland ES	1st floor inside Classroom 106	4/21/14	<1		
CES-0421-24A	Cleveland ES	1st floor inside Classroom 115	4/21/14	<1		
CES-0421-24B	Cleveland ES	1st floor inside Classroom 115	4/21/14	<1		
CES-0421-25A	Cleveland ES	1st floor inside Classroom 103	4/21/14	<1		
CES-0421-25B	Cleveland ES	1st floor inside Classroom 103	4/21/14	<1		
CES-0421-26A	Cleveland ES	1st floor inside Classroom 101	4/21/14	2.1		
CES-0421-26B	Cleveland ES	1st floor inside Classroom 101	4/21/14	<1		
CES-0421-27A	Cleveland ES	1st floor inside Classroom 120	4/21/14	<1		
CES-0421-27B	Cleveland ES	1st floor inside Classroom 120	4/21/14	<1		
CES-0421-28A	Cleveland ES	Ground floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-28B	Cleveland ES	Ground floor hallway across from Elevator (high)	4/21/14	<1		
CES-0421-29A	Cleveland ES	Ground floor hallway across from Elevator (low)	4/21/14	<1		
CES-0421-29B	Cleveland ES	Ground floor hallway across from Elevator (low)	4/21/14	<1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
JES-0528-19A	Janney ES	2nd floor inside Classroom 201	5/28/14	<1		
JES-0528-19B	Janney ES	2nd floor inside Classroom 201	5/28/14	<1		
JES-0528-20A	Janney ES	2nd floor inside Classroom 200	5/28/14	<1		
JES-0528-20B	Janney ES	2nd floor inside Classroom 200	5/28/14	<1		
JES-0528-21A	Janney ES	2nd floor hallway adjacent to Classroom 201	5/28/14	<1		
JES-0528-21B	Janney ES	2nd floor hallway adjacent to Classroom 201	5/28/14	<1		
JES-0528-22A	Janney ES	2nd floor hallway adjacent to Classroom 207	5/28/14	<1		
JES-0528-22B	Janney ES	2nd floor hallway adjacent to Classroom 207	5/28/14	<1		
JES-0528-23A	Janney ES	1st floor inside Art Room 110 (high)	5/28/14	<1		
JES-0528-23B	Janney ES	1st floor inside Art Room 110 (high)	5/28/14	<1		
JES-0528-24A	Janney ES	1st floor inside Art Room 110 (low)	5/28/14	<1		
JES-0528-24B	Janney ES	1st floor inside Art Room 110 (low)	5/28/14	<1		
JES-0528-25A	Janney ES	1st floor hallway adjacent to Art Room 110	5/28/14	<1		
JES-0528-25B	Janney ES	1st floor hallway adjacent to Art Room 110	5/28/14	<1		
JES-0528-26A	Janney ES	1st floor hallway adjacent to Classroom 115 (high)	5/28/14	<1		
JES-0528-26B	Janney ES	1st floor hallway adjacent to Classroom 115 (high)	5/28/14	<1		
JES-0528-27A	Janney ES	1st floor hallway adjacent to Classroom 115 (low)	5/28/14	<1		
JES-0528-27B	Janney ES	1st floor hallway adjacent to Classroom 115 (low)	5/28/14	<1		
JES-0528-28A	Janney ES	1st floor inside Classroom 115	5/28/14	<1		
JES-0528-28B	Janney ES	1st floor inside Classroom 115	5/28/14	<1		
JES-0528-29A	Janney ES	1st floor inside Classroom 117	5/28/14	<1		
JES-0528-29B	Janney ES	1st floor inside Classroom 117	5/28/14	<1		
JES-0528-30A	Janney ES	1st floor inside Classroom 113	5/28/14	<1		
JES-0528-30B	Janney ES	1st floor inside Classroom 113	5/28/14	<1		
JES-0528-31A	Janney ES	1st floor inside Classroom 109	5/28/14	<1		
JES-0528-31B	Janney ES	1st floor inside Classroom 109	5/28/14	<1		
JES-0528-32A	Janney ES	1st floor inside Classroom 108	5/28/14	<1		
JES-0528-32B	Janney ES	1st floor inside Classroom 108	5/28/14	<1		
JES-0528-33A	Janney ES	1st floor inside Classroom 107	5/28/14	<1		
JES-0528-33B	Janney ES	1st floor inside Classroom 107	5/28/14	<1		
JES-0528-34A	Janney ES	1st floor inside Classroom 106	5/28/14	<1		
JES-0528-34B	Janney ES	1st floor inside Classroom 106	5/28/14	<1		
JES-0528-35A	Janney ES	1st floor inside Health Suite	5/28/14	<1		
JES-0528-35B	Janney ES	1st floor inside Health Suite	5/28/14	<1		
JES-0528-36A	Janney ES	1st floor hallway near Health Suite	5/28/14	<1		
JES-0528-36B	Janney ES	1st floor hallway near Health Suite	5/28/14	<1		
JES-0528-37A	Janney ES	1st floor hallway adjacent to Classroom 107	5/28/14	<1		
JES-0528-37B	Janney ES	1st floor hallway adjacent to Classroom 107	5/28/14	<1		
JES-0528-38A	Janney ES	Lower Level hallway across from Stairwell 2	5/28/14	<1		
JES-0528-38B	Janney ES	Lower Level hallway across from Stairwell 2	5/28/14	<1		
JES-0528-39A	Janney ES	Lower Level inside Science Lab L10 (1)	5/28/14	<1		
JES-0528-39B	Janney ES	Lower Level inside Science Lab L10 (1)	5/28/14	<1		
JES-0528-40A	Janney ES	Lower Level inside Science Lab L10 (2)	5/28/14	<1		
JES-0528-40B	Janney ES	Lower Level inside Science Lab L10 (2)	5/28/14	<1		
JES-0528-41A	Janney ES	Lower Level inside Science Lab L10 (3)	5/28/14	<1		
JES-0528-41B	Janney ES	Lower Level inside Science Lab L10 (3)	5/28/14	<1		
JES-0528-42A	Janney ES	Lower Level inside Science Lab L10 (4)	5/28/14	<1		
JES-0528-42B	Janney ES	Lower Level inside Science Lab L10 (4)	5/28/14	<1		
JES-0528-43A	Janney ES	2nd floor inside Teacher's Lounge	5/28/14	<1		
JES-0528-43B	Janney ES	2nd floor inside Teacher's Lounge	5/28/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
JMS-0606-1A	Jefferson MS	3rd floor hallway adjacent to Boy's Room	6/6/14	<1		
JMS-0606-1B	Jefferson MS	3rd floor hallway adjacent to Boy's Room	6/6/14	<1		
JMS-0606-2A	Jefferson MS	3rd floor hallway adjacent to Girl's Room	6/6/14	<1		
JMS-0606-2B	Jefferson MS	3rd floor hallway adjacent to Girl's Room	6/6/14	<1		
JMS-0606-3A	Jefferson MS	2nd floor hallway adjacent to Classroom 207	6/6/14	<1		
JMS-0606-3B	Jefferson MS	2nd floor hallway adjacent to Classroom 207	6/6/14	<1		
JMS-0606-4A	Jefferson MS	2nd floor hallway adjacent to Men's Room	6/6/14	<1		
JMS-0606-4B	Jefferson MS	2nd floor hallway adjacent to Men's Room	6/6/14	<1		
JMS-0606-5A	Jefferson MS	1st floor hallway adjacent to Girl's Room	6/6/14	<1		
JMS-0606-5B	Jefferson MS	1st floor hallway adjacent to Girl's Room	6/6/14	<1		
JMS-0606-6A	Jefferson MS	1st floor hallway adjacent to Boy's Room	6/6/14	<1		
JMS-0606-6B	Jefferson MS	1st floor hallway adjacent to Boy's Room	6/6/14	<1		
JMS-0606-7A	Jefferson MS	Basement floor inside Cafeteria	6/6/14	<1		
JMS-0606-7B	Jefferson MS	Basement floor inside Cafeteria	6/6/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
JMS-0611-1A	Johnson MS	4th floor hallway across from Classroom 420	6/11/14	<1		
JMS-0611-1B	Johnson MS	4th floor hallway across from Classroom 420	6/11/14	<1		
JMS-0611-2A	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (high)	6/11/14	<1		
JMS-0611-2B	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (high)	6/11/14	<1		
JMS-0611-3A	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (low)	6/11/14	<1		
JMS-0611-3B	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (low)	6/11/14	<1		
JMS-0611-4A	Johnson MS	3rd floor hallway adjacent to Girl's Room (high)	6/11/14	<1		
JMS-0611-4B	Johnson MS	3rd floor hallway adjacent to Girl's Room (high)	6/11/14	<1		
JMS-0611-5A	Johnson MS	3rd floor hallway adjacent to Girl's Room (low)	6/11/14	<1		
JMS-0611-5B	Johnson MS	3rd floor hallway adjacent to Girl's Room (low)	6/11/14	<1		
JMS-0611-6A	Johnson MS	3rd floor hallway adjacent to Elevator	6/11/14	<1		
JMS-0611-6B	Johnson MS	3rd floor hallway adjacent to Elevator	6/11/14	<1		
JMS-0611-7A	Johnson MS	3rd floor hallway adjacent to Science Lab 220 (high)	6/11/14	<1		
JMS-0611-7B	Johnson MS	3rd floor hallway adjacent to Science Lab 220 (high)	6/11/14	<1		
JMS-0611-8A	Johnson MS	3rd floor hallway adjacent to Science Lab 220 (low)	6/11/14	<1		
JMS-0611-8B	Johnson MS	3rd floor hallway adjacent to Science Lab 220 (low)	6/11/14	<1		
JMS-0611-9A	Johnson MS	2nd floor hallway adjacent to Girl's Room (high)	6/11/14	<1		
JMS-0611-9B	Johnson MS	2nd floor hallway adjacent to Girl's Room (high)	6/11/14	<1		
JMS-0611-10A	Johnson MS	2nd floor hallway adjacent to Girl's Room (low)	6/11/14	<1		
JMS-0611-10B	Johnson MS	2nd floor hallway adjacent to Girl's Room (low)	6/11/14	<1		
JMS-0611-11A	Johnson MS	2nd floor hallway adjacent to Elevator	6/11/14	<1		
JMS-0611-11B	Johnson MS	2nd floor hallway adjacent to Elevator	6/11/14	<1		
JMS-0611-12A	Johnson MS	1st floor near entrance of new addition to building	6/11/14	<1		
JMS-0611-12B	Johnson MS	1st floor near entrance of new addition to building	6/11/14	<1		
JMS-0611-13A	Johnson MS	1st floor hallway adjacent to Girl's Room (high)	6/11/14	<1		
JMS-0611-13B	Johnson MS	1st floor hallway adjacent to Girl's Room (high)	6/11/14	<1		
JMS-0611-14A	Johnson MS	1st floor hallway adjacent to Girl's Room (low)	6/11/14	<1		
JMS-0611-14B	Johnson MS	1st floor hallway adjacent to Girl's Room (low)	6/11/14	<1		
JMS-0611-15A	Johnson MS	1st floor hallway adjacent to Elevator	6/11/14	<1		
JMS-0611-15B	Johnson MS	1st floor hallway adjacent to Elevator	6/11/14	<1		
JMS-0611-16A	Johnson MS	1st floor inside Cafeteria (left wall)	6/11/14	<1		
JMS-0611-16B	Johnson MS	1st floor inside Cafeteria (left wall)	6/11/14	<1		
JMS-0611-17A	Johnson MS	1st floor inside Cafeteria (right wall)	6/11/14	<1		
JMS-0611-17B	Johnson MS	1st floor inside Cafeteria (right wall)	6/11/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
WMHS-70814-1A	K.C. Lewis ES	Near Room 312	7/8/14	<1		
WMHS-70814-2B	K.C. Lewis ES	Near Room 312	7/8/14	<1		
WMHS-70814-3A	K.C. Lewis ES	Between Rooms 303 & 305	7/8/14	<1		
WMHS-70814-4B	K.C. Lewis ES	Between Rooms 303 & 305	7/8/14	<1		
WMHS-70814-5A	K.C. Lewis ES	Staircase 201	7/8/14	<1		
WMHS-70814-6B	K.C. Lewis ES	Staircase 201	7/8/14	<1		
WMHS-70814-7A	K.C. Lewis ES	Near Room 210	7/8/14	<1		
WMHS-70814-8B	K.C. Lewis ES	Near Room 210	7/8/14	<1		
WMHS-70814-9A	K.C. Lewis ES	Near Room 104	7/8/14	<1		
WMHS-70814-10B	K.C. Lewis ES	Near Room 104	7/8/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
KM-0610-1A	Kelly Miller MS	3rd floor hallway adjacent to Boy's Room (low)	6/10/14	<1		
KM-0610-1B	Kelly Miller MS	3rd floor hallway adjacent to Boy's Room (low)	6/10/14	<1		
KM-0610-2A	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (high)	6/10/14	<1		
KM-0610-2B	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (high)	6/10/14	<1		
KM-0610-3A	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (low)	6/10/14	<1		
KM-0610-3B	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (low)	6/10/14	<1		
KM-0610-4A	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (high)	6/10/14	<1		
KM-0610-4B	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (high)	6/10/14	<1		
KM-0610-5A	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (low)	6/10/14	<1		
KM-0610-5B	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (low)	6/10/14	<1		
KM-0610-6A	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (high)	6/10/14	<1		
KM-0610-6B	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (high)	6/10/14	<1		
KM-0610-7A	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (low)	6/10/14	<1		
KM-0610-7B	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (low)	6/10/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
KM-0610-8A	Kelly Miller MS	1st floor inside Cafeteria (high)	6/10/14	<1		
KM-0610-8B	Kelly Miller MS	1st floor inside Cafeteria (high)	6/10/14	<1		
KM-0610-9A	Kelly Miller MS	1st floor inside Cafeteria (low)	6/10/14	<1		
KM-0610-9B	Kelly Miller MS	1st floor inside Cafeteria (low)	6/10/14	<1		
KM-0610-10A	Kelly Miller MS	1st floor inside Gym adjacent to Girl's Locker Room	6/10/14	<1		
KM-0610-10B	Kelly Miller MS	1st floor inside Gym adjacent to Girl's Locker Room	6/10/14	<1		
KM-0610-11A	Kelly Miller MS	1st floor inside Gym adjacent to Electric Room D122	6/10/14	<1		
KM-0610-11B	Kelly Miller MS	1st floor inside Gym adjacent to Electric Room D122	6/10/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
KES-0127-1A	Kenilworth ES	3rd Fl Hall across from Room 310	1/27/14	<1		
KES-0127-1B	Kenilworth ES	3rd Fl Hall across from Room 310	1/27/14	<1		
KES-0127-2A	Kenilworth ES	2nd Fl Hall adj to Girls Rm	1/27/14	<1		
KES-0127-2B	Kenilworth ES	2nd Fl Hall adj to Girls Rm	1/27/14	<1		
KES-0127-3A	Kenilworth ES	2nd Fl Hall across from Room 210	1/27/14	<1		
KES-0127-3B	Kenilworth ES	2nd Fl Hall across from Room 210	1/27/14	<1		
KES-0127-4A	Kenilworth ES	1st Fl Hall adj to Teacher's Lounge	1/27/14	<1		
KES-0127-4B	Kenilworth ES	1st Fl Hall adj to Teacher's Lounge	1/27/14	<1		
KES-0127-5A	Kenilworth ES	1st Fl inside Health Suite	1/27/14	<1		
KES-0127-5B	Kenilworth ES	1st Fl inside Health Suite	1/27/14	<1		
KES-0127-6A	Kenilworth ES	1st Fl inside Kindergarten/Early Learning Center	1/27/14	<1		
KES-0127-6B	Kenilworth ES	1st Fl inside Kindergarten/Early Learning Center	1/27/14	<1		
KES-0127-7A	Kenilworth ES	1st Fl Hall across from Assembly Rm	1/27/14	<1		
KES-0127-7B	Kenilworth ES	1st Fl Hall across from Assembly Rm	1/27/14	<1		
KES-0127-8A	Kenilworth ES	1st Fl inside Digital Media Academy Rm	1/27/14	<1		
KES-0127-8B	Kenilworth ES	1st Fl inside Digital Media Academy Rm	1/27/14	<1		
KES-0127-9A	Kenilworth ES	1st Fl Hall adj to Room 100	1/27/14	<1		
KES-0127-9B	Kenilworth ES	1st Fl Hall adj to Room 100	1/27/14	<1		
KES-0127-10A	Kenilworth ES	1st Fl Hall across from Room 106	1/27/14	<1		
KES-0127-10B	Kenilworth ES	1st Fl Hall across from Room 106	1/27/14	<1		
KES-0127-11A	Kenilworth ES	2nd Fl Hall adj to Room 214	1/27/14	<1		
KES-0127-11B	Kenilworth ES	2nd Fl Hall adj to Room 214	1/27/14	<1		
KES-0127-12A	Kenilworth ES	2nd Fl Hall adj to Room 218	1/27/14	<1		
KES-0127-12B	Kenilworth ES	2nd Fl Hall adj to Room 218	1/27/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
KES-0312-1A	Ketcham ES	3rd floor hallway between Boy's and Girl's Rooms	3/12/14	<1		
KES-0312-1B	Ketcham ES	3rd floor hallway between Boy's and Girl's Rooms	3/12/14	<1		
KES-0312-2A	Ketcham ES	2nd floor hallway between Boy's and Girl's Rooms	3/12/14	<1		
KES-0312-2B	Ketcham ES	2nd floor hallway between Boy's and Girl's Rooms	3/12/14	<1		
KES-0312-3A	Ketcham ES	1st floor hallway between Boy's and Girl's Rooms	3/12/14	<1		
KES-0312-3B	Ketcham ES	1st floor hallway between Boy's and Girl's Rooms	3/12/14	1.1		
KES-0312-4A	Ketcham ES	1st floor hallway adjacent to Music Room A102	3/12/14	<1		
KES-0312-4B	Ketcham ES	1st floor hallway adjacent to Music Room A102	3/12/14	<1		
KES-0312-5A	Ketcham ES	1st floor inside Classroom A101 Kindergarten	3/12/14	<1		
KES-0312-5B	Ketcham ES	1st floor inside Classroom A101 Kindergarten	3/12/14	1.3		
KES-0312-6A	Ketcham ES	Basement floor hallway adjacent to Girl's Room	3/12/14	2.6		
KES-0312-6B	Ketcham ES	Basement floor hallway adjacent to Girl's Room	3/12/14	<1		
KES-0312-7A	Ketcham ES	1st floor inside Classroom B116 Pre-K	3/12/14	3.3		
KES-0312-7B	Ketcham ES	1st floor inside Classroom B116 Pre-K	3/12/14	1.5		
KES-0312-8A	Ketcham ES	1st floor inside Classroom B114 Pre-K	3/12/14	3		
KES-0312-8B	Ketcham ES	1st floor inside Classroom B114 Pre-K	3/12/14	<1		
KES-0312-9A	Ketcham ES	1st floor inside Classroom B113 Pre-K	3/12/14	3.6		
KES-0312-9B	Ketcham ES	1st floor inside Classroom B113 Pre-K	3/12/14	4.9		
KES-0312-10A	Ketcham ES	1st floor inside room between Classrooms B112 and B109	3/12/14	6		
KES-0312-10B	Ketcham ES	1st floor inside room between Classrooms B112 and B109	3/12/14	1.5		
KES-0312-11A	Ketcham ES	Basement inside Cafeteria	3/12/14	1.6		
KES-0312-11B	Ketcham ES	Basement inside Cafeteria	3/12/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
KES-0513-1A	Key ES	2nd floor adjacent to Classroom 204	5/13/14	<1		
KES-0513-1B	Key ES	2nd floor adjacent to Classroom 204	5/13/14	<1		
KES-0513-2A	Key ES	2nd floor inside Classroom 202	5/13/14	<1		
KES-0513-2B	Key ES	2nd floor inside Classroom 202	5/13/14	<1		
KES-0513-3A	Key ES	2nd floor inside Classroom 201	5/13/14	<1		
KES-0513-3B	Key ES	2nd floor inside Classroom 201	5/13/14	<1		
KES-0513-4A	Key ES	2nd floor inside Classroom 203	5/13/14	<1		
KES-0513-4B	Key ES	2nd floor inside Classroom 203	5/13/14	<1		
KES-0513-5A	Key ES	2nd floor inside Classroom 204	5/13/14	<1		
KES-0513-5B	Key ES	2nd floor inside Classroom 204	5/13/14	<1		
KES-0513-6A	Key ES	2nd floor inside Classroom 205	5/13/14	<1		
KES-0513-6B	Key ES	2nd floor inside Classroom 205	5/13/14	<1		
KES-0513-7A	Key ES	2nd floor inside Classroom 206 (left)	5/13/14	<1		
KES-0513-7B	Key ES	2nd floor inside Classroom 206 (left)	5/13/14	<1		
KES-0513-8A	Key ES	2nd floor inside Classroom 206 (right)	5/13/14	<1		
KES-0513-8B	Key ES	2nd floor inside Classroom 206 (right)	5/13/14	<1		
KES-0513-9A	Key ES	2nd floor inside Classroom 207	5/13/14	<1		
KES-0513-9B	Key ES	2nd floor inside Classroom 207	5/13/14	<1		
KES-0513-10A	Key ES	2nd floor inside Classroom 208	5/13/14	<1		
KES-0513-10B	Key ES	2nd floor inside Classroom 208	5/13/14	<1		
KES-0513-11A	Key ES	2nd floor hallway adjacent to Classroom 209	5/13/14	<1		
KES-0513-11B	Key ES	2nd floor hallway adjacent to Classroom 209	5/13/14	<1		
KES-0513-12A	Key ES	2nd floor inside Classroom 209	5/13/14	<1		
KES-0513-12B	Key ES	2nd floor inside Classroom 209	5/13/14	<1		
KES-0513-13A	Key ES	2nd floor inside Classroom 210	5/13/14	<1		
KES-0513-13B	Key ES	2nd floor inside Classroom 210	5/13/14	<1		
KES-0513-14A	Key ES	2nd floor inside Classroom 211	5/13/14	<1		
KES-0513-14B	Key ES	2nd floor inside Classroom 211	5/13/14	<1		
KES-0513-15A	Key ES	2nd floor inside Classroom 212	5/13/14	<1		
KES-0513-15B	Key ES	2nd floor inside Classroom 212	5/13/14	<1		
KES-0513-16A	Key ES	1st floor inside Classroom 101	5/13/14	<1		
KES-0513-16B	Key ES	1st floor inside Classroom 101	5/13/14	<1		
KES-0513-17A	Key ES	1st floor inside Classroom 102	5/13/14	<1		
KES-0513-17B	Key ES	1st floor inside Classroom 102	5/13/14	<1		
KES-0513-18A	Key ES	1st floor inside Classroom 103	5/13/14	<1		
KES-0513-18B	Key ES	1st floor inside Classroom 103	5/13/14	<1		
KES-0513-19A	Key ES	1st floor inside Classroom 104	5/13/14	<1		
KES-0513-19B	Key ES	1st floor inside Classroom 104	5/13/14	<1		
KES-0513-20A	Key ES	1st floor hallway adjacent to Classroom 104	5/13/14	<1		
KES-0513-20B	Key ES	1st floor hallway adjacent to Classroom 104	5/13/14	<1		
KES-0513-21A	Key ES	1st floor hallway adjacent to Classroom 103	5/13/14	<1		
KES-0513-21B	Key ES	1st floor hallway adjacent to Classroom 103	5/13/14	<1		
KES-0513-22A	Key ES	1st floor inside Classroom 105	5/13/14	1		
KES-0513-22B	Key ES	1st floor inside Classroom 105	5/13/14	<1		
KES-0513-23A	Key ES	1st floor inside Classroom 106	5/13/14	<1		
KES-0513-23B	Key ES	1st floor inside Classroom 106	5/13/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
KES-0415-1A	Kimball ES	2nd floor hallway South Wing across from Classroom OS2B	4/15/14	<1		
KES-0415-1B	Kimball ES	2nd floor hallway South Wing across from Classroom OS2B	4/15/14	<1		
KES-0415-2A	Kimball ES	2nd floor hallway South Wing between Teacher's Restroom and Custodian Closet	4/15/14	<1		
KES-0415-2B	Kimball ES	2nd floor hallway South Wing between Teacher's Restroom and Custodian Closet	4/15/14	<1		
KES-0415-3A	Kimball ES	1st floor hallway South Wing between Teacher's Restroom and Custodian Closet	4/15/14	<1		
KES-0415-3B	Kimball ES	1st floor hallway South Wing between Teacher's Restroom and Custodian Closet	4/15/14	<1		
KES-0415-4A	Kimball ES	2nd floor hallway Middle Wing adjacent to Teacher's Lounge	4/15/14	<1		
KES-0415-4B	Kimball ES	2nd floor hallway Middle Wing adjacent to Teacher's Lounge	4/15/14	<1		
KES-0415-5A	Kimball ES	2nd floor hallway Middle Wing adjacent to Classroom 212	4/15/14	<1		
KES-0415-5B	Kimball ES	2nd floor hallway Middle Wing adjacent to Classroom 212	4/15/14	<1		
KES-0415-6A	Kimball ES	1st floor hallway Middle Wing adjacent to Classroom 112	4/15/14	<1		
KES-0415-6B	Kimball ES	1st floor hallway Middle Wing adjacent to Classroom 112	4/15/14	<1		
KES-0415-7A	Kimball ES	1st floor hallway Middle Wing across from Classroom 105	4/15/14	<1		
KES-0415-7B	Kimball ES	1st floor hallway Middle Wing across from Classroom 105	4/15/14	<1		
KES-0415-8A	Kimball ES	Basement floor @ exit to Cafeteria	4/15/14	<1		
KES-0415-8B	Kimball ES	Basement floor @ exit to Cafeteria	4/15/14	<1		
KES-0415-9A	Kimball ES	1st floor hallway adjacent to Auditorium	4/15/14	<1		
KES-0415-9B	Kimball ES	1st floor hallway adjacent to Auditorium	4/15/14	<1		
KES-0415-10A	Kimball ES	2nd floor hallway North Wing adjacent to Classroom 200	4/15/14	<1		
KES-0415-10B	Kimball ES	2nd floor hallway North Wing adjacent to Classroom 200	4/15/14	1.3		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
NES-0307-10B	Nalle ES	1st floor inside Classroom 118	3/7/14	<1		
NES-0307-11A	Nalle ES	2nd floor hallway across from Classroom 214 (high)	3/7/14	<1		
NES-0307-11B	Nalle ES	2nd floor hallway across from Classroom 214 (high)	3/7/14	<1		
NES-0307-12A	Nalle ES	2nd floor hallway across from Classroom 214 (low)	3/7/14	<1		
NES-0307-12B	Nalle ES	2nd floor hallway across from Classroom 214 (low)	3/7/14	<1		
NES-0307-13A	Nalle ES	2nd floor hallway adjacent to Teacher's Lounge 230	3/7/14	<1		
NES-0307-13B	Nalle ES	2nd floor hallway adjacent to Teacher's Lounge 230	3/7/14	<1		
NES-0307-14A	Nalle ES	1st floor hall adj to Custodian Closet 111 (high)	3/7/14	<1		
NES-0307-14B	Nalle ES	1st floor hall adj to Custodian Closet 111 (high)	3/7/14	<1		
NES-0307-15A	Nalle ES	1st floor hall adj to Custodian Closet 111 (low)	3/7/14	<1		
NES-0307-15B	Nalle ES	1st floor hall adj to Custodian Closet 111 (low)	3/7/14	<1		
NES-0307-16A	Nalle ES	1st floor hall adj to Custodian Closet 127	3/7/14	<1		
NES-0307-16B	Nalle ES	1st floor hall adj to Custodian Closet 127	3/7/14	<1		
			Percentage of Passed Samples		100.00%	
			Percentage of Failed Samples		0.00%	
NES-0507-1A	Noyes ES	2nd floor inside Classroom 216	5/7/14	<1		
NES-0507-1B	Noyes ES	2nd floor inside Classroom 216	5/7/14	<1		
NES-0507-2A	Noyes ES	2nd floor inside Classroom 214	5/7/14	<1		
NES-0507-2B	Noyes ES	2nd floor inside Classroom 214	5/7/14	<1		
NES-0507-3A	Noyes ES	2nd floor inside Speech Room 212	5/7/14	<1		
NES-0507-3B	Noyes ES	2nd floor inside Speech Room 212	5/7/14	<1		
NES-0507-4A	Noyes ES	2nd floor inside Classroom 213	5/7/14	<1		
NES-0507-4B	Noyes ES	2nd floor inside Classroom 213	5/7/14	<1		
NES-0507-5A	Noyes ES	2nd floor hallway near Elevator (high)	5/7/14	<1		
NES-0507-5B	Noyes ES	2nd floor hallway near Elevator (high)	5/7/14	<1		
NES-0507-6A	Noyes ES	2nd floor hallway near Elevator (low)	5/7/14	<1		
NES-0507-6B	Noyes ES	2nd floor hallway near Elevator (low)	5/7/14	<1		
NES-0507-7A	Noyes ES	2nd floor inside Classroom 206	5/7/14	<1		
NES-0507-7B	Noyes ES	2nd floor inside Classroom 206	5/7/14	<1		
NES-0507-8A	Noyes ES	2nd floor inside Classroom 204	5/7/14	<1		
NES-0507-8B	Noyes ES	2nd floor inside Classroom 204	5/7/14	<1		
NES-0507-9A	Noyes ES	2nd floor inside Classroom 203	5/7/14	<1		
NES-0507-9B	Noyes ES	2nd floor inside Classroom 203	5/7/14	<1		
NES-0507-10A	Noyes ES	2nd floor inside Classroom 205	5/7/14	<1		
NES-0507-10B	Noyes ES	2nd floor inside Classroom 205	5/7/14	<1		
NES-0507-11A	Noyes ES	2nd floor hallway adjacent to Classroom 202 (high)	5/7/14	<1		
NES-0507-11B	Noyes ES	2nd floor hallway adjacent to Classroom 202 (high)	5/7/14	<1		
NES-0507-12A	Noyes ES	2nd floor hallway adjacent to Classroom 202 (low)	5/7/14	<1		
NES-0507-12B	Noyes ES	2nd floor hallway adjacent to Classroom 202 (low)	5/7/14	<1		
NES-0507-13A	Noyes ES	1st floor hallway adjacent to Stair A (high)	5/7/14	<1		
NES-0507-13B	Noyes ES	1st floor hallway adjacent to Stair A (high)	5/7/14	<1		
NES-0507-14A	Noyes ES	1st floor hallway adjacent to Stair A (low)	5/7/14	<1		
NES-0507-14B	Noyes ES	1st floor hallway adjacent to Stair A (low)	5/7/14	<1		
NES-0507-15A	Noyes ES	1st floor hallway near entrance to Auditorium (high)	5/7/14	<1		
NES-0507-15B	Noyes ES	1st floor hallway near entrance to Auditorium (high)	5/7/14	<1		
NES-0507-16A	Noyes ES	1st floor hallway near entrance to Auditorium (low)	5/7/14	<1		
NES-0507-16B	Noyes ES	1st floor hallway near entrance to Auditorium (low)	5/7/14	<1		
NES-0507-17A	Noyes ES	1st floor hallway at entrance to Gym (high)	5/7/14	<1		
NES-0507-17B	Noyes ES	1st floor hallway at entrance to Gym (high)	5/7/14	<1		
NES-0507-18A	Noyes ES	1st floor hallway at entrance to Gym (low)	5/7/14	<1		
NES-0507-18B	Noyes ES	1st floor hallway at entrance to Gym (low)	5/7/14	<1		
NES-0507-19A	Noyes ES	Ground floor inside Classroom 129	5/7/14	<1		
NES-0507-19B	Noyes ES	Ground floor inside Classroom 129	5/7/14	<1		
NES-0507-20A	Noyes ES	Ground floor inside Classroom 131	5/7/14	<1		
NES-0507-20B	Noyes ES	Ground floor inside Classroom 131	5/7/14	<1		
NES-0507-21A	Noyes ES	Ground floor inside Classroom 128	5/7/14	<1		
NES-0507-21B	Noyes ES	Ground floor inside Classroom 128	5/7/14	<1		
NES-0507-22A	Noyes ES	Ground floor inside Classroom 130	5/7/14	<1		
NES-0507-22B	Noyes ES	Ground floor inside Classroom 130	5/7/14	<1		
NES-0507-23A	Noyes ES	Ground floor inside Classroom 133	5/7/14	<1		
NES-0507-23B	Noyes ES	Ground floor inside Classroom 133	5/7/14	<1		
NES-0507-24A	Noyes ES	Ground floor inside Classroom 135	5/7/14	<1		
NES-0507-24B	Noyes ES	Ground floor inside Classroom 135	5/7/14	<1		
NES-0507-25A	Noyes ES	Ground floor inside Classroom 132	5/7/14	<1		
NES-0507-25B	Noyes ES	Ground floor inside Classroom 132	5/7/14	<1		
NES-0507-26A	Noyes ES	Ground floor inside Classroom 134	5/7/14	<1		
NES-0507-26B	Noyes ES	Ground floor inside Classroom 134	5/7/14	<1		
			Percentage of Passed Samples		100.00%	
			Percentage of Failed Samples		0.00%	
OES-0313-1A	Orr ES	4th floor hallway adjacent to Girl's room	3/13/14	<1		
OES-0313-1B	Orr ES	4th floor hallway adjacent to Girl's room	3/13/14	<1		
OES-0313-2A	Orr ES	4th floor hallway adjacent to Boy's room	3/13/14	<1		
OES-0313-2B	Orr ES	4th floor hallway adjacent to Boy's room	3/13/14	<1		
OES-0313-3A	Orr ES	3rd floor hallway adjacent to Girl's room	3/13/14	<1		
OES-0313-3B	Orr ES	3rd floor hallway adjacent to Girl's room	3/13/14	<1		
OES-0313-4A	Orr ES	3rd floor hallway adjacent to Boy's room	3/13/14	<1		
OES-0313-4B	Orr ES	3rd floor hallway adjacent to Boy's room	3/13/14	<1		
OES-0313-5A	Orr ES	2nd floor hallway adjacent to Girl's Room	3/13/14	<1		
OES-0313-5B	Orr ES	2nd floor hallway adjacent to Girl's Room	3/13/14	<1		
OES-0313-6A	Orr ES	2nd floor hallway adjacent to Boy's Room	3/13/14	<1		
OES-0313-6B	Orr ES	2nd floor hallway adjacent to Boy's Room	3/13/14	<1		
OES-0313-7A	Orr ES	1st floor inside Pre-K 4	3/13/14	<1		
OES-0313-7B	Orr ES	1st floor inside Pre-K 4	3/13/14	<1		
OES-0313-8A	Orr ES	1st floor inside Pre-School 3	3/13/14	<1		
OES-0313-8B	Orr ES	1st floor inside Pre-School 3	3/13/14	<1		
OES-0313-9A	Orr ES	1st floor inside Pre-School 2	3/13/14	3.8		
OES-0313-9B	Orr ES	1st floor inside Pre-School 2	3/13/14	3.8		
OES-0313-10A	Orr ES	1st floor inside Pre-School 1	3/13/14	<1		
OES-0313-10B	Orr ES	1st floor inside Pre-School 1	3/13/14	<1		
OES-0313-11A	Orr ES	1st floor hallway across from Main Office	3/13/14	<1		
OES-0313-11B	Orr ES	1st floor hallway across from Main Office	3/13/14	<1		
OES-0313-12A	Orr ES	1st floor hallway adjacent to Instructional Resource Room	3/13/14	<1		
OES-0313-12B	Orr ES	1st floor hallway adjacent to Instructional Resource Room	3/13/14	<1		
OES-0313-13A	Orr ES	1st floor inside Multi-Purpose Rm.	3/13/14	<1		
OES-0313-13B	Orr ES	1st floor inside Multi-Purpose Rm.	3/13/14	<1		
OES-0313-14A	Orr ES	1st floor inside Health Suite	3/13/14	<1		
OES-0313-14B	Orr ES	1st floor inside Health Suite	3/13/14	<1		
			Percentage of Passed Samples		100.00%	
			Percentage of Failed Samples		0.00%	
OES-0502-1A	Oyster ES	4th floor inside Classroom 415	5/2/14	<1		
OES-0502-1B	Oyster ES	4th floor inside Classroom 415	5/2/14	<1		
OES-0502-2A	Oyster ES	4th floor inside Classroom 412	5/2/14	<1		
OES-0502-2B	Oyster ES	4th floor inside Classroom 412	5/2/14	<1		
OES-0502-3A	Oyster ES	4th floor inside Classroom 410	5/2/14	<1		
OES-0502-3B	Oyster ES	4th floor inside Classroom 410	5/2/14	<1		
OES-0502-4A	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (high)	5/2/14	<1		
OES-0502-4B	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (high)	5/2/14	<1		
OES-0502-5A	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (low)	5/2/14	<1		
OES-0502-5B	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (low)	5/2/14	<1		
OES-0502-6A	Oyster ES	4th floor inside Classroom 407	5/2/14	<1		
OES-0502-6B	Oyster ES	4th floor inside Classroom 407	5/2/14	<1		
OES-0502-7A	Oyster ES	4th floor inside Classroom 405	5/2/14	<1		
OES-0502-7B	Oyster ES	4th floor inside Classroom 405	5/2/14	<1		
OES-0502-8A	Oyster ES	4th floor inside Classroom 401	5/2/14	<1		
OES-0502-8B	Oyster ES	4th floor inside Classroom 401	5/2/14	<1		
OES-0502-9A	Oyster ES	3rd floor inside Classroom 316	5/2/14	<1		
OES-0502-9B	Oyster ES	3rd floor inside Classroom 316	5/2/14	<1		
OES-0502-10A	Oyster ES	3rd floor inside Classroom 313	5/2/14	<1		
OES-0502-10B	Oyster ES	3rd floor inside Classroom 313	5/2/14	<1		
OES-0502-11A	Oyster ES	3rd floor hallway across from Pump Room 312 (high)	5/2/14	<1		
OES-0502-11B	Oyster ES	3rd floor hallway across from Pump Room 312 (high)	5/2/14	<1		
OES-0502-12A	Oyster ES	3rd floor hallway across from Pump Room 312 (low)	5/2/14	<1		
OES-0502-12B	Oyster ES	3rd floor hallway across from Pump Room 312 (low)	5/2/14	<1		
OES-0502-13A	Oyster ES	3rd floor inside Classroom 308	5/2/14	<1		
OES-0502-13B	Oyster ES	3rd floor inside Classroom 308	5/2/14	<1		
OES-0502-14A	Oyster ES	3rd floor inside Classroom 304	5/2/14	<1		
OES-0502-14B	Oyster ES	3rd floor inside Classroom 304	5/2/14	<1		
OES-0502-15A	Oyster ES	3rd floor inside Classroom 301	5/2/14	<1		
OES-0502-15B	Oyster ES	3rd floor inside Classroom 301	5/2/14	<1		
OES-0502-16A	Oyster ES	2nd floor inside Classroom 211	5/2/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PES-0219-32B	Patterson MS	1st floor inside Cafeteria (high)	2/19/14	<1		
PES-0219-33A	Patterson MS	1st floor inside Cafeteria (low)	2/19/14	<1		
PES-0219-33B	Patterson MS	1st floor inside Cafeteria (low)	2/19/14	<1		
PES-0219-34A	Patterson MS	1st floor hallway adjacent to Janitor's Closet 110 (high)	2/19/14	<1		
PES-0219-34B	Patterson MS	1st floor hallway adjacent to Janitor's Closet 110 (high)	2/19/14	<1		
PES-0219-35A	Patterson MS	1st floor hallway adjacent to Janitor's Closet 110 (low)	2/19/14	1.7		
PES-0219-35B	Patterson MS	1st floor hallway adjacent to Janitor's Closet 110 (low)	2/19/14	2.1		
PES-0219-36A	Patterson MS	1st floor inside Classroom 125	2/19/14	3		
PES-0219-36B	Patterson MS	1st floor inside Classroom 125	2/19/14	<1		
PES-0219-37A	Patterson MS	2nd floor inside Classroom 218	2/19/14	<1		
PES-0219-37B	Patterson MS	2nd floor inside Classroom 218	2/19/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
PES-0401-1A	Payne ES	3rd floor hallway across from Women's Restroom	4/1/14	<1		
PES-0401-1B	Payne ES	3rd floor hallway across from Women's Restroom	4/1/14	<1		
PES-0401-2A	Payne ES	3rd floor hallway adjacent to Boy's Room	4/1/14	<1		
PES-0401-2B	Payne ES	3rd floor hallway adjacent to Boy's Room	4/1/14	<1		
PES-0401-3A	Payne ES	2nd floor hallway across from Women's Restroom	4/1/14	<1		
PES-0401-3B	Payne ES	2nd floor hallway across from Women's Restroom	4/1/14	<1		
PES-0401-4A	Payne ES	1st floor hallway adjacent to Men's Room	4/1/14	<1		
PES-0401-4B	Payne ES	1st floor hallway adjacent to Men's Room	4/1/14	<1		
PES-0401-5A	Payne ES	1st floor inside Classroom 125 Kindergarten	4/1/14	2.8		
PES-0401-5B	Payne ES	1st floor inside Classroom 125 Kindergarten	4/1/14	1.1		
PES-0401-6A	Payne ES	1st floor hallway across from Classroom 133	4/1/14	<1		
PES-0401-6B	Payne ES	1st floor hallway across from Classroom 133	4/1/14	<1		
PES-0401-7A	Payne ES	1st floor hallway adjacent to Custodian Closet	4/1/14	<1		
PES-0401-7B	Payne ES	1st floor hallway adjacent to Custodian Closet	4/1/14	<1		
PES-0401-8A	Payne ES	1st floor inside Cafeteria	4/1/14	<1		
PES-0401-8B	Payne ES	1st floor inside Cafeteria	4/1/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
PES-0129-1A	Peabody ES	Basement floor hallway adjacent to Girl's Room (high)	1/29/14	<1		
PES-0129-1B	Peabody ES	Basement floor hallway adjacent to Girl's Room (high)	1/29/14	<1		
PES-0129-2A	Peabody ES	Basement floor hallway adjacent to Girl's Room (low)	1/29/14	<1		
PES-0129-2B	Peabody ES	Basement floor hallway adjacent to Girl's Room (low)	1/29/14	<1		
PES-0129-3A	Peabody ES	3rd floor inside Classroom 303	1/29/14	<1		
PES-0129-3B	Peabody ES	3rd floor inside Classroom 303	1/29/14	<1		
PES-0129-4A	Peabody ES	3rd floor inside Classroom 304	1/29/14	<1		
PES-0129-4B	Peabody ES	3rd floor inside Classroom 304	1/29/14	<1		
PES-0129-5A	Peabody ES	3rd floor inside Classroom 306	1/29/14	<1		
PES-0129-5B	Peabody ES	3rd floor inside Classroom 306	1/29/14	<1		
PES-0129-6A	Peabody ES	3rd floor inside Classroom 307	1/29/14	<1		
PES-0129-6B	Peabody ES	3rd floor inside Classroom 307	1/29/14	<1		
PES-0129-7A	Peabody ES	2nd floor inside Classroom 203	1/29/14	<1		
PES-0129-7B	Peabody ES	2nd floor inside Classroom 203	1/29/14	<1		
PES-0129-8A	Peabody ES	2nd floor inside Classroom 204	1/29/14	<1		
PES-0129-8B	Peabody ES	2nd floor inside Classroom 204	1/29/14	<1		
PES-0129-9A	Peabody ES	2nd floor inside Classroom 206	1/29/14	<1		
PES-0129-9B	Peabody ES	2nd floor inside Classroom 206	1/29/14	<1		
PES-0129-10A	Peabody ES	2nd floor inside Classroom 207	1/29/14	<1		
PES-0129-10B	Peabody ES	2nd floor inside Classroom 207	1/29/14	<1		
PES-0129-11A	Peabody ES	1st floor inside Classroom 103	1/29/14	<1		
PES-0129-11B	Peabody ES	1st floor inside Classroom 103	1/29/14	<1		
PES-0129-12A	Peabody ES	1st floor inside Classroom 104	1/29/14	<1		
PES-0129-12B	Peabody ES	1st floor inside Classroom 104	1/29/14	<1		
PES-0129-13A	Peabody ES	1st floor inside Classroom 106	1/29/14	<1		
PES-0129-13B	Peabody ES	1st floor inside Classroom 106	1/29/14	<1		
PES-0129-14A	Peabody ES	1st floor inside Classroom 107	1/29/14	<1		
PES-0129-14B	Peabody ES	1st floor inside Classroom 107	1/29/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
PHS-0703-1A	Phelps HS	2nd floor hallway adjacent to Music Room S206	7/3/14	<1		
PHS-0703-1B	Phelps HS	2nd floor hallway adjacent to Music Room S206	7/3/14	<1		
PHS-0703-2A	Phelps HS	2nd floor hallway adjacent to Classroom C211	7/3/14	<1		
PHS-0703-2B	Phelps HS	2nd floor hallway adjacent to Classroom C211	7/3/14	<1		
PHS-0703-3A	Phelps HS	1st floor hallway adjacent to Classroom C108	7/3/14	<1		
PHS-0703-3B	Phelps HS	1st floor hallway adjacent to Classroom C108	7/3/14	<1		
PHS-0703-4A	Phelps HS	1st floor hallway adjacent to Classroom C110	7/3/14	<1		
PHS-0703-4B	Phelps HS	1st floor hallway adjacent to Classroom C110	7/3/14	<1		
PHS-0703-5A	Phelps HS	Lower level hallway across from Gym	7/3/14	<1		
PHS-0703-5B	Phelps HS	Lower level hallway across from Gym	7/3/14	<1		
PHS-0703-6A	Phelps HS	Lower level hallway adjacent to Custodian Closet S005	7/3/14	<1		
PHS-0703-6B	Phelps HS	Lower level hallway adjacent to Custodian Closet S005	7/3/14	<1		
PHS-0703-7A	Phelps HS	1st floor hallway adjacent to Wood Shop T106	7/3/14	<1		
PHS-0703-7B	Phelps HS	1st floor hallway adjacent to Wood Shop T106	7/3/14	<1		
PHS-0703-8A	Phelps HS	1st floor hallway adjacent to Electric Shop T104	7/3/14	<1		
PHS-0703-8B	Phelps HS	1st floor hallway adjacent to Electric Shop T104	7/3/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
PES-0310-1A	Plummer ES	2nd floor hallway across from Classroom 212	3/10/14	<1		
PES-0310-1B	Plummer ES	2nd floor hallway across from Classroom 212	3/10/14	<1		
PES-0310-2A	Plummer ES	2nd floor hallway adjacent to Teacher's Restroom	3/10/14	<1		
PES-0310-2B	Plummer ES	2nd floor hallway adjacent to Teacher's Restroom	3/10/14	<1		
PES-0310-3A	Plummer ES	1st floor hallway adjacent to Classroom 132	3/10/14	<1		
PES-0310-3B	Plummer ES	1st floor hallway adjacent to Classroom 132	3/10/14	<1		
PES-0310-4A	Plummer ES	1st floor inside Cafeteria	3/10/14	<1		
PES-0310-4B	Plummer ES	1st floor inside Cafeteria	3/10/14	<1		
PES-0310-5A	Plummer ES	1st floor hallway adjacent to Boy's Room	3/10/14	<1		
PES-0310-5B	Plummer ES	1st floor hallway adjacent to Boy's Room	3/10/14	<1		
PES-0310-6A	Plummer ES	1st floor hallway adjacent to Classroom 127 Pre-K	3/10/14	<1		
PES-0310-6B	Plummer ES	1st floor hallway adjacent to Classroom 127 Pre-K	3/10/14	<1		
PES-0310-7A	Plummer ES	1st floor hallway adjacent to Classroom 125	3/10/14	<1		
PES-0310-7B	Plummer ES	1st floor hallway adjacent to Classroom 125	3/10/14	<1		
PES-0310-8A	Plummer ES	1st floor inside Classroom 127 Pre-K	3/10/14	<1		
PES-0310-8B	Plummer ES	1st floor inside Classroom 127 Pre-K	3/10/14	<1		
PES-0310-9A	Plummer ES	1st floor inside Classroom 116	3/10/14	<1		
PES-0310-9B	Plummer ES	1st floor inside Classroom 116	3/10/14	<1		
PES-0310-10A	Plummer ES	1st floor inside Classroom 109	3/10/14	<1		
PES-0310-10B	Plummer ES	1st floor inside Classroom 109	3/10/14	<1		
PES-0310-11A	Plummer ES	Ground floor hallway adjacent to Classroom 39	3/10/14	<1		
PES-0310-11B	Plummer ES	Ground floor hallway adjacent to Classroom 39	3/10/14	<1		
PES-0310-12A	Plummer ES	Ground floor hallway adjacent to Library	3/10/14	<1		
PES-0310-12B	Plummer ES	Ground floor hallway adjacent to Library	3/10/14	<1		
PES-0310-13A	Plummer ES	Ground floor hallway adjacent to Main Office	3/10/14	<1		
PES-0310-13B	Plummer ES	Ground floor hallway adjacent to Main Office	3/10/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
PES-0414-1A	Powell ES	1st floor inside Multi-Purpose Room	4/14/14	<1		
PES-0414-1B	Powell ES	1st floor inside Multi-Purpose Room	4/14/14	<1		
PES-0414-2A	Powell ES	2nd floor hallway adjacent to Classroom 203	4/14/14	<1		
PES-0414-2B	Powell ES	2nd floor hallway adjacent to Classroom 203	4/14/14	<1		
PES-0414-3A	Powell ES	2nd floor hallway adjacent to Classroom 206 (high)	4/14/14	<1		
PES-0414-3B	Powell ES	2nd floor hallway adjacent to Classroom 206 (high)	4/14/14	<1		
PES-0414-4A	Powell ES	2nd floor hallway adjacent to Classroom 206 (low)	4/14/14	<1		
PES-0414-4B	Powell ES	2nd floor hallway adjacent to Classroom 206 (low)	4/14/14	<1		
PES-0414-5A	Powell ES	2nd floor hallway adjacent to Classroom 201 (high)	4/14/14	<1		
PES-0414-5B	Powell ES	2nd floor hallway adjacent to Classroom 201 (high)	4/14/14	<1		
PES-0414-6A	Powell ES	2nd floor hallway adjacent to Classroom 201 (low)	4/14/14	<1		
PES-0414-6B	Powell ES	2nd floor hallway adjacent to Classroom 201 (low)	4/14/14	<1		
PES-0414-7A	Powell ES	2nd floor inside Classroom 201	4/14/14	<1		
PES-0414-7B	Powell ES	2nd floor inside Classroom 201	4/14/14	<1		
PES-0414-8A	Powell ES	2nd floor inside Classroom 202	4/14/14	<1		
PES-0414-8B	Powell ES	2nd floor inside Classroom 202	4/14/14	<1		
PES-0414-9A	Powell ES	2nd floor inside Classroom 206	4/14/14	<1		
PES-0414-9B	Powell ES	2nd floor inside Classroom 206	4/14/14	<1		
PES-0414-10A	Powell ES	1st floor inside Classroom 102	4/14/14	<1		
PES-0414-10B	Powell ES	1st floor inside Classroom 102	4/14/14	<1		
PES-0414-11A	Powell ES	1st floor hallway adjacent to Classroom 101 (high)	4/14/14	<1		
PES-0414-11B	Powell ES	1st floor hallway adjacent to Classroom 101 (high)	4/14/14	<1		
PES-0414-12A	Powell ES	1st floor hallway adjacent to Classroom 101 (low)	4/14/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SWS-0519-4B	School Within a School	3rd floor hallway across from Classroom 308	5/19/14	1.7		
SWS-0519-5A	School Within a School	2nd floor hallway across from Classroom 206	5/19/14	<1		
SWS-0519-5B	School Within a School	2nd floor hallway across from Classroom 206	5/19/14	<1		
SWS-0519-6A	School Within a School	2nd floor hallway adjacent to Classroom 203	5/19/14	<1		
SWS-0519-6B	School Within a School	2nd floor hallway adjacent to Classroom 203	5/19/14	<1		
SWS-0519-7A	School Within a School	1st floor hallway adjacent to Classroom 103	5/19/14	<1		
SWS-0519-7B	School Within a School	1st floor hallway adjacent to Classroom 103	5/19/14	<1		
SWS-0519-8A	School Within a School	1st floor hallway adjacent to Custodian Closet	5/19/14	<1		
SWS-0519-8B	School Within a School	1st floor hallway adjacent to Custodian Closet	5/19/14	<1		
SWS-0519-9A	School Within a School	Basement floor inside Cafeteria	5/19/14	<1		
SWS-0519-9B	School Within a School	Basement floor inside Cafeteria	5/19/14	1.8		
SWS-0519-10A	School Within a School	Basement floor hallway adjacent to Custodian Closet	5/19/14	<1		
SWS-0519-10B	School Within a School	Basement floor hallway adjacent to Custodian Closet	5/19/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
466-7914-1A	School Without Walls HS	3rd floor near Room 307 (upper)	7/9/14	<1		
466-7914-2B	School Without Walls HS	3rd floor near Room 307 (upper)	7/9/14	<1		
466-7914-3A	School Without Walls HS	3rd floor near Room 307 (lower)	7/9/14	<1		
466-7914-4B	School Without Walls HS	3rd floor near Room 307 (lower)	7/9/14	<1		
466-7914-5A	School Without Walls HS	2nd floor near Room 207 (upper)	7/9/14	<1		
466-7914-6B	School Without Walls HS	2nd floor near Room 207 (upper)	7/9/14	<1		
466-7914-7A	School Without Walls HS	2nd floor near Room 207 (lower)	7/9/14	<1		
466-7914-8B	School Without Walls HS	2nd floor near Room 207 (lower)	7/9/14	<1		
466-7914-9A	School Without Walls HS	1st floor near Room 107 (upper)	7/9/14	<1		
466-7914-10B	School Without Walls HS	1st floor near Room 107 (upper)	7/9/14	<1		
466-7914-11A	School Without Walls HS	1st floor near Room 107 (lower)	7/9/14	<1		
466-7914-12B	School Without Walls HS	1st floor near Room 107 (lower)	7/9/14	<1		
466-7914-13B	School Without Walls HS	Basement near Room 07 (upper)	7/9/14	<1		
466-7914-14B	School Without Walls HS	Basement near Room 07 (upper)	7/9/14	<1		
466-7914-15A	School Without Walls HS	Basement near Room 07 (lower)	7/9/14	<1		
466-7914-16B	School Without Walls HS	Basement near Room 07 (lower)	7/9/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SES-0207-1A	Seaton ES	3rd floor hallway adjacent to Girl's Room	2/7/14	1.7		
SES-0207-1B	Seaton ES	3rd floor hallway adjacent to Girl's Room	2/7/14	1		
SES-0207-2A	Seaton ES	3rd floor hallway adjacent to Janitor's Closet 306	2/7/14	1.1		
SES-0207-2B	Seaton ES	3rd floor hallway adjacent to Janitor's Closet 306	2/7/14	<1		
SES-0207-3A	Seaton ES	3rd floor inside Classroom 307	2/7/14	2.2		
SES-0207-3B	Seaton ES	3rd floor inside Classroom 307	2/7/14	<1		
SES-0207-4A	Seaton ES	2nd floor hallway adjacent to Janitor's Closet 206	2/7/14	<1		
SES-0207-4B	Seaton ES	2nd floor hallway adjacent to Janitor's Closet 206	2/7/14	<1		
SES-0207-5A	Seaton ES	2nd floor hallway adjacent to Girl's Room	2/7/14	<1		
SES-0207-5B	Seaton ES	2nd floor hallway adjacent to Girl's Room	2/7/14	<1		
SES-0207-6A	Seaton ES	3rd floor inside Classroom 309	2/7/14	<1		
SES-0207-6B	Seaton ES	3rd floor inside Classroom 309	2/7/14	<1		
SES-0207-7A	Seaton ES	1st floor hallway adjacent to Girl's room	2/7/14	1		
SES-0207-7B	Seaton ES	1st floor hallway adjacent to Girl's room	2/7/14	<1		
SES-0207-8A	Seaton ES	1st floor hallway adjacent to Janitor's Closet 106	2/7/14	5.2		
SES-0207-8B	Seaton ES	Basement floor inside Dining Area B11 (high)	2/7/14	<1		
SES-0207-9A	Seaton ES	1st floor inside Classroom 109	2/7/14	<1		
SES-0207-9B	Seaton ES	1st floor inside Classroom 109	2/7/14	<1		
SES-0207-10A	Seaton ES	1st floor inside Classroom 111	2/7/14	<1		
SES-0207-10B	Seaton ES	1st floor inside Classroom 111	2/7/14	<1		
SES-0207-11A	Seaton ES	1st floor inside Multi-Purpose Room	2/7/14	<1		
SES-0207-11B	Seaton ES	1st floor inside Multi-Purpose Room	2/7/14	<1		
SES-0207-12A	Seaton ES	1st floor inside Classroom 122	2/7/14	<1		
SES-0207-12B	Seaton ES	1st floor inside Classroom 122	2/7/14	<1		
SES-0207-13A	Seaton ES	1st floor inside Classroom 125	2/7/14	<1		
SES-0207-13B	Seaton ES	1st floor inside Classroom 125	2/7/14	<1		
SES-0207-14A	Seaton ES	1st floor inside Classroom 127	2/7/14	<1		
SES-0207-14B	Seaton ES	1st floor inside Classroom 127	2/7/14	<1		
SES-0207-15A	Seaton ES	1st floor inside Classroom 124	2/7/14	<1		
SES-0207-15B	Seaton ES	1st floor inside Classroom 124	2/7/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SES-0305-1A	Shadd ES	2nd floor hallway adjacent to Classroom 211	3/5/14	<1		
SES-0305-1B	Shadd ES	2nd floor hallway adjacent to Classroom 211	3/5/14	<1		
SES-0305-2A	Shadd ES	2nd floor hallway adjacent to Classroom 206	3/5/14	<1		
SES-0305-2B	Shadd ES	2nd floor hallway adjacent to Classroom 206	3/5/14	<1		
SES-0305-3A	Shadd ES	1st floor hallway adjacent to Classroom 109	3/5/14	<1		
SES-0305-3B	Shadd ES	1st floor hallway adjacent to Classroom 109	3/5/14	<1		
SES-0305-4A	Shadd ES	1st floor hallway across from Men's Locker Room	3/5/14	<1		
SES-0305-4B	Shadd ES	1st floor hallway across from Main Office	3/5/14	<1		
SES-0305-5A	Shadd ES	Ground floor hallway across from Lunch Room	3/5/14	<1		
SES-0305-5B	Shadd ES	Ground floor hallway across from Lunch Room	3/5/14	<1		
SES-0305-6A	Shadd ES	Ground floor hallway across from Classroom 108	3/5/14	<1		
SES-0305-6B	Shadd ES	Ground floor hallway across from Classroom 108	3/5/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SH-0505-1A	Sharpe Health School	1st floor hallway adjacent to Classroom 104	5/5/14	<1		
SH-0505-1B	Sharpe Health School	1st floor hallway adjacent to Classroom 104	5/5/14	<1		
SH-0505-2A	Sharpe Health School	1st floor hallway across from Men's Locker Room	5/5/14	<1		
SH-0505-2B	Sharpe Health School	1st floor hallway across from Men's Locker Room	5/5/14	<1		
SH-0505-3A	Sharpe Health School	1st floor hallway adjacent to Classroom 108	5/5/14	<1		
SH-0505-3B	Sharpe Health School	1st floor hallway adjacent to Classroom 108	5/5/14	<1		
SH-0505-4A	Sharpe Health School	1st floor hallway across from Pool Room	5/5/14	<1		
SH-0505-4B	Sharpe Health School	1st floor hallway across from Pool Room	5/5/14	<1		
SH-0505-5A	Sharpe Health School	1st floor inside Dining Room	5/5/14	<1		
SH-0505-5B	Sharpe Health School	1st floor inside Dining Room	5/5/14	<1		
SH-0505-6A	Sharpe Health School	1st floor hallway across from Dining Room	5/5/14	<1		
SH-0505-6B	Sharpe Health School	1st floor hallway across from Dining Room	5/5/14	<1		
SH-0505-7A	Sharpe Health School	1st floor hallway adjacent to Classroom 207	5/5/14	<1		
SH-0505-7B	Sharpe Health School	1st floor hallway adjacent to Classroom 207	5/5/14	<1		
SH-0505-8A	Sharpe Health School	1st floor hallway across from Classroom 202	5/5/14	<1		
SH-0505-8B	Sharpe Health School	1st floor hallway across from Classroom 202	5/5/14	<1		
SH-0505-9A	Sharpe Health School	1st floor hallway across from Kitchen	5/5/14	<1		
SH-0505-9B	Sharpe Health School	1st floor hallway across from Kitchen	5/5/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SES-0407-1A	Shepherd ES	2nd floor hallway across from Classroom 214 (high)	4/7/14	<1		
SES-0407-1B	Shepherd ES	2nd floor hallway across from Classroom 214 (high)	4/7/14	<1		
SES-0407-2A	Shepherd ES	2nd floor hallway across from Classroom 214 (low)	4/7/14	<1		
SES-0407-2B	Shepherd ES	2nd floor hallway across from Classroom 214 (low)	4/7/14	<1		
SES-0407-3A	Shepherd ES	2nd floor hallway across from Classroom 220 (high)	4/7/14	<1		
SES-0407-3B	Shepherd ES	2nd floor hallway across from Classroom 220 (high)	4/7/14	<1		
SES-0407-4A	Shepherd ES	2nd floor hallway across from Classroom 220 (low)	4/7/14	<1		
SES-0407-4B	Shepherd ES	2nd floor hallway across from Classroom 220 (low)	4/7/14	<1		
SES-0407-5A	Shepherd ES	1st floor hallway adjacent to Counselor's Office 133	4/7/14	<1		
SES-0407-5B	Shepherd ES	1st floor hallway adjacent to Counselor's Office 133	4/7/14	<1		
SES-0407-6A	Shepherd ES	1st floor hallway across from Classroom A104	4/7/14	<1		
SES-0407-6B	Shepherd ES	1st floor hallway across from Classroom A104	4/7/14	<1		
SES-0407-7A	Shepherd ES	1st floor hallway adjacent to Classroom A103 Pre-K	4/7/14	<1		
SES-0407-7B	Shepherd ES	1st floor hallway adjacent to Classroom A103 Pre-K	4/7/14	<1		
SES-0407-8A	Shepherd ES	1st floor inside Classroom A101 Kindergarten	4/7/14	<1		
SES-0407-8B	Shepherd ES	1st floor inside Classroom A101 Kindergarten	4/7/14	<1		
SES-0407-9A	Shepherd ES	1st floor inside Classroom 106 Pre-K	4/7/14	<1		
SES-0407-9B	Shepherd ES	1st floor inside Classroom 106 Pre-K	4/7/14	<1		
SES-0407-10A	Shepherd ES	Ground floor inside Cafeteria	4/7/14	<1		
SES-0407-10B	Shepherd ES	Ground floor inside Cafeteria	4/7/14	<1		
SES-0407-11A	Shepherd ES	Ground floor hallway across from Classroom AG04 (high)	4/7/14	<1		
SES-0407-11B	Shepherd ES	Ground floor hallway across from Classroom AG04 (high)	4/7/14	<1		
SES-0407-12A	Shepherd ES	Ground floor hallway across from Classroom AG04 (low)	4/7/14	<1		
SES-0407-12B	Shepherd ES	Ground floor hallway across from Classroom AG04 (low)	4/7/14	1.1		
SES-0407-13A	Shepherd ES	1st floor inside Classroom A102	4/7/14	<1		
SES-0407-13B	Shepherd ES	1st floor inside Classroom A102	4/7/14	<1		
SES-0407-14A	Shepherd ES	1st floor inside Classroom A103	4/7/14	<1		
SES-0407-14B	Shepherd ES	1st floor inside Classroom A103	4/7/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
SES-0320-1A	Simon ES	3rd floor hallway adjacent to Janitor's Closet 309	3/20/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SES-0320-1B	Simon ES	3rd floor hallway adjacent to Janitor's Closet 309	3/20/14	<1		
SES-0320-2A	Simon ES	3rd floor hallway adjacent to Storage Room 305	3/20/14	<1		
SES-0320-2B	Simon ES	3rd floor hallway adjacent to Storage Room 305	3/20/14	<1		
SES-0320-3A	Simon ES	2nd floor hallway adjacent to Janitor's Closet 205	3/20/14	1.1		
SES-0320-3B	Simon ES	2nd floor hallway adjacent to Janitor's Closet 205	3/20/14	1		
SES-0320-4A	Simon ES	2nd floor hallway adjacent to Janitor's Closet 211	3/20/14	<1		
SES-0320-4B	Simon ES	2nd floor hallway adjacent to Janitor's Closet 211	3/20/14	1.7		
SES-0320-5A	Simon ES	1st floor hallway adjacent to Janitor's Closet 116	3/20/14	<1		
SES-0320-5B	Simon ES	1st floor hallway adjacent to Janitor's Closet 116	3/20/14	<1		
SES-0320-6A	Simon ES	1st floor hallway adjacent to Storage Room 105	3/20/14	<1		
SES-0320-6B	Simon ES	1st floor hallway adjacent to Storage Room 105	3/20/14	<1		
SES-0320-7A	Simon ES	Ground floor hallway adjacent to Teacher's Lounge 003	3/20/14	<1		
SES-0320-7B	Simon ES	Ground floor hallway adjacent to Teacher's Lounge 003	3/20/14	<1		
SES-0320-8A	Simon ES	Ground floor hallway adjacent to Health Suite 013	3/20/14	<1		
SES-0320-8B	Simon ES	Ground floor hallway adjacent to Health Suite 013	3/20/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
SES-0124-1A	Smothers ES	3rd floor hallway adjacent to Classroom 301	1/24/14	<1		
SES-0124-1B	Smothers ES	3rd floor hallway adjacent to Classroom 301	1/24/14	<1		
SES-0124-2A	Smothers ES	3rd floor hallway adjacent to Classroom 310	1/24/14	<1		
SES-0124-2B	Smothers ES	3rd floor hallway adjacent to Classroom 310	1/24/14	<1		
SES-0124-3A	Smothers ES	2nd floor hallway adjacent to Library 212	1/24/14	<1		
SES-0124-3B	Smothers ES	2nd floor hallway adjacent to Library 212	1/24/14	<1		
SES-0124-4A	Smothers ES	2nd floor hallway adjacent to Art Room 201	1/24/14	<1		
SES-0124-4B	Smothers ES	2nd floor hallway adjacent to Art Room 201	1/24/14	<1		
SES-0124-5A	Smothers ES	1st floor hallway adjacent to Classroom 104	1/24/14	<1		
SES-0124-5B	Smothers ES	1st floor hallway adjacent to Classroom 104	1/24/14	<1		
SES-0124-6A	Smothers ES	1st floor hallway adjacent to Classroom 111	1/24/14	<1		
SES-0124-6B	Smothers ES	1st floor hallway adjacent to Classroom 111	1/24/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
SMS-0618-1A	Sousa MS	1st floor inside Science Room A109 (Window side, left) (1)	6/18/14	12		Filter Installed.
SMS-0618-1B	Sousa MS	1st floor inside Science Room A109 (Window side, left) (1)	6/18/14	1.3		
SMS-0618-2A	Sousa MS	1st floor inside Science Room A109 (Window side, right) (2)	6/18/14	2		
SMS-0618-2B	Sousa MS	1st floor inside Science Room A109 (Window side, right) (2)	6/18/14	<1		
SMS-0618-3A	Sousa MS	1st floor inside Science Room A109 (other side, left) (3)	6/18/14	<1		
SMS-0618-3B	Sousa MS	1st floor inside Science Room A109 (other side, left) (3)	6/18/14	<1		
SMS-0618-4A	Sousa MS	1st floor inside Science Room A109 (other side, right) (4)	6/18/14	5.9		
SMS-0618-4B	Sousa MS	1st floor inside Science Room A109 (other side, right) (4)	6/18/14	<1		
SMS-0618-5A	Sousa MS	1st floor inside Science Room B104 (Window side, left) (1)	6/18/14	17		Filter Installed.
SMS-0618-5B	Sousa MS	1st floor inside Science Room B104 (Window side, left) (1)	6/18/14	<1		
SMS-0618-6A	Sousa MS	1st floor inside Science Room B104 (other side, from left) (2)	6/18/14	44		Filter Installed.
SMS-0618-6B	Sousa MS	1st floor inside Science Room B104 (other side, from left) (2)	6/18/14	1.3		
SMS-0618-7A	Sousa MS	1st floor inside Science Room B104 (3)	6/18/14	82		Filter Installed.
SMS-0618-7B	Sousa MS	1st floor inside Science Room B104 (3)	6/18/14	2.2		
SMS-0618-8A	Sousa MS	1st floor inside Science Room B104 (4)	6/18/14	53		Filter Installed.
SMS-0618-8B	Sousa MS	1st floor inside Science Room B104 (4)	6/18/14	1.2		
SMS-0618-9A	Sousa MS	1st floor near Stage Door D100 (high)	6/18/14	<1		
SMS-0618-9B	Sousa MS	1st floor near Stage Door D100 (high)	6/18/14	<1		
SMS-0618-10A	Sousa MS	1st floor near Stage Door D100 (low)	6/18/14	<1		
SMS-0618-10B	Sousa MS	1st floor near Stage Door D100 (low)	6/18/14	<1		
SMS-0618-11A	Sousa MS	1st floor inside Gym inside Boy's Locker Room (high)	6/18/14	<1		
SMS-0618-11B	Sousa MS	1st floor inside Gym inside Boy's Locker Room (high)	6/18/14	<1		
SMS-0618-12A	Sousa MS	1st floor inside Gym inside Boy's Locker Room (low)	6/18/14	<1		
SMS-0618-12B	Sousa MS	1st floor inside Gym inside Boy's Locker Room (low)	6/18/14	<1		
SMS-0618-13A	Sousa MS	1st floor inside Gym inside Girl's Locker Room (high)	6/18/14	<1		
SMS-0618-13B	Sousa MS	1st floor inside Gym inside Girl's Locker Room (high)	6/18/14	<1		
SMS-0618-14A	Sousa MS	1st floor inside Gym inside Girl's Locker Room (low)	6/18/14	<1		
SMS-0618-14B	Sousa MS	1st floor inside Gym inside Girl's Locker Room (high)	6/18/14	<1		
SMS-0618-15A	Sousa MS	2nd floor inside Science Room B204 (Window side, left) (1)	6/18/14	79		Filter Installed.
SMS-0618-15B	Sousa MS	2nd floor inside Science Room B204 (Window side, left) (1)	6/18/14	3.8		
SMS-0618-16A	Sousa MS	2nd floor inside Science Room B204 (Window side, right) (2)	6/18/14	79		Filter Installed.
SMS-0618-16B	Sousa MS	2nd floor inside Science Room B204 (Window side, right) (2)	6/18/14	8.3		
SMS-0618-17A	Sousa MS	2nd floor inside Science Room B204 (other side, from left) (3)	6/18/14	68		Filter Installed.
SMS-0618-17B	Sousa MS	2nd floor inside Science Room B204 (other side, from left) (3)	6/18/14	2.1		
SMS-0618-18A	Sousa MS	2nd floor inside Science Room B204 (4)	6/18/14	41		Filter Installed.
SMS-0618-18B	Sousa MS	2nd floor inside Science Room B204 (4)	6/18/14	2		
SMS-0618-19A	Sousa MS	2nd floor inside Science Room B204 (5)	6/18/14	33		Filter Installed.
SMS-0618-19B	Sousa MS	2nd floor inside Science Room B204 (5)	6/18/14	1.5		
SMS-0618-20A	Sousa MS	2nd floor inside Science Room B204 (6)	6/18/14	20		Filter Installed.
SMS-0618-20B	Sousa MS	2nd floor inside Science Room B204 (6)	6/18/14	1		
SMS-0618-21A	Sousa MS	2nd floor inside Science Room A209 (Window side, left) (1)	6/18/14	25		Filter Installed.
SMS-0618-21B	Sousa MS	2nd floor inside Science Room A209 (Window side, left) (1)	6/18/14	4		
SMS-0618-22A	Sousa MS	2nd floor inside Science Room A209 (Window side, right) (2)	6/18/14	18		Filter Installed.
SMS-0618-22B	Sousa MS	2nd floor inside Science Room A209 (Window side, right) (2)	6/18/14	1.1		
SMS-0618-23A	Sousa MS	2nd floor inside Science Room A209 (other side, from left) (3)	6/18/14	4		
SMS-0618-23B	Sousa MS	2nd floor inside Science Room A209 (other side, from left) (3)	6/18/14	1.1		
SMS-0618-24A	Sousa MS	2nd floor inside Science Room A209 (4)	6/18/14	60		Filter Installed.
SMS-0618-24B	Sousa MS	2nd floor inside Science Room A209 (4)	6/18/14	3.3		
SMS-0618-25A	Sousa MS	2nd floor inside Science Room A209 (5)	6/18/14	2		
SMS-0618-25B	Sousa MS	2nd floor inside Science Room A209 (5)	6/18/14	<1		
SMS-0618-26A	Sousa MS	3rd floor hallway adjacent to Classroom C 301	6/18/14	<1		
SMS-0618-26B	Sousa MS	3rd floor hallway adjacent to Classroom C 301	6/18/14	<1		
SMS-0618-27A	Sousa MS	3rd floor inside Science Room B304 (Window side, left) (1)	6/18/14	22		Filter Installed.
SMS-0618-27B	Sousa MS	3rd floor inside Science Room B304 (Window side, left) (1)	6/18/14	1.6		
SMS-0618-28A	Sousa MS	3rd floor inside Science Room B304 (Window side, right) (2)	6/18/14	20		Filter Installed.
SMS-0618-28B	Sousa MS	3rd floor inside Science Room B304 (Window side, right) (2)	6/18/14	1.6		
SMS-0618-29A	Sousa MS	3rd floor inside Science Room B304 (other side, from left) (3)	6/18/14	6.7		Filter Installed.
SMS-0618-29B	Sousa MS	3rd floor inside Science Room B304 (other side, from left) (3)	6/18/14	<1		
SMS-0618-30A	Sousa MS	3rd floor inside Science Room B304 (3)	6/18/14	4.8		
SMS-0618-30B	Sousa MS	3rd floor inside Science Room B304 (3)	6/18/14	1.2		
SMS-0618-31A	Sousa MS	3rd floor inside Science Room B304 (4)	6/18/14	9.7		Filter Installed.
SMS-0618-31B	Sousa MS	3rd floor inside Science Room B304 (4)	6/18/14	2.9		
SMS-0618-32A	Sousa MS	3rd floor hallway adjacent to Classroom A301 (high)	6/18/14	26		Filter Installed.
SMS-0618-32B	Sousa MS	3rd floor hallway adjacent to Classroom A301 (high)	6/18/14	3.5		
SMS-0618-33A	Sousa MS	3rd floor hallway adjacent to Classroom A301 (low)	6/18/14	<1		
SMS-0618-33B	Sousa MS	3rd floor hallway adjacent to Classroom A301 (low)	6/18/14	<1		
SMS-0618-34A	Sousa MS	3rd floor inside Science Room A309 (Window side, left) (1)	6/18/14	<1		
SMS-0618-34B	Sousa MS	3rd floor inside Science Room A309 (Window side, left) (1)	6/18/14	<1		
SMS-0618-35A	Sousa MS	3rd floor inside Science Room A309 (Window side, right) (2)	6/18/14	4.8		
SMS-0618-35B	Sousa MS	3rd floor inside Science Room A309 (Window side, right) (2)	6/18/14	1.5		
SMS-0618-36A	Sousa MS	3rd floor inside Science Room A309 (other side, from left) (3)	6/18/14	6.5		Filter Installed.
SMS-0618-36B	Sousa MS	3rd floor inside Science Room A309 (other side, from left) (3)	6/18/14	1.1		
SMS-0618-37A	Sousa MS	3rd floor inside Science Room A309 (4)	6/18/14	8.7		Filter Installed.
SMS-0618-37B	Sousa MS	3rd floor inside Science Room A309 (4)	6/18/14	1.8		
SMS-0618-38A	Sousa MS	3rd floor inside Science Room A309 (5)	6/18/14	6		
SMS-0618-38B	Sousa MS	3rd floor inside Science Room A309 (5)	6/18/14	<1		
SMS-0618-39A	Sousa MS	2nd floor hallway adjacent to Classroom A201 (high)	6/18/14	6.5		Filter Installed.
SMS-0618-39B	Sousa MS	2nd floor hallway adjacent to Classroom A201 (high)	6/18/14	1.7		
SMS-0618-40A	Sousa MS	2nd floor hallway adjacent to Classroom A201 (low)	6/18/14	<1		
SMS-0618-40B	Sousa MS	2nd floor hallway adjacent to Classroom A201 (low)	6/18/14	<1		
SMS-0618-41A	Sousa MS	1st floor hallway adjacent to Classroom C101 (high)	6/18/14	<1		
SMS-0618-41B	Sousa MS	1st floor hallway adjacent to Classroom C101 (high)	6/18/14	<1		
SMS-0618-42A	Sousa MS	1st floor hallway adjacent to Classroom C101 (low)	6/18/14	<1		
SMS-0618-42B	Sousa MS	1st floor hallway adjacent to Classroom C101 (low)	6/18/14	<1		
SMS-0618-43A	Sousa MS	1st floor hallway adjacent to Classroom A101 (high)	6/18/14	<1		
SMS-0618-43B	Sousa MS	1st floor hallway adjacent to Classroom A101 (high)	6/18/14	<1		
SMS-0618-44A	Sousa MS	1st floor hallway adjacent to Classroom A101 (low)	6/18/14	<1		
SMS-0618-44B	Sousa MS	1st floor hallway adjacent to Classroom A101 (low)	6/18/14	<1		
SMS-0618-45A	Sousa MS	1st floor hallway adjacent to Health Suite B122 (high)	6/18/14	<1		
SMS-0618-45B	Sousa MS	1st floor hallway adjacent to Health Suite B122 (high)	6/18/14	<1		
SMS-0618-46A	Sousa MS	1st floor hallway adjacent to Health Suite B122 (low)	6/18/14	<1		
SMS-0618-46B	Sousa MS	1st floor hallway adjacent to Health Suite B122 (low)	6/18/14	<1		
				Percentage of Passed Samples		75.00%
				Percentage of Failed Samples		25.00%
	Spingarn SHS					
	Spingarn SHS					
	Spingarn SHS					
	Spingarn SHS					
	Spingarn SHS					

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TEC-0411-13B	Takoma EC	Inside Gym Bldg. adjacent to Boy's Locker Room	4/11/14	<1		
TEC-0411-14A	Takoma EC	Inside Gym Bldg. adjacent to Girl's Locker Room	4/11/14	<1		
TEC-0411-14B	Takoma EC	Inside Gym Bldg. adjacent to Girl's Locker Room	4/11/14	<1		
Percentage of Passed Samples						96.43%
Percentage of Failed Samples						3.57%
TES-0123-1A	Thomas ES	3rd floor hallway adjacent to Boy's Room (high)	1/23/14	<1		
TES-0123-1B	Thomas ES	3rd floor hallway adjacent to Boy's Room (high)	1/23/14	<1		
TES-0123-2A	Thomas ES	3rd floor hallway adjacent to Boy's Room (low)	1/23/14	<1		
TES-0123-2B	Thomas ES	3rd floor hallway adjacent to Boy's Room (low)	1/23/14	<1		
TES-0123-3A	Thomas ES	2nd floor hallway adjacent to Storage Room (high)	1/23/14	<1		
TES-0123-3B	Thomas ES	2nd floor hallway adjacent to Storage Room (high)	1/23/14	<1		
TES-0123-4A	Thomas ES	2nd floor hallway adjacent to Storage Room (low)	1/23/14	<1		
TES-0123-4B	Thomas ES	2nd floor hallway adjacent to Storage Room (low)	1/23/14	<1		
TES-0123-5A	Thomas ES	1st floor hallway adjacent to Boy's Room (high)	1/23/14	<1		
TES-0123-5B	Thomas ES	1st floor hallway adjacent to Boy's Room (high)	1/23/14	<1		
TES-0123-6A	Thomas ES	1st floor hallway adjacent to Boy's Room (low)	1/23/14	<1		
TES-0123-6B	Thomas ES	1st floor hallway adjacent to Boy's Room (low)	1/23/14	<1		
TES-0123-7A	Thomas ES	1st floor hallway adjacent to Storage Room (high)	1/23/14	<1		
TES-0123-7B	Thomas ES	1st floor hallway adjacent to Storage Room (high)	1/23/14	<1		
TES-0123-8A	Thomas ES	1st floor hallway adjacent to Storage Room (low)	1/23/14	<1		
TES-0123-8B	Thomas ES	1st floor hallway adjacent to Storage Room (low)	1/23/14	<1		
TES-0123-9A	Thomas ES	1st floor inside Cafeteria	1/23/14	<1		
TES-0123-9B	Thomas ES	1st floor inside Cafeteria	1/23/14	<1		
TES-0123-10A	Thomas ES	1st floor inside Auditorium	1/23/14	<1		
TES-0123-10B	Thomas ES	1st floor inside Auditorium	1/23/14	<1		
TES-0123-11A	Thomas ES	1st floor hallway across from Auditorium between Boy's and Girl's Rooms	1/23/14	<1		
TES-0123-11B	Thomas ES	1st floor hallway across from Auditorium between Boy's and Girl's Rooms	1/23/14	<1		
TES-0123-12A	Thomas ES	1st floor hallway near security desk and Main Office	1/23/14	<1		
TES-0123-12B	Thomas ES	1st floor hallway near security desk and Main Office	1/23/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
TES-0205-1A	Thomson ES	3rd floor hallway across from Electrical Room 322 (high)	2/5/14	<1		
TES-0205-1B	Thomson ES	3rd floor hallway across from Electrical Room 322 (high)	2/5/14	<1		
TES-0205-2A	Thomson ES	3rd floor hallway across from Electrical Room 322 (low)	2/5/14	<1		
TES-0205-2B	Thomson ES	3rd floor hallway across from Electrical Room 322 (low)	2/5/14	<1		
TES-0205-3A	Thomson ES	2nd floor hallway across from Electrical Room 227 (high)	2/5/14	<1		
TES-0205-3B	Thomson ES	2nd floor hallway across from Electrical Room 227 (high)	2/5/14	<1		
TES-0205-4A	Thomson ES	2nd floor hallway across from Electrical Room 227 (low)	2/5/14	<1		
TES-0205-4B	Thomson ES	2nd floor hallway across from Electrical Room 227 (low)	2/5/14	<1		
TES-0205-5A	Thomson ES	1st floor hallway adjacent to Storage Room 129 (high)	2/5/14	<1		
TES-0205-5B	Thomson ES	1st floor hallway adjacent to Storage Room 129 (high)	2/5/14	<1		
TES-0205-6A	Thomson ES	1st floor hallway adjacent to Storage Room 129 (low)	2/5/14	<1		
TES-0205-6B	Thomson ES	1st floor hallway adjacent to Storage Room 129 (low)	2/5/14	<1		
TES-0205-7A	Thomson ES	1st floor inside Classroom 123	2/5/14	<1		
TES-0205-7B	Thomson ES	1st floor inside Classroom 123	2/5/14	<1		
TES-0205-8A	Thomson ES	1st floor inside Classroom 124	2/5/14	<1		
TES-0205-8B	Thomson ES	1st floor inside Classroom 124	2/5/14	<1		
TES-0205-9A	Thomson ES	1st floor inside Classroom 127	2/5/14	<1		
TES-0205-9B	Thomson ES	1st floor inside Classroom 127	2/5/14	<1		
TES-0205-10A	Thomson ES	1st floor inside Classroom 126	2/5/14	<1		
TES-0205-10B	Thomson ES	1st floor inside Classroom 126	2/5/14	<1		
TES-0205-11A	Thomson ES	1st floor inside Classroom 112	2/5/14	<1		
TES-0205-11B	Thomson ES	1st floor inside Classroom 112	2/5/14	<1		
TES-0205-12A	Thomson ES	1st floor inside Classroom 113	2/5/14	<1		
TES-0205-12B	Thomson ES	1st floor inside Classroom 113	2/5/14	<1		
TES-0205-13A	Thomson ES	1st floor inside Classroom 114	2/5/14	<1		
TES-0205-13B	Thomson ES	1st floor inside Classroom 114	2/5/14	<1		
TES-0205-14A	Thomson ES	1st floor inside Classroom 115	2/5/14	<1		
TES-0205-14B	Thomson ES	1st floor inside Classroom 115	2/5/14	<1		
TES-0205-15A	Thomson ES	Basement inside Multi-Purpose Room (high)	2/5/14	<1		
TES-0205-15B	Thomson ES	Basement inside Multi-Purpose Room (high)	2/5/14	<1		
TES-0205-16A	Thomson ES	Basement inside Multi-Purpose Room (low)	2/5/14	<1		
TES-0205-16B	Thomson ES	Basement inside Multi-Purpose Room (low)	2/5/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
TES-0403-1A	Truesdell ES	3rd floor hallway adjacent to Roof Door	4/3/14	<1		
TES-0403-1B	Truesdell ES	3rd floor hallway adjacent to Roof Door	4/3/14	<1		
TES-0403-2A	Truesdell ES	3rd floor hallway adjacent to Classroom 300	4/3/14	<1		
TES-0403-2B	Truesdell ES	3rd floor hallway adjacent to Classroom 300	4/3/14	<1		
TES-0403-3A	Truesdell ES	2nd floor hallway adjacent to Classroom 200	4/3/14	<1		
TES-0403-3B	Truesdell ES	2nd floor hallway adjacent to Classroom 200	4/3/14	<1		
TES-0403-4A	Truesdell ES	2nd floor hallway adjacent to Classroom 212	4/3/14	<1		
TES-0403-4B	Truesdell ES	2nd floor hallway adjacent to Classroom 212	4/3/14	<1		
TES-0403-5A	Truesdell ES	1st floor hallway across from Library 117	4/3/14	<1		
TES-0403-5B	Truesdell ES	1st floor hallway across from Library 117	4/3/14	<1		
TES-0403-6A	Truesdell ES	1st floor hallway across from Art Room 126	4/3/14	<1		
TES-0403-6B	Truesdell ES	1st floor hallway across from Art Room 126	4/3/14	<1		
TES-0403-7A	Truesdell ES	2nd floor hallway adjacent to Classroom 227	4/3/14	<1		
TES-0403-7B	Truesdell ES	2nd floor hallway adjacent to Classroom 227	4/3/14	<1		
TES-0403-8A	Truesdell ES	2nd floor hallway adjacent to Classroom 218	4/3/14	<1		
TES-0403-8B	Truesdell ES	2nd floor hallway adjacent to Classroom 218	4/3/14	<1		
TES-0403-9A	Truesdell ES	1st floor inside Classroom 101 Pre-K	4/3/14	1.6		
TES-0403-9B	Truesdell ES	1st floor inside Classroom 101 Pre-K	4/3/14	<1		
TES-0403-10A	Truesdell ES	1st floor inside Classroom 100 Pre-K	4/3/14	<1		
TES-0403-10B	Truesdell ES	1st floor inside Classroom 100 Pre-K	4/3/14	<1		
TES-0403-11A	Truesdell ES	1st floor inside Classroom 114 Pre-School	4/3/14	<1		
TES-0403-11B	Truesdell ES	1st floor inside Classroom 114 Pre-School	4/3/14	<1		
TES-0403-12A	Truesdell ES	1st floor inside Classroom 115 Pre-School	4/3/14	<1		
TES-0403-12B	Truesdell ES	1st floor inside Classroom 115 Pre-School	4/3/14	<1		
TES-0403-13A	Truesdell ES	2nd floor inside Classroom 216	4/3/14	<1		
TES-0403-13B	Truesdell ES	2nd floor inside Classroom 216	4/3/14	<1		
TES-0403-14A	Truesdell ES	2nd floor inside Classroom 217	4/3/14	2		
TES-0403-14B	Truesdell ES	2nd floor inside Classroom 217	4/3/14	1.6		
TES-0403-15A	Truesdell ES	1st floor hallway across from Boy's and Girl's Rooms	4/3/14	<1		
TES-0403-15B	Truesdell ES	1st floor hallway across from Boy's and Girl's Rooms	4/3/14	<1		
TES-0403-16A	Truesdell ES	1st floor hallway across from Cafe Annex 103	4/3/14	<1		
TES-0403-16B	Truesdell ES	1st floor hallway across from Cafe Annex 103	4/3/14	<1		
TES-0403-17A	Truesdell ES	Basement floor inside Health Suite	4/3/14	1.6		
TES-0403-17B	Truesdell ES	Basement floor inside Health Suite	4/3/14	1		
TES-0403-18A	Truesdell ES	Basement floor hallway adjacent to Rm 012	4/3/14	<1		
TES-0403-18B	Truesdell ES	Basement floor hallway adjacent to Rm 012	4/3/14	<1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
TES-0206-1A	Tubman ES	3rd floor hallway across from Storage Room 301	2/6/14	<1		
TES-0206-1B	Tubman ES	3rd floor hallway across from Storage Room 301	2/6/14	<1		
TES-0206-2A	Tubman ES	3rd floor hallway adjacent to Classroom 306	2/6/14	<1		
TES-0206-2B	Tubman ES	3rd floor hallway adjacent to Classroom 306	2/6/14	<1		
TES-0206-3A	Tubman ES	3rd floor hallway across from Girl's Room	2/6/14	<1		
TES-0206-3B	Tubman ES	3rd floor hallway across from Girl's Room	2/6/14	<1		
TES-0206-4A	Tubman ES	2nd floor hallway across from Girl's Room	2/6/14	<1		
TES-0206-4B	Tubman ES	2nd floor hallway across from Girl's Room	2/6/14	<1		
TES-0206-5A	Tubman ES	2nd floor hallway across from Storage Room 201	2/6/14	<1		
TES-0206-5B	Tubman ES	2nd floor hallway across from Storage Room 201	2/6/14	<1		
TES-0206-6A	Tubman ES	1st floor hallway across from Storage Room 101	2/6/14	<1		
TES-0206-6B	Tubman ES	1st floor hallway across from Storage Room 101	2/6/14	<1		
TES-0206-7A	Tubman ES	1st floor inside Classroom 106	2/6/14	1.8		
TES-0206-7B	Tubman ES	1st floor inside Classroom 106	2/6/14	<1		
TES-0206-8A	Tubman ES	1st floor inside Classroom 108	2/6/14	<1		
TES-0206-8B	Tubman ES	1st floor inside Classroom 108	2/6/14	<1		
TES-0206-9A	Tubman ES	1st floor inside Classroom 110	2/6/14	<1		
TES-0206-9B	Tubman ES	1st floor inside Classroom 110	2/6/14	<1		
TES-0206-10A	Tubman ES	1st floor hallway adjacent to Classroom 110	2/6/14	<1		
TES-0206-10B	Tubman ES	1st floor hallway adjacent to Classroom 110	2/6/14	<1		
TES-0206-11A	Tubman ES	1st floor inside Classroom 114	2/6/14	<1		
TES-0206-11B	Tubman ES	1st floor inside Classroom 114	2/6/14	<1		
TES-0206-12A	Tubman ES	1st floor inside Classroom 115	2/6/14	<1		
TES-0206-12B	Tubman ES	1st floor inside Classroom 115	2/6/14	<1		
TES-0206-13A	Tubman ES	1st floor inside Classroom 113	2/6/14	<1		
TES-0206-13B	Tubman ES	1st floor inside Classroom 113	2/6/14	<1		
TES-0206-14A	Tubman ES	1st floor inside Classroom 111	2/6/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-0206-14B	Tubman ES	1st floor inside Classroom 111	2/6/14	<1		
TES-0206-15A	Tubman ES	1st floor inside Classroom 119 Art	2/6/14	<1		
TES-0206-15B	Tubman ES	1st floor inside Classroom 119 Art	2/6/14	<1		
TES-0206-16A	Tubman ES	1st floor inside Classroom 120 Pre-K	2/6/14	<1		
TES-0206-16B	Tubman ES	1st floor inside Classroom 120 Pre-K	2/6/14	<1		
TES-0206-17A	Tubman ES	1st floor inside Classroom 121	2/6/14	<1		
TES-0206-17B	Tubman ES	1st floor inside Classroom 121	2/6/14	<1		
TES-0206-18A	Tubman ES	1st floor hallway across from Multi-Purpose Room	2/6/14	<1		
TES-0206-18B	Tubman ES	1st floor hallway across from Multi-Purpose Room	2/6/14	1.1		
TES-0206-19A	Tubman ES	1st floor inside Multi-Purpose Room	2/6/14	<1		
TES-0206-19B	Tubman ES	1st floor inside Multi-Purpose Room	2/6/14	<1		
TES-0206-20A	Tubman ES	1st floor hallway adjacent to Room 132	2/6/14	<1		
TES-0206-20B	Tubman ES	1st floor hallway adjacent to Room 132	2/6/14	<1		
TES-0206-21A	Tubman ES	1st floor inside Health Suite	2/6/14	<1		
TES-0206-21B	Tubman ES	1st floor inside Health Suite	2/6/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
TES-0226-1A	Turner ES	3rd floor hallway adjacent to elevator (high)	2/26/14	<1		
TES-0226-1B	Turner ES	3rd floor hallway adjacent to elevator (high)	2/26/14	<1		
TES-0226-2A	Turner ES	3rd floor hallway adjacent to elevator (low)	2/26/14	<1		
TES-0226-2B	Turner ES	3rd floor hallway adjacent to elevator (low)	2/26/14	<1		
TES-0226-3A	Turner ES	3rd floor across from Classroom 310 (high)	2/26/14	<1		
TES-0226-3B	Turner ES	3rd floor across from Classroom 310 (high)	2/26/14	<1		
TES-0226-4A	Turner ES	3rd floor across from Classroom 310 (low)	2/26/14	<1		
TES-0226-4B	Turner ES	3rd floor across from Classroom 310 (low)	2/26/14	<1		
TES-0226-5A	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (high)	2/26/14	<1		
TES-0226-5B	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (high)	2/26/14	<1		
TES-0226-6A	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (low)	2/26/14	<1		
TES-0226-6B	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (low)	2/26/14	<1		
TES-0226-7A	Turner ES	3rd floor hallway adjacent to Girl's Room (high)	2/26/14	<1		
TES-0226-7B	Turner ES	3rd floor hallway adjacent to Girl's Room (high)	2/26/14		32	Filter Installed.
TES-0226-8A	Turner ES	3rd floor hallway adjacent to Girl's Room (low)	2/26/14		14	Filter Installed.
TES-0226-8B	Turner ES	3rd floor hallway adjacent to Girl's Room (low)	2/26/14	<1		
TES-0226-9A	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (high)	2/26/14	<1		
TES-0226-9B	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (high)	2/26/14	<1		
TES-0226-10A	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (low)	2/26/14	<1		
TES-0226-10B	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (low)	2/26/14	<1		
TES-0226-11A	Turner ES	2nd floor hallway at entrance to Library (high)	2/26/14		8.9	Filter Installed.
TES-0226-11B	Turner ES	2nd floor hallway at entrance to Library (high)	2/26/14	<1		
TES-0226-12A	Turner ES	2nd floor hallway at entrance to Library (low)	2/26/14	<1		
TES-0226-12B	Turner ES	2nd floor hallway at entrance to Library (low)	2/26/14	<1		
TES-0226-13A	Turner ES	2nd floor hallway adjacent to Girl's Room (high)	2/26/14	<1		
TES-0226-13B	Turner ES	2nd floor hallway adjacent to Girl's Room (high)	2/26/14	<1		
TES-0226-14A	Turner ES	2nd floor hallway adjacent to Girl's Room (low)	2/26/14	<1		
TES-0226-14B	Turner ES	2nd floor hallway adjacent to Girl's Room (low)	2/26/14		8	Filter Installed.
TES-0226-15A	Turner ES	2nd floor hallway adjacent to Elevator (high)	2/26/14	<1		
TES-0226-15B	Turner ES	2nd floor hallway adjacent to Elevator (high)	2/26/14	<1		
TES-0226-16A	Turner ES	2nd floor hallway adjacent to Elevator (low)	2/26/14	<1		
TES-0226-16B	Turner ES	2nd floor hallway adjacent to Elevator (low)	2/26/14	<1		
TES-0226-17A	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (high)	2/26/14	<1		
TES-0226-17B	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (high)	2/26/14	<1		
TES-0226-18A	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (low)	2/26/14	<1		
TES-0226-18B	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (low)	2/26/14	<1		
TES-0226-19A	Turner ES	1st floor hallway at entrance to Classroom 109 Kindergarten (high)	2/26/14	<1		
TES-0226-19B	Turner ES	1st floor hallway at entrance to Classroom 109 Kindergarten (high)	2/26/14	<1		
TES-0226-20A	Turner ES	1st floor hallway at entrance to Classroom 109 Kindergarten (low)	2/26/14	<1		
TES-0226-20B	Turner ES	1st floor hallway at entrance to Classroom 109 Kindergarten (low)	2/26/14	<1		
TES-0226-21A	Turner ES	1st floor hallway adjacent to Elevator (high)	2/26/14	<1		
TES-0226-21B	Turner ES	1st floor hallway adjacent to Elevator (high)	2/26/14	<1		
TES-0226-22A	Turner ES	1st floor hallway adjacent to Elevator (low)	2/26/14	<1		
TES-0226-22B	Turner ES	1st floor hallway adjacent to Elevator (low)	2/26/14	<1		
TES-0226-23A	Turner ES	1st floor hallway across from Gym (high)	2/26/14	<1		
TES-0226-23B	Turner ES	1st floor hallway across from Gym (high)	2/26/14	<1		
TES-0226-24A	Turner ES	1st floor hallway across from Gym (low)	2/26/14	<1		
TES-0226-24B	Turner ES	1st floor hallway across from Gym (low)	2/26/14	<1		
TES-0226-25A	Turner ES	1st floor hallway across from Main Office (high)	2/26/14	<1		
TES-0226-25B	Turner ES	1st floor hallway across from Main Office (high)	2/26/14	<1		
TES-0226-26A	Turner ES	1st floor hallway across from Main Office (low)	2/26/14	<1		
TES-0226-26B	Turner ES	1st floor hallway across from Main Office (low)	2/26/14	<1		
TES-0226-27A	Turner ES	1st floor inside Classroom 117 Pre-K	2/26/14	2.3		
TES-0226-27B	Turner ES	1st floor inside Classroom 117 Pre-K	2/26/14	<1		
TES-0226-28A	Turner ES	1st floor inside Classroom 116 Pre-K	2/26/14		270	Filter Installed.
TES-0226-28B	Turner ES	1st floor inside Classroom 116 Pre-K	2/26/14		13	Filter Installed.
TES-0226-29A	Turner ES	1st floor inside Classroom 112 Pre-K	2/26/14	<1		
TES-0226-29B	Turner ES	1st floor inside Classroom 112 Pre-K	2/26/14	<1		
TES-0226-30A	Turner ES	1st floor inside Classroom 113 Pre-K	2/26/14	<1		
TES-0226-30B	Turner ES	1st floor inside Classroom 113 Pre-K	2/26/14	<1		
TES-0226-31A	Turner ES	1st floor inside Classroom 109 Kindergarten	2/26/14	<1		
TES-0226-31B	Turner ES	1st floor inside Classroom 109 Kindergarten	2/26/14	<1		
TES-0226-32A	Turner ES	1st floor inside Classroom 108 Kindergarten	2/26/14	<1		
TES-0226-32B	Turner ES	1st floor inside Classroom 108 Kindergarten	2/26/14	<1		
TES-0226-33A	Turner ES	1st floor inside Classroom 107 Kindergarten	2/26/14	<1		
TES-0226-33B	Turner ES	1st floor inside Classroom 107 Kindergarten	2/26/14		21	Filter Installed.
TES-0226-34A	Turner ES	1st floor inside Classroom 106 Kindergarten	2/26/14	<1		
TES-0226-34B	Turner ES	1st floor inside Classroom 106 Kindergarten	2/26/14	<1		
				Percentage of Passed Samples		89.71%
				Percentage of Failed Samples		10.29%
TES-0228-1A	Tyler ES	3rd floor hallway across from Girl's Room	2/28/14	<1		
TES-0228-1B	Tyler ES	3rd floor hallway across from Girl's Room	2/28/14	<1		
TES-0228-2A	Tyler ES	2nd floor hallway across from Girl's Room	2/28/14	<1		
TES-0228-2B	Tyler ES	2nd floor hallway across from Girl's Room	2/28/14	<1		
TES-0228-3A	Tyler ES	2nd floor hallway across from Boy's Room	2/28/14	<1		
TES-0228-3B	Tyler ES	2nd floor hallway across from Boy's Room	2/28/14	<1		
TES-0228-4A	Tyler ES	1st floor hallway across from Boy's Room (high)	2/28/14	<1		
TES-0228-4B	Tyler ES	1st floor hallway across from Boy's Room (high)	2/28/14	<1		
TES-0228-5A	Tyler ES	1st floor hallway across from Boy's Room (low)	2/28/14	<1		
TES-0228-5B	Tyler ES	1st floor hallway across from Boy's Room (low)	2/28/14	<1		
TES-0228-6A	Tyler ES	1st floor hallway adjacent to Classroom 142 (high)	2/28/14	<1		
TES-0228-6B	Tyler ES	1st floor hallway adjacent to Classroom 142 (high)	2/28/14	<1		
TES-0228-7A	Tyler ES	1st floor hallway adjacent to Classroom 142 (low)	2/28/14	<1		
TES-0228-7B	Tyler ES	1st floor hallway adjacent to Classroom 142 (low)	2/28/14	<1		
TES-0228-8A	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (high)	2/28/14	<1		
TES-0228-8B	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (high)	2/28/14	<1		
TES-0228-9A	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (low)	2/28/14	<1		
TES-0228-9B	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (low)	2/28/14	<1		
TES-0228-10A	Tyler ES	Basement floor inside Cafeteria	2/28/14	<1		
TES-0228-10B	Tyler ES	Basement floor inside Cafeteria	2/28/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
VES-0328-1A	Van Ness ES	3rd floor hallway across from Room 302	3/28/14	<1		
VES-0328-1B	Van Ness ES	3rd floor hallway across from Room 302	3/28/14	<1		
VES-0328-2A	Van Ness ES	2nd floor hallway across from Room 202	3/28/14	<1		
VES-0328-2B	Van Ness ES	2nd floor hallway across from Room 202	3/28/14	<1		
VES-0328-3A	Van Ness ES	2nd floor hallway adjacent to Room 209	3/28/14	<1		
VES-0328-3B	Van Ness ES	2nd floor hallway adjacent to Room 209	3/28/14	<1		
VES-0328-4A	Van Ness ES	1st floor hallway adjacent to Incinerator Room	3/28/14	<1		
VES-0328-4B	Van Ness ES	1st floor hallway adjacent to Incinerator Room	3/28/14	<1		
VES-0328-5A	Van Ness ES	Basement floor hallway near entrance to Auditorium	3/28/14	<1		
VES-0328-5B	Van Ness ES	Basement floor hallway near entrance to Auditorium	3/28/14	<1		
VES-0328-6A	Van Ness ES	Basement floor hallway adjacent to Men's Room	3/28/14	<1		
VES-0328-6B	Van Ness ES	Basement floor hallway adjacent to Men's Room	3/28/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
WJ-0530-1A	Walker Jones ES	1st floor hallway across from Classroom 108 (high)	5/30/14	<1		
WJ-0530-1B	Walker Jones ES	1st floor hallway across from Classroom 108 (high)	5/30/14	<1		
WJ-0530-2A	Walker Jones ES	1st floor hallway across from Classroom 108 (low)	5/30/14	<1		
WJ-0530-2B	Walker Jones ES	1st floor hallway across from Classroom 108 (low)	5/30/14	<1		
WJ-0530-3A	Walker Jones ES	1st floor inside Classroom 108	5/30/14	3.8		
WJ-0530-3B	Walker Jones ES	1st floor inside Classroom 108	5/30/14	1		
WJ-0530-4A	Walker Jones ES	1st floor inside Classroom 106	5/30/14	<1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WJ-0530-4B	Walker Jones ES	1st floor inside Classroom 106	5/30/14	<1		
WJ-0530-5A	Walker Jones ES	1st floor inside Classroom 105	5/30/14	1.7		
WJ-0530-5B	Walker Jones ES	1st floor inside Classroom 105	5/30/14	<1		
WJ-0530-6A	Walker Jones ES	1st floor inside Classroom 104	5/30/14	<1		
WJ-0530-6B	Walker Jones ES	1st floor inside Classroom 104	5/30/14	<1		
WJ-0530-7A	Walker Jones ES	1st floor inside Classroom 103	5/30/14	<1		
WJ-0530-7B	Walker Jones ES	1st floor inside Classroom 103	5/30/14	<1		
WJ-0530-8A	Walker Jones ES	1st floor inside Classroom 120	5/30/14	<1		
WJ-0530-8B	Walker Jones ES	1st floor inside Classroom 120	5/30/14	<1		
WJ-0530-9A	Walker Jones ES	1st floor inside Classroom 122	5/30/14	<1		
WJ-0530-9B	Walker Jones ES	1st floor inside Classroom 122	5/30/14	<1		
WJ-0530-10A	Walker Jones ES	1st floor inside Classroom 115	5/30/14	<1		
WJ-0530-10B	Walker Jones ES	1st floor inside Classroom 115	5/30/14	<1		
WJ-0530-11A	Walker Jones ES	1st floor inside Classroom 117	5/30/14	<1		
WJ-0530-11B	Walker Jones ES	1st floor inside Classroom 117	5/30/14	<1		
WJ-0530-12A	Walker Jones ES	1st floor inside Classroom 119	5/30/14	1.2		
WJ-0530-12B	Walker Jones ES	1st floor inside Classroom 119	5/30/14	1.3		
WJ-0530-13A	Walker Jones ES	1st floor inside Classroom 126	5/30/14	4		
WJ-0530-13B	Walker Jones ES	1st floor inside Classroom 126	5/30/14	1.8		
WJ-0530-14A	Walker Jones ES	1st floor inside Classroom 128	5/30/14	<1		
WJ-0530-14B	Walker Jones ES	1st floor inside Classroom 128	5/30/14	<1		
WJ-0530-15A	Walker Jones ES	3rd floor inside Teacher's Workroom 300	5/30/14	<1		
WJ-0530-15B	Walker Jones ES	3rd floor inside Teacher's Workroom 300	5/30/14	<1		
WJ-0530-16A	Walker Jones ES	3rd floor hallway across from Classroom 312 (high)	5/30/14	<1		
WJ-0530-16B	Walker Jones ES	3rd floor hallway across from Classroom 312 (high)	5/30/14	<1		
WJ-0530-17A	Walker Jones ES	3rd floor hallway across from Classroom 312 (low)	5/30/14	<1		
WJ-0530-17B	Walker Jones ES	3rd floor hallway across from Classroom 312 (low)	5/30/14	<1		
WJ-0530-18A	Walker Jones ES	3rd floor inside Classroom 320 (near window)	5/30/14	2.4		
WJ-0530-18B	Walker Jones ES	3rd floor inside Classroom 320 (near window)	5/30/14	<1		
WJ-0530-19A	Walker Jones ES	3rd floor inside Classroom 320 (1) (clockwise from left)	5/30/14	.3		
WJ-0530-19B	Walker Jones ES	3rd floor inside Classroom 320 (1)	5/30/14	<1		
WJ-0530-20A	Walker Jones ES	3rd floor inside Classroom 320 (2)	5/30/14	3.7		
WJ-0530-20B	Walker Jones ES	3rd floor inside Classroom 320 (2)	5/30/14	1.6		
WJ-0530-21A	Walker Jones ES	3rd floor inside Classroom 320 (3)	5/30/14	3.3		
WJ-0530-21B	Walker Jones ES	3rd floor inside Classroom 320 (3)	5/30/14	<1		
WJ-0530-22A	Walker Jones ES	2nd floor inside Teacher's Lounge 201	5/30/14	1.9		
WJ-0530-22B	Walker Jones ES	2nd floor inside Teacher's Lounge 201	5/30/14	<1		
WJ-0530-23A	Walker Jones ES	2nd floor inside Classroom 206	5/30/14	1.8		
WJ-0530-23B	Walker Jones ES	2nd floor inside Classroom 206	5/30/14	<1		
WJ-0530-24A	Walker Jones ES	2nd floor inside Classroom 208	5/30/14	1.3		
WJ-0530-24B	Walker Jones ES	2nd floor inside Classroom 208	5/30/14	<1		
WJ-0530-25A	Walker Jones ES	2nd floor inside Classroom 210	5/30/14	<1		
WJ-0530-25B	Walker Jones ES	2nd floor inside Classroom 210	5/30/14	<1		
WJ-0530-26A	Walker Jones ES	2nd floor inside Classroom 212	5/30/14	<1		
WJ-0530-26B	Walker Jones ES	2nd floor inside Classroom 212	5/30/14	<1		
WJ-0530-27A	Walker Jones ES	2nd floor hallway across from Classroom 212 (high)	5/30/14	<1		
WJ-0530-27B	Walker Jones ES	2nd floor hallway across from Classroom 212 (high)	5/30/14	<1		
WJ-0530-28A	Walker Jones ES	2nd floor hallway across from Classroom 212 (low)	5/30/14	<1		
WJ-0530-28B	Walker Jones ES	2nd floor hallway across from Classroom 212 (low)	5/30/14	<1		
WJ-0530-29A	Walker Jones ES	2nd floor inside Classroom 220	5/30/14	<1		
WJ-0530-29B	Walker Jones ES	2nd floor inside Classroom 220	5/30/14	<1		
WJ-0530-30A	Walker Jones ES	2nd floor inside Classroom 217	5/30/14	<1		
WJ-0530-30B	Walker Jones ES	2nd floor inside Classroom 217	5/30/14	<1		
WJ-0530-31A	Walker Jones ES	2nd floor inside Classroom 226	5/30/14	<1		
WJ-0530-31B	Walker Jones ES	2nd floor inside Classroom 226	5/30/14	<1		
WJ-0530-32A	Walker Jones ES	2nd floor inside Classroom 222	5/30/14	<1		
WJ-0530-32B	Walker Jones ES	2nd floor inside Classroom 222	5/30/14	<1		
WJ-0530-33A	Walker Jones ES	2nd floor inside Classroom 224	5/30/14	<1		
WJ-0530-33B	Walker Jones ES	2nd floor inside Classroom 224	5/30/14	<1		
WJ-0530-34A	Walker Jones ES	2nd floor inside Classroom 219	5/30/14	<1		
WJ-0530-34B	Walker Jones ES	2nd floor inside Classroom 219	5/30/14	<1		
WJ-0530-35A	Walker Jones ES	2nd floor inside Classroom 221	5/30/14	1.1		
WJ-0530-35B	Walker Jones ES	2nd floor inside Classroom 221	5/30/14	<1		
WJ-0530-36A	Walker Jones ES	2nd floor inside Classroom 228	5/30/14		41	Filter Installed.
WJ-0530-36B	Walker Jones ES	2nd floor inside Classroom 228	5/30/14	4.3		
WJ-0530-37A	Walker Jones ES	2nd floor inside Classroom 227 (left)	5/30/14		17	Filter Installed.
WJ-0530-37B	Walker Jones ES	2nd floor inside Classroom 227 (left)	5/30/14	2.9		
WJ-0530-38A	Walker Jones ES	2nd floor inside Classroom 227 (right)	5/30/14	2.5		
WJ-0530-38B	Walker Jones ES	2nd floor inside Classroom 227 (right)	5/30/14	<1		
WJ-0530-39A	Walker Jones ES	Lower Level inside Music Room 32	5/30/14	<1		
WJ-0530-39B	Walker Jones ES	Lower Level inside Music Room 32	5/30/14	<1		
WJ-0530-40A	Walker Jones ES	Lower Level hallway across from Music Room 32 (high)	5/30/14	<1		
WJ-0530-40B	Walker Jones ES	Lower Level hallway across from Music Room 32 (high)	5/30/14	<1		
WJ-0530-41A	Walker Jones ES	Lower Level hallway across from Music Room 32 (low)	5/30/14	<1		
WJ-0530-41B	Walker Jones ES	Lower Level hallway across from Music Room 32 (low)	5/30/14	<1		
WJ-0530-42A	Walker Jones ES	Lower Level inside Classroom 34	5/30/14	3		
WJ-0530-42B	Walker Jones ES	Lower Level inside Classroom 34	5/30/14	1.3		
WJ-0530-43A	Walker Jones ES	Lower Level inside Classroom 36	5/30/14		9.6	Filter Installed.
WJ-0530-43B	Walker Jones ES	Lower Level inside Classroom 36	5/30/14	3		
				Percentage of Passed Samples		96.51%
				Percentage of Failed Samples		3.49%
WES-0326-1A	Watkins ES	4th Floor Hall across from Elevator	3/26/14	<1		
WES-0326-1B	Watkins ES	4th Floor Hall across from Elevator	3/26/14	<1		
WES-0326-2A	Watkins ES	4th Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-2B	Watkins ES	4th Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-3A	Watkins ES	4th Floor Hall adjacent to Classroom 408	3/26/14	<1		
WES-0326-3B	Watkins ES	4th Floor Hall adjacent to Classroom 408	3/26/14	<1		
WES-0326-4A	Watkins ES	3rd Floor Hall adjacent to Classroom 307	3/26/14	<1		
WES-0326-4B	Watkins ES	3rd Floor Hall adjacent to Classroom 307	3/26/14	<1		
WES-0326-5A	Watkins ES	3rd Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-5B	Watkins ES	3rd Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-6A	Watkins ES	3rd Floor Hall across from elevator	3/26/14	<1		
WES-0326-6B	Watkins ES	3rd Floor Hall across from elevator	3/26/14	<1		
WES-0326-7A	Watkins ES	2nd Floor Hall across from elevator	3/26/14	<1		
WES-0326-7B	Watkins ES	2nd Floor Hall across from elevator	3/26/14	<1		
WES-0326-8A	Watkins ES	2nd Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-8B	Watkins ES	2nd Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-9A	Watkins ES	2nd Floor Hall adjacent to Rm 207 OT/PT	3/26/14	<1		
WES-0326-9B	Watkins ES	2nd Floor Hall adjacent to Rm 207 OT/PT	3/26/14	<1		
WES-0326-10A	Watkins ES	1st Floor Hall adjacent to Classroom 112	3/26/14	<1		
WES-0326-10B	Watkins ES	1st Floor Hall adjacent to Classroom 112	3/26/14	<1		
WES-0326-11A	Watkins ES	1st Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-11B	Watkins ES	1st Floor Hall adjacent to Custodian Closet	3/26/14	<1		
WES-0326-12A	Watkins ES	1st Floor Hall at entrance to Multi-Purpose Rm	3/26/14	<1		
WES-0326-12B	Watkins ES	1st Floor Hall at entrance to Multi-Purpose Rm	3/26/14	<1		
				Percentage of Passed Samples		100.00%
				Percentage of Failed Samples		0.00%
WES-0423-1A	West ES	Mezzanine level in Library	4/23/14	<1		
WES-0423-1B	West ES	Mezzanine level in Library	4/23/14	<1		
WES-0423-2A	West ES	2nd floor near Computer Lab (left)	4/23/14	<1		
WES-0423-2B	West ES	2nd floor near Computer Lab (left)	4/23/14	<1		
WES-0423-3A	West ES	2nd floor near Computer Lab (right)	4/23/14	1.1		
WES-0423-3B	West ES	2nd floor near Computer Lab (right)	4/23/14	<1		
WES-0423-4A	West ES	2nd floor near Book Storage Rm. (left)	4/23/14	<1		
WES-0423-4B	West ES	2nd floor near Book Storage Rm. (left)	4/23/14	<1		
WES-0423-5A	West ES	2nd floor near Book Storage Rm. (right)	4/23/14	<1		
WES-0423-5B	West ES	2nd floor near Book Storage Rm. (right)	4/23/14	<1		
WES-0423-6A	West ES	2nd floor hallway at entrance to Multi-Purpose Rm.	4/23/14	<1		
WES-0423-6B	West ES	2nd floor hallway at entrance to Multi-Purpose Rm.	4/23/14	<1		
WES-0423-7A	West ES	2nd floor inside Teacher's Lounge	4/23/14	<1		
WES-0423-7B	West ES	2nd floor inside Teacher's Lounge	4/23/14	<1		
WES-0423-8A	West ES	2nd floor inside Multi-Purpose Rm.	4/23/14	<1		
WES-0423-8B	West ES	2nd floor inside Multi-Purpose Rm.	4/23/14	<1		
WES-0423-9A	West ES	2nd floor outside Multi-Purpose Rm. near Boy's Room (high)	4/23/14	<1		
WES-0423-9B	West ES	2nd floor outside Multi-Purpose Rm. near Boy's Room (high)	4/23/14	<1		
WES-0423-10A	West ES	2nd floor outside Multi-Purpose Rm. near Boy's Room (low)	4/23/14	<1		
WES-0423-10B	West ES	2nd floor outside Multi-Purpose Rm. near Boy's Room (low)	4/23/14	<1		
WES-0423-11A	West ES	2nd floor inside Gym (high)	4/23/14	<1		
WES-0423-11B	West ES	2nd floor inside Gym (high)	4/23/14	<1		
WES-0423-12A	West ES	2nd floor inside Gym (low)	4/23/14	<1		

Sample Id	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
	Adams ES	Ground Floor, Inside Lunch Room	2/26/13	< 1		
	Adams ES	Ground Floor, Inside Lunch Room	2/26/13	< 1		
	Adams ES	Ground Floor, Next to Staircase	2/26/13	< 1		
	Adams ES	Ground Floor, Next to Staircase	2/26/13	< 1		
	Adams ES	Ground Floor, Next to Main Office	2/26/13	< 1		
	Adams ES	Ground Floor, Next to Main Office	2/26/13	< 1		
	Adams ES	Ground Floor, Inside Teachers' Lounge	2/26/13	< 1		
	Adams ES	Ground Floor, Inside Teachers' Lounge	2/26/13	< 1		
	Adams ES	2nd Floor Corridor, Next to Room 312	2/26/13	< 1		
	Adams ES	2nd Floor Corridor, Next to Room 312	2/26/13	< 1		
	Adams ES	2nd Floor Corridor, Next to Room 316	2/26/13	< 1		
	Adams ES	2nd Floor Corridor, Next to Room 316	2/26/13	< 1		
	Adams ES	1st Floor Corridor, Next to Room 206	2/26/13	< 1		
	Adams ES	1st Floor Corridor, Next to Room 206	2/26/13	< 1		
	Adams ES	1st Floor Corridor, Next to Room 210	2/26/13	< 1		
	Adams ES	1st Floor Corridor, Next to Room 210	2/26/13	< 1		
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
	Aiton ES	4th Floor Hallway, Opposite to Elevator	1/15/14			
	Aiton ES	4th Floor Hallway, Opposite to Elevator	1/15/14			
	Aiton ES	4th Floor Hallway, Opposite to Maintenance Storage Room	1/15/14			
	Aiton ES	4th Floor Hallway, Opposite to Maintenance Storage Room	1/15/14			
	Aiton ES	3rd Floor Hallway, Opposite to Storage Room	1/15/14			
	Aiton ES	3rd Floor Hallway, Opposite to Storage Room	1/15/14			
	Aiton ES	3rd Floor Hallway, Opposite to Elevator	1/15/14			
	Aiton ES	3rd Floor Hallway, Opposite to Elevator	1/15/14			
	Aiton ES	2nd Floor Hallway, Opposite to Vault	1/15/14			
	Aiton ES	2nd Floor Hallway, Opposite to Vault	1/15/14			
	Aiton ES	2nd Floor Hallway, Opposite to Elevator	1/15/14			
	Aiton ES	2nd Floor Hallway, Opposite to Elevator	1/15/14			
	Aiton ES	1st Floor, Inside Kindergarten #2	1/15/14			
	Aiton ES	1st Floor, Inside Kindergarten #2	1/15/14			
	Aiton ES	1st Floor, Inside Kindergarten #1	1/15/14			
	Aiton ES	1st Floor, Inside Kindergarten #1	1/15/14			
	Aiton ES	1st Floor Hallway, Opposite to Health Suite	1/15/14			
	Aiton ES	1st Floor Hallway, Opposite to Health Suite	1/15/14			
	Aiton ES	1st Floor Lobby, at Main Entrance	1/15/14			
	Aiton ES	1st Floor Lobby, at Main Entrance	1/15/14			
Percentage of Passed Samples						100.00%
Percentage of Failed Samples						0.00%
	Amidon ES	1st Floor Hallway, by Men's Restroom	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, by Men's Restroom	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, by Room B128 (High)	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, by Room B128 (High)	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, by Room B128 (Low)	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, by Room B128 (Low)	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, Leading to Gym	2/11/14	< 1		
	Amidon ES	1st Floor Hallway, Leading to Gym	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Gym	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Gym	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Pre-Kindergarten	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Pre-Kindergarten	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room B128	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room B128	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A103 (High)	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A103 (High)	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A106 (High)	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A106 (High)	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A105 (High)	2/11/14	1.3		
	Amidon ES	1st Floor, Inside Room A105 (High)	2/11/14	1.4		
	Amidon ES	1st Floor, Inside Room A105 (Low)	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A105 (Low)	2/11/14	< 1		
	Amidon ES	1st Floor, Inside Room A107 (High)	2/11/14	4.1		
	Amidon ES	1st Floor, Inside Room A107 (High)	2/11/14	< 1		

Amidon ES	1st Floor, Inside Room A107 (Low)	2/11/14	< 1		
Amidon ES	1st Floor, Inside Room A107 (Low)	2/11/14	< 1		
Amidon ES	1st Floor Hallway, Outside Health Suite	2/11/14	< 1		
Amidon ES	1st Floor Hallway, Outside Health Suite	2/11/14	< 1		
Amidon ES	1st Floor, Inside Health Suite	2/11/14	< 1		
Amidon ES	1st Floor, Inside Health Suite	2/11/14	< 1		
Amidon ES	1st Floor, Inside Room A103 (Low)	2/11/14	< 1		
Amidon ES	1st Floor, Inside Room A103 (Low)	2/11/14	< 1		
Amidon ES	1st Floor, Inside Room A106 (Low)	2/11/14	< 1		
Amidon ES	1st Floor, Inside Room A106 (Low)	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B223	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B223	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B230	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B230	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A208	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A208	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A212	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A212	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A202	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A202	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A213	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A213	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A209	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room A209	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B225	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B225	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B227	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B227	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B231	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B231	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B236	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B236	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B232	2/11/14	< 1		
Amidon ES	2nd Floor, Inside Room B232	2/11/14	< 1		
Amidon ES	2nd Floor Hallway, by Girls Restroom	2/11/14		59	Filter was installed.
Amidon ES	2nd Floor Hallway, by Girls Restroom	2/11/14	10		
Amidon ES	2nd Floor Hallway, by Girls Restroom - Retest		< 1		
Amidon ES	2nd Floor Hallway, by Girls Restroom - Retest		< 1		
				Percentage of Passed Samples	98.33%
				Percentage of Failed Samples	1.67%
Anacostia SHS	1st Floor Hallway, Next to Room M103	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Next to Room M103	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Next to Room S103	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Next to Room S103	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Across from Room G102	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Across from Room G102	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Across from Room M115	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Across from Room M115	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Across from Room N110	6/6/13	< 1		
Anacostia SHS	1st Floor Hallway, Across from Room N110	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room M320	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room M320	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room M303	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room M303	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room M220	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room M220	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room M202	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room M202	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room S204	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room S204	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room G204	6/6/13	< 1		
Anacostia SHS	2nd Floor Hallway, Next to Room G204	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room G302	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room G302	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room N201	6/6/13	< 1		
Anacostia SHS	3rd Floor Hallway, Next to Room N201	6/6/13	< 1		
				Percentage of Passed Samples	100.00%

		Percentage of Failed Samples		0.00%
Ballou SHS	3rd Floor Hallway, Opposite to Elevator	5/24/13	< 1	
Ballou SHS	3rd Floor Hallway, Opposite to Elevator	5/24/13	< 1	
Ballou SHS	3rd Floor Hallway, by Room 307	5/24/13	< 1	
Ballou SHS	3rd Floor Hallway, by Room 307	5/24/13	< 1	
Ballou SHS	3rd Floor Hallway, by Room 315	5/24/13	< 1	
Ballou SHS	3rd Floor Hallway, by Room 315	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, by Room 215	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, by Room 215	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, by Room 209	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, by Room 209	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, by Men's Restroom	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, by Men's Restroom	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, Outside Gym	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, Outside Gym	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Music Room & Auditorium	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Music Room & Auditorium	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Elevator	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Elevator	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A129	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A129	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A121	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A121	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A114	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A114	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A104	5/24/13	< 1	
Ballou SHS	1st Floor Hallway, by Room A104	5/24/13	< 1	
Ballou SHS	1st Floor, Inside Cafeteria, Right Side	5/24/13	< 1	
Ballou SHS	1st Floor, Inside Cafeteria, Right Side	5/24/13	< 1	
Ballou SHS	1st Floor, Inside Cafeteria, Close to Security Desk	5/24/13	< 1	
Ballou SHS	1st Floor, Inside Cafeteria, Close to Security Desk	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, Opposite to Room 206	5/24/13	< 1	
Ballou SHS	2nd Floor Hallway, Opposite to Room 206	5/24/13	< 1	
Ballou SHS	Basement Hallway, by Room A41	5/24/13	< 1	
Ballou SHS	Basement Hallway, by Room A41	5/24/13	< 1	
Ballou SHS	Basement Floor, Inside Armory	5/24/13	< 1	
Ballou SHS	Basement Floor, Inside Armory	5/24/13	< 1	
Ballou SHS	Basement Floor, Inside Girls Locker Room	5/24/13	< 1	
Ballou SHS	Basement Floor, Inside Girls Locker Room	5/24/13	< 1	
		Percentage of Passed Samples		100.00%
		Percentage of Failed Samples		0.00%
Bancroft ES	4th Floor, Next to Room 225	2/10/14	< 1	
Bancroft ES	4th Floor, Next to Room 225	2/10/14	< 1	
Bancroft ES	4th Floor, Next to Room 221	2/10/14	< 1	
Bancroft ES	4th Floor, Next to Room 221	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 122	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 122	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 213	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 213	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 210	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 210	2/10/14	< 1	
Bancroft ES	2nd Floor, Inside Health Suite	2/10/14	< 1	
Bancroft ES	2nd Floor, Inside Health Suite	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 107	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 107	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 324	2/10/14	< 1	
Bancroft ES	3rd Floor, Next to Room 324	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 309	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 309	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 314	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 314	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 313	2/10/14	< 1	
Bancroft ES	2nd Floor, Next to Room 313	2/10/14	< 1	
Bancroft ES	1st Floor, Next to Boys Restroom	2/10/14	< 1	
Bancroft ES	1st Floor, Next to Boys Restroom	2/10/14	< 1	

Bancroft ES	Basement Floor, Inside Lunch Room	2/10/14	< 1		
Bancroft ES	Basement Floor, Inside Lunch Room	2/10/14	< 1		
Bancroft ES	Open Space, by Boys Restroom	2/10/14	< 1		
Bancroft ES	Open Space, by Boys Restroom	2/10/14	< 1		
Bancroft ES	Open Space, by Girls Restroom	2/10/14	< 1		
Bancroft ES	Open Space, by Girls Restroom	2/10/14	< 1		
Bancroft ES	Open Space, Inside Library	2/10/14	< 1		
Bancroft ES	Open Space, Inside Library	2/10/14	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Bannaker SHS	3rd Floor, Outside Room 306	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 306	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 304	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 304	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 315	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 315	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 321	4/24/13	< 1		
Bannaker SHS	3rd Floor, Outside Room 321	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Mechanical Room	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Mechanical Room	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Library and Girls Restroom	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Library and Girls Restroom	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Library and Boys Restroom	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Library and Boys Restroom	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Mechanical Room, by Locker 754	4/24/13	< 1		
Bannaker SHS	2nd Floor, Outside Mechanical Room, by Locker 754	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Room 113	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Room 113	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Gym Entrance	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Gym Entrance	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Principal's Office	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Principal's Office	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Men's Restroom	4/24/13	< 1		
Bannaker SHS	1st Floor Hallway, by Men's Restroom	4/24/13	< 1		
Bannaker SHS	Basement Hallway, by Custodian's Office	4/24/13	< 1		
Bannaker SHS	Basement Hallway, by Custodian's Office	4/24/13	< 1		
Bannaker SHS	Basement Hallway, by Maintenance Office	4/24/13	< 1		
Bannaker SHS	Basement Hallway, by Maintenance Office	4/24/13	< 1		
Bannaker SHS	Basement, Inside Cafeteria, by Boys Restroom	4/24/13	< 1		
Bannaker SHS	Basement, Inside Cafeteria, by Boys Restroom	4/24/13	< 1		
Bannaker SHS	Basement, Inside Cafeteria, by Girls Restroom	4/24/13	< 1		
Bannaker SHS	Basement, Inside Cafeteria, by Girls Restroom	4/24/13	< 1		
Bannaker SHS	Basement Hallway, Opposite to Room 006	4/24/13	< 1		
Bannaker SHS	Basement Hallway, Opposite to Room 006	4/24/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Barnard ES	2nd Floor Hallway, by Room 239 (High)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 239 (High)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 239 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 239 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 206 (High)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 206 (High)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 206 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 206 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 210 (High)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 210 (High)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 210 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor Hallway, by Room 210 (Low)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 109 (High)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 109 (High)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 109 (Low)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 109 (Low)	1/31/14	< 1		

Barnard ES	1st Floor Hallway, by Room 106 (High)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 106 (High)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 106 (Low)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 106 (Low)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 121 (High)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 121 (High)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 121 (Low)	1/31/14	< 1		
Barnard ES	1st Floor Hallway, by Room 121 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 219 (High)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 219 (High)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 219 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 219 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 215 (High)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 215 (High)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 215 (Low)	1/31/14	< 1		
Barnard ES	2nd Floor, Across from Room 215 (Low)	1/31/14	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Beers ES	1st Floor, Inside Health Suite	3/26/13	< 1		
Beers ES	1st Floor, Inside Health Suite	3/26/13	< 1		
Beers ES	2nd Floor Hallway, Next to Teachers' Restroom	3/26/13	< 1		
Beers ES	2nd Floor Hallway, Next to Teachers' Restroom	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (High)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (High)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (Low)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (Low)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Girls Restroom (High)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Girls Restroom (High)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Girls Restroom (Low)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Next to Girls Restroom (Low)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Room B109	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Room B109	3/26/13	< 1		
Beers ES	2nd Floor Hallway, by Room B209	3/26/13	< 1		
Beers ES	2nd Floor Hallway, by Room B209	3/26/13	< 1		
Beers ES	2nd Floor Hallway, by Room B201	3/26/13	< 1		
Beers ES	2nd Floor Hallway, by Room B201	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Teachers' Lounge	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Teachers' Lounge	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Room D211 (High)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Room D211 (High)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Room D211 (Low)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Outside Room D211 (Low)	3/26/13	< 1		
Beers ES	1st Floor Hallway, Opposite to Room C101	3/26/13	2.1		
Beers ES	1st Floor Hallway, Opposite to Room C101	3/26/13	< 1		
Beers ES	Ground Floor, Entrance to Lunch Room (High)	3/26/13	< 1		
Beers ES	Ground Floor, Entrance to Lunch Room (High)	3/26/13	< 1		
Beers ES	Ground Floor, Entrance to Lunch Room (Low)	3/26/13	< 1		
Beers ES	Ground Floor, Entrance to Lunch Room (Low)	3/26/13	< 1		
Beers ES	Ground Floor Hallway, by Room D109 (High)	3/26/13	< 1		
Beers ES	Ground Floor Hallway, by Room D109 (High)	3/26/13	< 1		
Beers ES	Ground Floor Hallway, by Room D109 (Low)	3/26/13	< 1		
Beers ES	Ground Floor Hallway, by Room D109 (Low)	3/26/13	< 1		
Beers ES	Ground Floor Hallway, by Room D101	3/26/13	< 1		
Beers ES	Ground Floor Hallway, by Room D101	3/26/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (High)	6/3/13	< 1		
Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (High)	6/3/13	< 1		
Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (Low)	6/3/13	< 1		

Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (Low)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Display)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Display)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Display)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Display)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Stairwell)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Stairwell)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Stairwell)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Stairwell)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, High, Closer to Gym)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, High, Closer to Gym)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, Low, Closer to Gym)	6/3/13	< 1		
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, Low, Closer to Gym)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (High)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (High)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (Low)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (Low)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (High)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (High)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (Low)	6/3/13	< 1		
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (Low)	6/3/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Brent ES	3rd Floor Hallway, Across from Room 310	4/1/13	< 1		
Brent ES	3rd Floor Hallway, Across from Room 310	4/1/13	< 1		
Brent ES	3rd Floor Hallway, Across from Room 304	4/1/13	< 1		
Brent ES	3rd Floor Hallway, Across from Room 304	4/1/13	< 1		
Brent ES	2nd Floor Hallway, Across from Room 204	4/1/13	< 1		
Brent ES	2nd Floor Hallway, Across from Room 204	4/1/13	< 1		
Brent ES	2nd Floor Hallway, Across from Room 210	4/1/13	< 1		
Brent ES	2nd Floor Hallway, Across from Room 210	4/1/13	< 1		
Brent ES	2nd Floor, Inside Room 202	4/1/13	< 1		
Brent ES	2nd Floor, Inside Room 202	4/1/13	< 1		
Brent ES	2nd Floor, Inside Room 204	4/1/13	< 1		
Brent ES	2nd Floor, Inside Room 204	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 102	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 102	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 104	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 104	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 108	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 108	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 110	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 110	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 116	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 116	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 118	4/1/13	< 1		
Brent ES	1st Floor, Inside Room 118	4/1/13	< 1		
Brent ES	1st Floor Hallway Leading to Parking Lot	4/1/13	< 1		
Brent ES	1st Floor Hallway Leading to Parking Lot	4/1/13	< 1		
Brent ES	1st Floor, Inside Cafeteria	4/1/13	< 1		
Brent ES	1st Floor, Inside Cafeteria	4/1/13	< 1		
Percentage of Passed Samples				100.00%	

Brightwood ES	1st Floor, Inside Room 134	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 134	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 138	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 138	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 142	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 142	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 146	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 146	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 147	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 147	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 145	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 145	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 143	3/13/13	< 1	
Brightwood ES	1st Floor, Inside Room 143	3/13/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Browne MS	3rd Floor Hallway, Next to Room 3-329	5/13/13	< 1	
Browne MS	3rd Floor Hallway, Next to Room 3-329	5/13/13	< 1	
Browne MS	3rd Floor Hallway, Next to Room 3-337	5/13/13	< 1	
Browne MS	3rd Floor Hallway, Next to Room 3-337	5/13/13	< 1	
Browne MS	3rd Floor Hallway, Next to Room 3-307	5/13/13	< 1	
Browne MS	3rd Floor Hallway, Next to Room 3-307	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-301	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-301	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-269	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-269	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-217	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-217	5/13/13	1.4	
Browne MS	2nd Floor Hallway, Next to Room 2-213	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-213	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-235	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-235	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-239	5/13/13	< 1	
Browne MS	2nd Floor Hallway, Next to Room 2-239	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-135	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-135	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-124	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-124	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-119	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-119	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-111	5/13/13	2.5	
Browne MS	1st Floor, Inside Room 1-111	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-099	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-099	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-112	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-112	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-128	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 1-128	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-108	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-108	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 108	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 108	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-157	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-157	5/13/13	< 1	
Browne MS	1st Floor, Inside Room 137	5/13/13	2.5	
Browne MS	1st Floor, Inside Room 137	5/13/13	4.8	
Browne MS	1st Floor Hallway, Next to Room 1-179	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-179	5/13/13	2.6	
Browne MS	1st Floor Hallway, Near Room 1-193	5/13/13	< 1	
Browne MS	1st Floor Hallway, Near Room 1-193	5/13/13	< 1	
Browne MS	1st Floor Hallway, Next to Room 1-207	5/13/13	1.6	
Browne MS	1st Floor Hallway, Next to Room 1-207	5/13/13	3.7	
Browne MS	Basement Floor, Inside Gym	5/13/13	1.7	
Browne MS	Basement Floor, Inside Gym	5/13/13	3.4	
Browne MS	Basement Floor, Inside Girls Locker Room	5/13/13	2	
Browne MS	Basement Floor, Inside Girls Locker Room	5/13/13	2.2	
Browne MS	Basement Floor, Inside Boys Locker Room	5/13/13	2.5	

Browne MS	Basement Floor, Inside Boys Locker Room	5/13/13	3.4		
Browne MS	Basement Floor, Next to Custodian's Closet	5/13/13	3		
Browne MS	Basement Floor, Next to Custodian's Closet	5/13/13	4.1		
Browne MS	Basement Floor, Inside Cafeteria, Near Entrance	5/13/13	3.1		
Browne MS	Basement Floor, Inside Cafeteria, Near Entrance	5/13/13	3.3		
Browne MS	Basement Floor, Inside Cafeteria, Near Stair H	5/13/13	3.5		
Browne MS	Basement Floor, Inside Cafeteria, Near Stair H	5/13/13	2.4		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Bunker Hill ES	2nd Floor Hallway, Near Room 205	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Room 205	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near Teachers' Lounge	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near Teachers' Lounge	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Southwest Stairs	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Southwest Stairs	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Northwest Stairs	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Northwest Stairs	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 105	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 105	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 106	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 106	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near Room 103	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near Room 103	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 107	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 107	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 103	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 103	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near Auditorium	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near Auditorium	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Southeast Stairs	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Southeast Stairs	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Northeast Stairs	3/11/13	< 1		
Bunker Hill ES	2nd Floor Hallway, Near Northeast Stairs	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near North Stairs	3/11/13	< 1		
Bunker Hill ES	1st Floor Hallway, Near North Stairs	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 126	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 126	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 118	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 118	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 124	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 124	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 119	3/11/13	< 1		
Bunker Hill ES	1st Floor, Inside Room 119	3/11/13	< 1		
Bunker Hill ES	Basement Floor, Inside Lunch Room	3/11/13	< 1		
Bunker Hill ES	Basement Floor, Inside Lunch Room	3/11/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Burrville ES	2nd Floor, by Library (Low)	1/16/14			
Burrville ES	2nd Floor, by Library (Low)	1/16/14			
Burrville ES	2nd Floor, by Library (High)	1/16/14			
Burrville ES	2nd Floor, by Library (High)	1/16/14			
Burrville ES	2nd Floor, by Gymnasium	1/16/14			
Burrville ES	2nd Floor, by Gymnasium	1/16/14			
Burrville ES	2nd Floor, Inside Room 241	1/16/14			
Burrville ES	2nd Floor, Inside Room 241	1/16/14			
Burrville ES	2nd Floor, Inside Teachers' Lounge	1/16/14			
Burrville ES	2nd Floor, Inside Teachers' Lounge	1/16/14			
Burrville ES	2nd Floor, by the Exit (Low)	1/16/14			
Burrville ES	2nd Floor, by the Exit (Low)	1/16/14			
Burrville ES	2nd Floor, by the Exit (High)	1/16/14			
Burrville ES	2nd Floor, by the Exit (High)	1/16/14			
Burrville ES	2nd Floor, by Room 228 (High)	1/16/14			
Burrville ES	2nd Floor, by Room 228 (High)	1/16/14			
Burrville ES	2nd Floor, by Room 228 (Low)	1/16/14			
Burrville ES	2nd Floor, by Room 228 (Low)	1/16/14			

Burrville ES	2nd Floor, Inside Room 228	1/16/14		
Burrville ES	2nd Floor, Inside Room 228	1/16/14		
Burrville ES	2nd Floor, Inside Room 227	1/16/14		
Burrville ES	2nd Floor, Inside Room 227	1/16/14		
Burrville ES	2nd Floor, Inside Room 224	1/16/14		
Burrville ES	2nd Floor, Inside Art Room A	1/16/14		
Burrville ES	2nd Floor, Inside Art Room A	1/16/14		
Burrville ES	2nd Floor, Inside Art Room B	1/16/14		
Burrville ES	2nd Floor, Inside Art Room B	1/16/14		
Burrville ES	2nd Floor, Inside Room 221	1/16/14		
Burrville ES	2nd Floor, Inside Room 221	1/16/14		
Burrville ES	2nd Floor, by Boys Restroom (High)	1/16/14		
Burrville ES	2nd Floor, by Boys Restroom (High)	1/16/14		
Burrville ES	2nd Floor, by Boys Restroom (Low)	1/16/14		
Burrville ES	2nd Floor, by Boys Restroom (Low)	1/16/14		
Burrville ES	2nd Floor, Inside Boys Locker Room	1/16/14		
Burrville ES	2nd Floor, Inside Boys Locker Room	1/16/14		
Burrville ES	2nd Floor, Inside Girls Locker Room	1/16/14		
Burrville ES	2nd Floor, Inside Girls Locker Room	1/16/14		
Burrville ES	2nd Floor, In the Main Lobby (High)	1/16/14		
Burrville ES	2nd Floor, In the Main Lobby (High)	1/16/14		
Burrville ES	2nd Floor, In the Main Lobby (Low)	1/16/14		
Burrville ES	2nd Floor, In the Main Lobby (Low)	1/16/14		
Burrville ES	1st Floor, Inside Room 114	1/16/14		
Burrville ES	1st Floor, Inside Room 114	1/16/14		
Burrville ES	1st Floor, Inside Room 113	1/16/14		
Burrville ES	1st Floor, Inside Room 113	1/16/14		
Burrville ES	1st Floor, Inside Room 111	1/16/14		
Burrville ES	1st Floor, Inside Room 111	1/16/14		
Burrville ES	1st Floor, by Room 111 (High)	1/16/14		
Burrville ES	1st Floor, by Room 111 (High)	1/16/14		
Burrville ES	1st Floor, by Room 111 (Low)	1/16/14		
Burrville ES	1st Floor, by Room 111 (Low)	1/16/14		
Burrville ES	1st Floor, Inside Room 110	1/16/14		
Burrville ES	1st Floor, Inside Room 110	1/16/14		
Burrville ES	1st Floor, Inside Room 115	1/16/14		
Burrville ES	1st Floor, Inside Room 115	1/16/14		
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Burroughs ES	Basement Floor Hallway, Next to Room 19	3/19/13	< 1	
Burroughs ES	Basement Floor Hallway, Next to Room 19	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 19	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 19	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 20	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 20	3/19/13	< 1	
Burroughs ES	Basement Floor Hallway, Next to Room 20	3/19/13	< 1	
Burroughs ES	Basement Floor Hallway, Next to Room 20	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 21	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 21	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 22	3/19/13	< 1	
Burroughs ES	Basement Floor, Inside Room 22	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Across from Room 3	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Across from Room 3	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Next to Room 8	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Next to Room 8	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Next to Room 9	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Next to Room 9	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Next to Room 14	3/19/13	< 1	
Burroughs ES	1st Floor Hallway, Next to Room 14	3/19/13	< 1	
Burroughs ES	1st Floor (new wing) Hallway, Across from Room 27	3/19/13	< 1	
Burroughs ES	1st Floor (new wing) Hallway, Across from Room 27	3/19/13	< 1	
Burroughs ES	1st Floor (new wing), Sink Inside Room 34	3/19/13	< 1	
Burroughs ES	1st Floor (new wing), Sink Inside Room 34	3/19/13	< 1	
Burroughs ES	1st Floor (new wing), Inside Room 35	3/19/13	< 1	
Burroughs ES	1st Floor (new wing), Inside Room 35	3/19/13	< 1	

Burroughs ES	1st Floor (new wing), Inside Room 25	3/19/13	< 1		
Burroughs ES	1st Floor (new wing), Inside Room 25	3/19/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
C.W. Harris ES	1st Floor Hallway, Across from Custodian's Office	3/22/13	< 1		
C.W. Harris ES	1st Floor Hallway, Across from Custodian's Office	3/22/13	< 1		
C.W. Harris ES	1st Floor, Inside Room 149	3/22/13	< 1		
C.W. Harris ES	1st Floor, Inside Room 149	3/22/13	< 1		
C.W. Harris ES	1st Floor, Inside Room 153	3/22/13	< 1		
C.W. Harris ES	1st Floor, Inside Room 153	3/22/13	< 1		
C.W. Harris ES	1st Floor, Inside Multi-Purpose Room	3/22/13	< 1		
C.W. Harris ES	1st Floor, Inside Multi-Purpose Room	3/22/13	< 1		
C.W. Harris ES	1st Floor Hallway, Across from Health Suite	3/22/13	< 1		
C.W. Harris ES	1st Floor Hallway, Across from Health Suite	3/22/13	< 1		
C.W. Harris ES	1st Floor Hallway, Inside Health Suite	3/22/13	< 1		
C.W. Harris ES	1st Floor Hallway, Inside Health Suite	3/22/13	< 1		
C.W. Harris ES	2nd Floor Hallway, Across from Room 218	3/22/13	< 1		
C.W. Harris ES	2nd Floor Hallway, Across from Room 218	3/22/13	< 1		
C.W. Harris ES	2nd Floor Hallway, Across from Room 246	3/22/13	< 1		
C.W. Harris ES	2nd Floor Hallway, Across from Room 246	3/22/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Cleveland ES	3rd Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	3rd Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	3rd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	3rd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 308	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 308	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 304	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 304	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 313	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 313	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 302	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 302	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 315	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 315	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 301	2/20/13	< 1		
Cleveland ES	3rd Floor, Inside Room 301	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 218	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 218	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 203	2/20/13	2.3		
Cleveland ES	2nd Floor, Inside Room 203	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 212	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 212	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 207	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 207	2/20/13	< 1		
Cleveland ES	2nd Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	2nd Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	2nd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	2nd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	1st Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	1st Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	1st Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	1st Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		

Cleveland ES	1st Floor, Inside Room 111	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 111	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 106	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 106	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 103	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 103	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 115	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 115	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 117	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 117	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 120	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 120	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 101	2/20/13	< 1		
Cleveland ES	1st Floor, Inside Room 101	2/20/13	< 1		
Cleveland ES	Ground Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	Ground Floor Hallway, Across from Elevator (High)	2/20/13	< 1		
Cleveland ES	Ground Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	Ground Floor Hallway, Across from Elevator (Low)	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 216 (1)	2/20/13	1.7		
Cleveland ES	2nd Floor, Inside Room 216 (1)	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 216 (2)	2/20/13	2		
Cleveland ES	2nd Floor, Inside Room 216 (2)	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 216 (3)	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 216 (3)	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 216 (4)	2/20/13	< 1		
Cleveland ES	2nd Floor, Inside Room 216 (4)	2/20/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Davis ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1		
Davis ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1		
Davis ES	1st Floor Hallway, Next to Room 118	1/25/13	< 1		
Davis ES	1st Floor Hallway, Next to Room 118	1/25/13	< 1		
Davis ES	1st Floor Entrance, Next to Security Desk	1/25/13	< 1		
Davis ES	1st Floor Entrance, Next to Security Desk	1/25/13	< 1		
Davis ES	1st Floor Hallway, Next to Room 104	1/25/13	< 1		
Davis ES	1st Floor Hallway, Next to Room 104	1/25/13	< 1		
Davis ES	Basement Floor, Cafeteria, Next to Fuse Box	1/25/13	< 1		
Davis ES	Basement Floor, Cafeteria, Next to Fuse Box	1/25/13	< 1		
Davis ES	Basement Floor, Cafeteria, Next to Storage Room 15	1/25/13	< 1		
Davis ES	Basement Floor, Cafeteria, Next to Storage Room 15	1/25/13	< 1		
Davis ES	1st Floor, Inside Room 101	1/25/13	< 1		
Davis ES	1st Floor, Inside Room 101	1/25/13	< 1		
Davis ES	1st Floor, Teachers' Lounge, Near Room 104	1/25/13	2.5		
Davis ES	1st Floor, Teachers' Lounge, Near Room 104	1/25/13		15	Filter was installed.
Davis ES	<i>1st Floor, Teachers' Lounge, Near Room 104 - Retest</i>	<i>2/7/13</i>	<i>3</i>		
Davis ES	<i>1st Floor, Teachers' Lounge, Near Room 104 - Retest</i>	<i>2/7/13</i>	<i>2.3</i>		
Davis ES	1st Floor, Inside Room 115 Kindergarten	1/25/13	< 1		
Davis ES	1st Floor, Inside Room 115 Kindergarten	1/25/13	< 1		
Davis ES	2nd Floor Hallway, Next to Room 218A	1/25/13	< 1		
Davis ES	2nd Floor Hallway, Next to Room 218A	1/25/13	< 1		
Davis ES	Basement Hallway, Next to Room 16A	1/25/13	< 1		
Davis ES	Basement Hallway, Next to Room 16A	1/25/13	< 1		
Davis ES	2nd Floor Hallway, Next to Room 212	1/25/13	< 1		
Davis ES	2nd Floor Hallway, Next to Room 212	1/25/13	< 1		
Davis ES	2nd Floor Hallway, Next to Room 204	1/25/13	< 1		

Davis ES	2nd Floor Hallway, Next to Room 204	1/25/13	< 1		
Davis ES	2nd Floor, Teachers' Lounge, Near Room 218A	1/25/13	< 1		
Davis ES	2nd Floor, Teachers' Lounge, Near Room 218A	1/25/13	< 1		
Davis ES	1st Floor, Inside Room 105	1/25/13	< 1		
Davis ES	1st Floor, Inside Room 105	1/25/13	< 1		
Davis ES	1st Floor, Inside Principal's Office	1/25/13	< 1		
Davis ES	1st Floor, Inside Principal's Office	1/25/13	< 1		
Davis ES	1st Floor, Inside Health Suite	1/25/13	< 1		
Davis ES	1st Floor, Inside Health Suite	1/25/13	< 1		
Percentage of Passed Samples					97.06%
Percentage of Failed Samples					2.94%
Deal MS	3rd Floor Hallway, Next to Room W300 (High)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room W300 (High)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room W300 (Low)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room W300 (Low)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room E300 (High)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room E300 (High)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room E300 (Low)	2/13/13	< 1		
Deal MS	3rd Floor Hallway, Next to Room E300 (Low)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room E200 (High)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room E200 (High)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room E200 (Low)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room E200 (Low)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room W200 (High)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room W200 (High)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room W200 (Low)	2/13/13	< 1		
Deal MS	2nd Floor Hallway, Next to Room W200 (Low)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room W100 (High)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room W100 (High)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room W100 (Low)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room W100 (Low)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room E100 (High)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room E100 (High)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room E100 (Low)	2/13/13	< 1		
Deal MS	1st Floor Hallway, Next to Room E100 (Low)	2/13/13	< 1		
Deal MS	Basement Floor, Outside Cafeteria (High)	2/13/13	< 1		
Deal MS	Basement Floor, Outside Cafeteria (High)	2/13/13	< 1		
Deal MS	Basement Floor, Outside Cafeteria (Low)	2/13/13	< 1		
Deal MS	Basement Floor, Outside Cafeteria (Low)	2/13/13	< 1		
Deal MS	Basement Hallway, Next to Room CG42 (High)	2/13/13	< 1		
Deal MS	Basement Hallway, Next to Room CG42 (High)	2/13/13	< 1		
Deal MS	Basement Hallway, Next to Room CG42 (Low)	2/13/13	< 1		

Deal MS	Basement Hallway, Next to Room CG42 (Low)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1		
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1		
Deal MS	Basement Hallway, Outside Coach's Office (High)	2/13/13	< 1		
Deal MS	Basement Hallway, Outside Coach's Office (High)	2/13/13	< 1		
Deal MS	Basement Hallway, Outside Coach's Office (Low)	2/13/13	< 1		
Deal MS	Basement Hallway, Outside Coach's Office (Low)	2/13/13	< 1		
Percentage of Passed Samples					100.00%
					0.00%
Drew ES	4th Floor Hallway, by Room 407 (High)	1/17/14			
Drew ES	4th Floor Hallway, by Room 407 (High)	1/17/14			
Drew ES	4th Floor Hallway, by Room 407 (Low)	1/17/14			
Drew ES	4th Floor Hallway, by Room 407 (Low)	1/17/14			
Drew ES	4th Floor Hallway, by Room 400	1/17/14			
Drew ES	4th Floor Hallway, by Room 400	1/17/14			
Drew ES	3rd Floor Hallway, by Room 300 (High)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 300 (High)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 300 (Low)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 300 (Low)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 307 (High)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 307 (High)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 307 (Low)	1/17/14			
Drew ES	3rd Floor Hallway, by Room 307 (Low)	1/17/14			
Drew ES	2nd Floor, Inside Room 205	1/17/14			
Drew ES	2nd Floor, Inside Room 205	1/17/14			
Drew ES	2nd Floor, Inside Room 207	1/17/14			
Drew ES	2nd Floor, Inside Room 207	1/17/14			
Drew ES	2nd Floor Hallway, by Room 207 (High)	1/17/14			
Drew ES	2nd Floor Hallway, by Room 207 (High)	1/17/14			
Drew ES	2nd Floor Hallway, by Room 207 (Low)	1/17/14			
Drew ES	2nd Floor Hallway, by Room 207 (Low)	1/17/14			
Drew ES	2nd Floor, Inside Room 209	1/17/14			
Drew ES	2nd Floor, Inside Room 209	1/17/14			
Drew ES	2nd Floor Hallway, by Room 200 (High)	1/17/14			
Drew ES	2nd Floor Hallway, by Room 200 (High)	1/17/14			
Drew ES	2nd Floor Hallway, by Room 200 (Low)	1/17/14			
Drew ES	2nd Floor Hallway, by Room 200 (Low)	1/17/14			
Drew ES	2nd Floor, Inside Teachers' Lounge	1/17/14			
Drew ES	2nd Floor, Inside Teachers' Lounge	1/17/14			
Drew ES	1st Floor, Inside Health Suite	1/17/14			
Drew ES	1st Floor, Inside Health Suite	1/17/14			
Drew ES	1st Floor, Inside Health Suite (High)	1/17/14			
Drew ES	1st Floor, Inside Health Suite (High)	1/17/14			
Drew ES	1st Floor, Inside Health Suite (Low)	1/17/14			
Drew ES	1st Floor, Inside Health Suite (Low)	1/17/14			
Drew ES	1st Floor, Inside Room 104	1/17/14			
Drew ES	1st Floor, Inside Room 104	1/17/14			
Drew ES	1st Floor, Inside Room 108	1/17/14			
Drew ES	1st Floor, Inside Room 108	1/17/14			
Drew ES	1st Floor, Inside Room 105	1/17/14			
Drew ES	1st Floor, Inside Room 105	1/17/14			
Drew ES	1st Floor Hallway, by Room 105 (High)	1/17/14			
Drew ES	1st Floor Hallway, by Room 105 (High)	1/17/14			
Drew ES	1st Floor Hallway, by Room 105 (Low)	1/17/14			
Drew ES	1st Floor Hallway, by Room 105 (Low)	1/17/14			
Drew ES	1st Floor, Inside Room 107	1/17/14			

Drew ES	1st Floor, Inside Room 107	1/17/14		
Drew ES	1st Floor, Inside Room 106	1/17/14		
Drew ES	1st Floor, Inside Room 106	1/17/14		
Drew ES	1st Floor, Inside Lunch Room	1/17/14		
Drew ES	1st Floor, Inside Lunch Room	1/17/14		
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Dunbar SHS	13th Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	13th Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	12th Floor, Next to East Stairwell	6/13/13	4.3	
Dunbar SHS	12th Floor, Next to East Stairwell	6/13/13	3.5	
Dunbar SHS	10th Floor, Next to East Stairwell	6/13/13	< 1	
Dunbar SHS	10th Floor, Next to East Stairwell	6/13/13	< 1	
Dunbar SHS	9th Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	9th Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	7th Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	7th Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	6th Floor, Next to East Stairwell	6/13/13	< 1	
Dunbar SHS	6th Floor, Next to East Stairwell	6/13/13	< 1	
Dunbar SHS	5th Floor, Next to West Stairwell in Cafeteria	6/13/13	< 1	
Dunbar SHS	5th Floor, Next to West Stairwell in Cafeteria	6/13/13	< 1	
Dunbar SHS	4th Floor, Next to East Stairwell in Media Center	6/13/13	< 1	
Dunbar SHS	4th Floor, Next to East Stairwell in Media Center	6/13/13	< 1	
Dunbar SHS	3rd Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	3rd Floor, Next to West Stairwell	6/13/13	< 1	
Dunbar SHS	2nd Floor, Next to Main Entrance	6/13/13	< 1	
Dunbar SHS	2nd Floor, Next to Main Entrance	6/13/13	< 1	
Dunbar SHS	2nd Floor Hallway, Next to Instrumental Room	6/13/13	< 1	
Dunbar SHS	2nd Floor Hallway, Next to Instrumental Room	6/13/13	< 1	
Dunbar SHS	Inside Main Office	6/13/13	< 1	
Dunbar SHS	Inside Main Office	6/13/13	< 1	
Dunbar SHS	Inside Community Room	6/13/13	< 1	
Dunbar SHS	Inside Community Room	6/13/13	< 1	
Dunbar SHS	2nd Floor Hallway, Across from Room 206	6/13/13	< 1	
Dunbar SHS	2nd Floor Hallway, Across from Room 206	6/13/13	< 1	
Dunbar SHS	In Gym Hallway, Near Handicap Ramp	6/13/13	< 1	
Dunbar SHS	In Gym Hallway, Near Handicap Ramp	6/13/13	< 1	
Dunbar SHS	In Gym Hallway, Across from Gym Entrance	6/13/13	< 1	
Dunbar SHS	In Gym Hallway, Across from Gym Entrance	6/13/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Eastern SHS	Inside Cafeteria (High)	6/7/13	< 1	
Eastern SHS	Inside Cafeteria (High)	6/7/13	< 1	
Eastern SHS	Inside Cafeteria (Low)	6/7/13	< 1	
Eastern SHS	Inside Cafeteria (Low)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (High)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (High)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (Low)	6/7/13	< 1	
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (Low)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (High)	6/7/13	< 1	

Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (High)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (Low)	6/7/13	< 1	
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (Low)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (High)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (High)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (Low)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (Low)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (High)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (High)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (Low)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (Low)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (High)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (High)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (Low)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (Low)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, Opposite to Room E124	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, Opposite to Room E124	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (High)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (High)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (Low)	6/7/13	< 1	
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (Low)	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room E227	6/7/13	< 1	
Eastern SHS	2nd Floor Hallway, Opposite to Room E227	6/7/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Eaton ES	3rd Floor Hallway, by Room 313	2/1/13	< 1	
Eaton ES	3rd Floor Hallway, by Room 313	2/1/13	< 1	
Eaton ES	3rd Floor Hallway, by Room 303	2/1/13	< 1	
Eaton ES	3rd Floor Hallway, by Room 303	2/1/13	< 1	
Eaton ES	2nd Floor Hallway, by Room 208	2/1/13	< 1	
Eaton ES	2nd Floor Hallway, by Room 208	2/1/13	< 1	
Eaton ES	2nd Floor Hallway, by Room 218	2/1/13	< 1	
Eaton ES	2nd Floor Hallway, by Room 218	2/1/13	< 1	
Eaton ES	1st Floor Hallway, by Room 120	2/1/13	< 1	
Eaton ES	1st Floor Hallway, by Room 120	2/1/13	< 1	
Eaton ES	1st Floor, by Main Entrance (High)	2/1/13	< 1	
Eaton ES	1st Floor, by Main Entrance (High)	2/1/13	< 1	
Eaton ES	1st Floor, by Main Entrance (Low)	2/1/13	< 1	
Eaton ES	1st Floor, by Main Entrance (Low)	2/1/13	< 1	
Eaton ES	1st Floor, Inside Health Suite	2/1/13	< 1	
Eaton ES	1st Floor, Inside Health Suite	2/1/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Eliot-Hine MS	1st Floor Hallway, Next to Main Office	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Next to Main Office	5/10/13	< 1	
Eliot-Hine MS	1st Floor, Next to Room 1-166	5/10/13	< 1	
Eliot-Hine MS	1st Floor, Next to Room 1-166	5/10/13	< 1	
Eliot-Hine MS	1st Floor, at Entrance to Gym	5/10/13	< 1	
Eliot-Hine MS	1st Floor, at Entrance to Gym	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Across from Room 1-100 (Custodian's Closet)	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Across from Room 1-100 (Custodian's Closet)	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Next to Army ROTC Office	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Next to Army ROTC Office	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Across from Ladies' Room	5/10/13	< 1	
Eliot-Hine MS	1st Floor Hallway, Across from Ladies' Room	5/10/13	< 1	

Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-262	5/10/13	< 1	
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-262	5/10/13	< 1	
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-255	5/10/13	< 1	
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-255	5/10/13	< 1	
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-210	5/10/13	< 1	
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-210	5/10/13	< 1	
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-206	5/10/13	< 1	
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-206	5/10/13	< 1	
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-198	5/10/13	< 1	
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-198	5/10/13	< 1	
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Entrance	5/10/13	< 1	
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Entrance	5/10/13	< 1	
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Exit to Stairwell	5/10/13	< 1	
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Exit to Stairwell	5/10/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Ellington SHS	3rd Floor Hallway, by Room 306	5/29/13	< 1	
Ellington SHS	3rd Floor Hallway, by Room 306	5/29/13	< 1	
Ellington SHS	2nd Floor Hallway, by Staff Lounge	5/29/13	< 1	
Ellington SHS	2nd Floor Hallway, by Staff Lounge	5/29/13	< 1	
Ellington SHS	2nd Floor Hallway, by Room 254A	5/29/13	< 1	
Ellington SHS	2nd Floor Hallway, by Room 254A	5/29/13	< 1	
Ellington SHS	1st Floor Hallway, by Office of Director of Admissions	5/29/13	< 1	
Ellington SHS	1st Floor Hallway, by Office of Director of Admissions	5/29/13	< 1	
Ellington SHS	1st Floor Hallway, by Stage Left & Rehearsal Hall Door	5/29/13	< 1	
Ellington SHS	1st Floor Hallway, by Stage Left & Rehearsal Hall Door	5/29/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Evans MS	3rd Floor Hallway, by Room 329	5/28/13	< 1	
Evans MS	3rd Floor Hallway, by Room 329	5/28/13	< 1	
Evans MS	3rd Floor Hallway, by Room 317	5/28/13	< 1	
Evans MS	3rd Floor Hallway, by Room 317	5/28/13	< 1	
Evans MS	2nd Floor Hallway, by Room 211	5/28/13	< 1	
Evans MS	2nd Floor Hallway, by Room 211	5/28/13	< 1	
Evans MS	2nd Floor Hallway, by Staff Restroom	5/28/13	< 1	
Evans MS	2nd Floor Hallway, by Staff Restroom	5/28/13	< 1	
Evans MS	1st Floor Hallway, by Room 150	5/28/13	< 1	
Evans MS	1st Floor Hallway, by Room 150	5/28/13	< 1	
Evans MS	1st Floor Hallway, by Teachers' Lavatory	5/28/13	< 1	
Evans MS	1st Floor Hallway, by Teachers' Lavatory	5/28/13	< 1	
Evans MS	Basement Floor, Inside Gym	5/28/13	< 1	
Evans MS	Basement Floor, Inside Gym	5/28/13	< 1	
Evans MS	Basement Floor Hallway, by Room 024	5/28/13	< 1	
Evans MS	Basement Floor Hallway, by Room 024	5/28/13	< 1	
Evans MS	Basement Floor Hallway, by Teachers' Lavatory	5/28/13	< 1	
Evans MS	Basement Floor Hallway, by Teachers' Lavatory	5/28/13	< 1	
Evans MS	Basement Floor Hallway, by Room 078	5/28/13	< 1	
Evans MS	Basement Floor Hallway, by Room 078	5/28/13	< 1	
Evans MS	Sub-Basement Floor, Inside Cafeteria	5/28/13	< 1	
Evans MS	Sub-Basement Floor, Inside Cafeteria	5/28/13	< 1	
Evans MS	Sub-Basement Floor, Inside Multi-Purpose Room	5/28/13	< 1	
Evans MS	Sub-Basement Floor, Inside Multi-Purpose Room	5/28/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Ferebee Hope ES	4th Floor Hallway, Across from Room 406	5/8/13	< 1	
Ferebee Hope ES	4th Floor Hallway, Across from Room 406	5/8/13	< 1	
Ferebee Hope ES	4th Floor Hallway, Next to Women's Room	5/8/13	< 1	
Ferebee Hope ES	4th Floor Hallway, Next to Women's Room	5/8/13	< 1	
Ferebee Hope ES	4th Floor Hallway, Next to Boy's Room	5/8/13	< 1	
Ferebee Hope ES	4th Floor Hallway, Next to Boy's Room	5/8/13	< 1	

Ferebee Hope ES	4th Floor Hallway, Across from Room 402	5/8/13	2.2		
Ferebee Hope ES	4th Floor Hallway, Across from Room 402	5/8/13	1.5		
Ferebee Hope ES	3rd Floor Hallway, Across from Room 306	5/8/13	< 1		
Ferebee Hope ES	3rd Floor Hallway, Across from Room 306	5/8/13	< 1		
Ferebee Hope ES	3rd Floor Hallway, Next to Women's Room	5/8/13	< 1		
Ferebee Hope ES	3rd Floor Hallway, Next to Women's Room	5/8/13	< 1		
Ferebee Hope ES	3rd Floor Hallway, Next to Boy's Room	5/8/13	< 1		
Ferebee Hope ES	3rd Floor Hallway, Next to Boy's Room	5/8/13	< 1		
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Across from Room 206	5/8/13	< 1		
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Across from Room 206	5/8/13	< 1		
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Women's Room	5/8/13	< 1		
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Women's Room	5/8/13	< 1		
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Boy's Room	5/8/13	< 1		
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Boy's Room	5/8/13	< 1		
Ferebee Hope ES	1st Floor, at Entrance to Gym (Closer to Exit)	5/8/13	< 1		
Ferebee Hope ES	1st Floor, at Entrance to Gym (Closer to Exit)	5/8/13	< 1		
Ferebee Hope ES	1st Floor, at Entrance to Gym	5/8/13	< 1		
Ferebee Hope ES	1st Floor, at Entrance to Gym	5/8/13	< 1		
Ferebee Hope ES	1st Floor, Inside Boys Locker Room	5/8/13	< 1		
Ferebee Hope ES	1st Floor, Inside Boys Locker Room	5/8/13	< 1		
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Bldg D	5/8/13	< 1		
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Bldg D	5/8/13	< 1		
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Men's Room	5/8/13	< 1		
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Men's Room	5/8/13	< 1		
Ferebee Hope ES	2nd Floor, Building D, Next to Men's Room	5/8/13	< 1		
Ferebee Hope ES	2nd Floor, Building D, Next to Men's Room	5/8/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Francis MS	3rd Floor, by Room 303	3/27/13	< 1		
Francis MS	3rd Floor, by Room 303	3/27/13	< 1		
Francis MS	3rd Floor, by Room 304	3/27/13	< 1		
Francis MS	3rd Floor, by Room 304	3/27/13	< 1		
Francis MS	2nd Floor, by Room 204	3/27/13	< 1		
Francis MS	2nd Floor, by Room 204	3/27/13	< 1		
Francis MS	1st Floor, by Main Office	3/27/13	< 1		
Francis MS	1st Floor, by Main Office	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 108	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 108	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 110	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 110	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 107	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 107	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 105	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 105	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 103	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 103	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 100	3/27/13	< 1		
Francis MS	1st Floor, Inside Room 100	3/27/13	< 1		
Francis MS	1st Floor, Inside Teachers' Room	3/27/13	< 1		
Francis MS	1st Floor, Inside Teachers' Room	3/27/13	< 1		
Francis MS	1st Floor, Inside Lunch Room	3/27/13	< 1		
Francis MS	1st Floor, Inside Lunch Room	3/27/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Garfield ES	2nd Floor Hallway, by Ladder to Roof	3/13/13	< 1		
Garfield ES	2nd Floor Hallway, by Ladder to Roof	3/13/13	< 1		
Garfield ES	2nd Floor Hallway, by Teachers' Lounge	3/13/13	6		Filter was installed.
Garfield ES	2nd Floor Hallway, by Teachers' Lounge	3/13/13	3		
Garfield ES	2nd Floor Hallway, by Boys Restroom	3/13/13	< 1		
Garfield ES	2nd Floor Hallway, by Boys Restroom	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Main Office	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Main Office	3/13/13	< 1		

Garfield ES	1st Floor Hallway, by Room 104	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Room 104	3/13/13	< 1		
Garfield ES	1st Floor, Inside Nurse's Suite	3/13/13	< 1		
Garfield ES	1st Floor, Inside Nurse's Suite	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Teachers' Lounge	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Teachers' Lounge	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Boys Restroom	3/13/13	< 1		
Garfield ES	1st Floor Hallway, by Boys Restroom	3/13/13	< 1		
Garfield ES	1st Floor, Inside Kindergarten, Room 102	3/13/13	< 1		
Garfield ES	1st Floor, Inside Kindergarten, Room 102	3/13/13	< 1		
Garfield ES	1st Floor, Inside Kindergarten, Room 110	3/13/13	< 1		
Garfield ES	1st Floor, Inside Kindergarten, Room 110	3/13/13	< 1		
Garfield ES	Basement Floor, Inside Lunch Room, by Restrooms	3/13/13	< 1		
Garfield ES	Basement Floor, Inside Lunch Room, by Restrooms	3/13/13	< 1		
Garfield ES	Basement Floor, Inside Lunch Room, by Kitchen Wall	3/13/13	< 1		
Garfield ES	Basement Floor, Inside Lunch Room, by Kitchen Wall	3/13/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Garnet-Patterson MS	Next to Exit, Inside Cafeteria	4/17/13	1.4		
Garnet-Patterson MS	Next to Exit, Inside Cafeteria	4/17/13	< 1		
Garnet-Patterson MS	Inside Cafeteria with Broken Knob	4/17/13	< 1		
Garnet-Patterson MS	Inside Cafeteria with Broken Knob	4/17/13	< 1		
Garnet-Patterson MS	1st Floor Hallway, Across from Room 106	4/17/13	< 1		
Garnet-Patterson MS	1st Floor Hallway, Across from Room 106	4/17/13	< 1		
Garnet-Patterson MS	1st Floor Hallway, Next to Room 110	4/17/13	< 1		
Garnet-Patterson MS	1st Floor Hallway, Next to Room 110	4/17/13	< 1		
Garnet-Patterson MS	2nd Floor Hallway, Next to Nurse's Suite	4/17/13	< 1		
Garnet-Patterson MS	2nd Floor Hallway, Next to Nurse's Suite	4/17/13	< 1		
Garnet-Patterson MS	2nd Floor Hallway, Next to Room 216	4/17/13	< 1		
Garnet-Patterson MS	2nd Floor Hallway, Next to Room 216	4/17/13	< 1		
Garnet-Patterson MS	3rd Floor Hallway, Across from Room 304	4/17/13	< 1		
Garnet-Patterson MS	3rd Floor Hallway, Across from Room 304	4/17/13	< 1		
Garnet-Patterson MS	3rd Floor Hallway, Next to Room 308	4/17/13	< 1		
Garnet-Patterson MS	3rd Floor Hallway, Next to Room 308	4/17/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Garrison ES	2nd Floor, by Room 206	2/4/14			
Garrison ES	2nd Floor, by Room 206	2/4/14			
Garrison ES	2nd Floor, by Room 201	2/4/14			
Garrison ES	2nd Floor, by Room 201	2/4/14			
Garrison ES	1st Floor, Inside Health Suite	2/4/14			
Garrison ES	1st Floor, Inside Health Suite	2/4/14			
Garrison ES	1st Floor, Inside Room 110	2/4/14			
Garrison ES	1st Floor, Inside Room 110	2/4/14			
Garrison ES	1st Floor, Inside Room 109	2/4/14			
Garrison ES	1st Floor, Inside Room 109	2/4/14			
Garrison ES	1st Floor, Inside Room 108	2/4/14			
Garrison ES	1st Floor, Inside Room 108	2/4/14			
Garrison ES	1st Floor, by Main Office	2/4/14			
Garrison ES	1st Floor, by Main Office	2/4/14			
Garrison ES	1st Floor, Inside Lunch Room	2/4/14			
Garrison ES	1st Floor, Inside Lunch Room	2/4/14			
Garrison ES	2nd Floor, by Room 212	2/4/14			
Garrison ES	2nd Floor, by Room 212	2/4/14			
Garrison ES	2nd Floor, by Room 217	2/4/14			
Garrison ES	2nd Floor, by Room 217	2/4/14			
Garrison ES	1st Floor, Inside Room 122	2/4/14			
Garrison ES	1st Floor, Inside Room 122	2/4/14			
Garrison ES	1st Floor, Inside Room 128	2/4/14			
Garrison ES	1st Floor, Inside Room 128	2/4/14			
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1		
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1		
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1		

H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 302	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 302	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 303	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 303	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 304	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 304	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 305	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 305	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 310	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 310	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 311	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 311	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 312	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 312	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 313	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 313	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 341	6/6/13		16
H.D. Cooke ES	1st Floor, Inside Room 341	6/6/13	2.7	
H.D. Cooke ES	<i>1st Floor, Inside Room 341 - Retest</i>	<i>6/20/13</i>	<i>1</i>	
H.D. Cooke ES	<i>1st Floor, Inside Room 341 - Retest</i>	<i>6/20/13</i>	< 1	
H.D. Cooke ES	1st Floor, Inside Room 314	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 314	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 202	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 202	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 203	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 203	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 204	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 204	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 205	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 205	6/6/13	< 1	
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (High)	6/6/13	< 1	
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (High)	6/6/13	< 1	
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1	
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 210	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 210	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 211	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 211	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 212	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 212	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 213	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 213	6/6/13	< 1	
H.D. Cooke ES	2nd Floor, Inside Room 241	6/6/13	3.1	
H.D. Cooke ES	2nd Floor, Inside Room 241	6/6/13	2	
H.D. Cooke ES	1st Floor, Inside Room 136	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 136	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 132	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 132	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 135	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 135	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 133	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Room 133	6/6/13	< 1	
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1	
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1	
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1	
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Gym (High)	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Gym (High)	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Gym (Low)	6/6/13	< 1	
H.D. Cooke ES	1st Floor, Inside Gym (Low)	6/6/13	< 1	
			Percentage of Passed Samples	98.39%
			Percentage of Failed Samples	1.61%
Hamilton School	1st Floor Hallway, by Corner of Kitchen	5/30/13	< 1	
Hamilton School	1st Floor Hallway, by Corner of Kitchen	5/30/13	1.2	
Hamilton School	1st Floor Hallway, Between Rooms 1019 & 1021	5/30/13	2.5	

Hamilton School	1st Floor Hallway, Between Rooms 1019 & 1021	5/30/13	5.4	
Hamilton School	1st Floor Hallway, by Room 1014	5/30/13	< 1	
Hamilton School	1st Floor Hallway, by Room 1014	5/30/13	< 1	
Hamilton School	1st Floor Hallway, by Boys Restroom	5/30/13	2.8	
Hamilton School	1st Floor Hallway, by Boys Restroom	5/30/13	2.8	
Hamilton School	2nd Floor Hallway, by Room 204	5/30/13	< 1	
Hamilton School	2nd Floor Hallway, by Room 204	5/30/13	< 1	
Hamilton School	2nd Floor Hallway, by Room 2020	5/30/13	< 1	
Hamilton School	2nd Floor Hallway, by Room 2020	5/30/13	< 1	
Hamilton School	2nd Floor, Inside Gym, by Boys Restroom	5/30/13	< 1	
Hamilton School	2nd Floor, Inside Gym, by Boys Restroom	5/30/13	< 1	
Hamilton School	2nd Floor Hallway, by Room 231 & Security Desk	5/30/13	< 1	
Hamilton School	2nd Floor Hallway, by Room 231 & Security Desk	5/30/13	< 1	
Hamilton School	2nd Floor, by Girls Restroom	5/30/13	< 1	
Hamilton School	2nd Floor, by Girls Restroom	5/30/13	< 1	
Hamilton School	2nd Floor, by Boys Restroom	5/30/13	1.1	
Hamilton School	2nd Floor, by Boys Restroom	5/30/13	1.3	
Hamilton School	2nd Floor, by Storage Rooms	5/30/13	< 1	
Hamilton School	2nd Floor, by Storage Rooms	5/30/13	< 1	
Hamilton School	2nd Floor, Inside Main Office	5/30/13	1.4	
Hamilton School	2nd Floor, Inside Main Office	5/30/13	1.6	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Hardy MS	3rd Floor Hallway, by Room 302 (High)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 302 (High)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 302 (Low)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 302 (Low)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 313 (High)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 313 (High)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 313 (Low)	5/2/13	< 1	
Hardy MS	3rd Floor Hallway, by Room 313 (Low)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 205 (High)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 205 (High)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 205 (Low)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 205 (Low)	5/2/13	< 1	
Hardy MS	2nd Floor, Inside Gymnasium (High)	5/2/13	< 1	
Hardy MS	2nd Floor, Inside Gymnasium (High)	5/2/13	< 1	
Hardy MS	2nd Floor, Inside Gymnasium (Low)	5/2/13	< 1	
Hardy MS	2nd Floor, Inside Gymnasium (Low)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 212 (High)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 212 (High)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 212 (Low)	5/2/13	< 1	
Hardy MS	2nd Floor Hallway, by Room 212 (Low)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 167 (High)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 167 (High)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 167 (Low)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 167 (Low)	5/2/13	< 1	
Hardy MS	1st Floor, Inside Cafeteria (High)	5/2/13	< 1	
Hardy MS	1st Floor, Inside Cafeteria (High)	5/2/13	< 1	
Hardy MS	1st Floor, Inside Cafeteria (Low)	5/2/13	< 1	
Hardy MS	1st Floor, Inside Cafeteria (Low)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 119 (High)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 119 (High)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 119 (Low)	5/2/13	< 1	
Hardy MS	1st Floor Hallway, by Room 119 (Low)	5/2/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (High)	3/18/13	< 1	
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (High)	3/18/13	< 1	
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (Low)	3/18/13	< 1	
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (Low)	3/18/13	< 1	
Harrison ES	Second Floor, Inside Room 201	3/18/13	< 1	
Harrison ES	Second Floor, Inside Room 201	3/18/13	< 1	

Harrison ES	Second Floor, Inside Room 203	3/18/13	< 1		
Harrison ES	Second Floor, Inside Room 203	3/18/13	< 1		
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (High)	3/18/13	< 1		
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (High)	3/18/13	< 1		
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (Low)	3/18/13	< 1		
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (Low)	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 109	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 109	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 107	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 107	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 103	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 103	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 101	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 101	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 133 (Right)	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 133 (Right)	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 133 (Left)	3/18/13	< 1		
Harrison ES	1st Floor, Inside Room 133 (Left)	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 22	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 22	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 23	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 23	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 26	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 26	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 27	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 27	3/18/13	< 1		
Harrison ES	Basement Hallway, by Room 5 (High)	3/18/13	< 1		
Harrison ES	Basement Hallway, by Room 5 (High)	3/18/13	< 1		
Harrison ES	Basement Hallway, by Room 5 (Low)	3/18/13	< 1		
Harrison ES	Basement Hallway, by Room 5 (Low)	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 5	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 5	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 1	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 1	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 3	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 3	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 6	3/18/13	< 1		
Harrison ES	Basement Floor, Inside Room 6	3/18/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Hart MS	2nd Floor Hallway, by Room 226 (High)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 226 (High)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 226 (Low)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 226 (Low)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 232 (High)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 232 (High)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 232 (Low)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 232 (Low)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 243 (High)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 243 (High)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 243 (Low)	5/22/13	< 1		
Hart MS	2nd Floor Hallway, by Room 243 (Low)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 119 (High)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 119 (High)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 119 (Low)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 119 (Low)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 123 (High)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 123 (High)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 123 (Low)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 123 (Low)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 131 (High)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 131 (High)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 131 (Low)	5/22/13	< 1		
Hart MS	1st Floor Hallway, by Room 131 (Low)	5/22/13	< 1		
Hart MS	1st Floor, Inside Gym, Boys Locker Room	5/22/13	< 1		

Hart MS	1st Floor, Inside Gym, Boys Locker Room	5/22/13	< 1		
Hart MS	1st Floor, Inside Gym, Girls Locker Room	5/22/13	< 1		
Hart MS	1st Floor, Inside Gym, Girls Locker Room	5/22/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Hearst ES	2nd Floor, by Room 206	2/25/13	< 1		
Hearst ES	2nd Floor, by Room 206	2/25/13	< 1		
Hearst ES	2nd Floor, by Room 200	2/25/13	< 1		
Hearst ES	2nd Floor, by Room 200	2/25/13	< 1		
Hearst ES	1st Floor, by Girls Restroom	2/25/13	< 1		
Hearst ES	1st Floor, by Girls Restroom	2/25/13	< 1		
Hearst ES	1st Floor, by Boys Restroom	2/25/13	< 1		
Hearst ES	1st Floor, by Boys Restroom	2/25/13	< 1		
Hearst ES	1st Floor, New Building, by Girls Restroom	2/25/13	< 1		
Hearst ES	1st Floor, New Building, by Girls Restroom	2/25/13	< 1		
Hearst ES	1st Floor, New Building, by Boys Restroom	2/25/13	< 1		
Hearst ES	1st Floor, New Building, by Boys Restroom	2/25/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Hendley ES	Ground Floor, Inside Cafeteria by Kitchen	3/12/13	< 1		
Hendley ES	Ground Floor, Inside Cafeteria by Kitchen	3/12/13	< 1		
Hendley ES	Ground Floor, by Boys Restroom	3/12/13	< 1		
Hendley ES	Ground Floor, by Boys Restroom	3/12/13	< 1		
Hendley ES	Ground Floor, by Teachers Restroom	3/12/13	< 1		
Hendley ES	Ground Floor, by Teachers Restroom	3/12/13	< 1		
Hendley ES	3rd Floor Hallway, Outside Teachers Restroom	3/12/13	< 1		
Hendley ES	3rd Floor Hallway, Outside Teachers Restroom	3/12/13	< 1		
Hendley ES	3rd Floor Hallway, by Room 306	3/12/13	< 1		
Hendley ES	3rd Floor Hallway, by Room 306	3/12/13	< 1		
Hendley ES	2nd Floor Hallway, by Room 206	3/12/13	< 1		
Hendley ES	2nd Floor Hallway, by Room 206	3/12/13	< 1		
Hendley ES	1st Floor, Inside Nurse's Suite	3/12/13	< 1		
Hendley ES	1st Floor, Inside Nurse's Suite	3/12/13	< 1		
Hendley ES	1st Floor Hallway, Outside Teachers' Lounge	3/12/13	< 1		
Hendley ES	1st Floor Hallway, Outside Teachers' Lounge	3/12/13	< 1		
Hendley ES	1st Floor Hallway, Outside Teachers Restroom	3/12/13	< 1		
Hendley ES	1st Floor Hallway, Outside Teachers Restroom	3/12/13	< 1		
Hendley ES	Ground Floor Annex Hallway, between Girls and Boys Restrooms	3/12/13	< 1		
Hendley ES	Ground Floor Annex Hallway, between Girls and Boys Restrooms	3/12/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Houston ES	1st Floor, Inside Lunch Room	1/21/14			
Houston ES	1st Floor, Inside Lunch Room	1/21/14			
Houston ES	1st Floor, by Room 156	1/21/14			
Houston ES	1st Floor, by Room 156	1/21/14			
Houston ES	1st Floor, by Room 148	1/21/14			
Houston ES	1st Floor, by Room 148	1/21/14			
Houston ES	1st Floor, by Room 147	1/21/14			
Houston ES	1st Floor, by Room 147	1/21/14			
Houston ES	1st Floor, by Teachers' Lounge	1/21/14			
Houston ES	1st Floor, by Teachers' Lounge	1/21/14			
Houston ES	1st Floor, in Teachers' Lounge	1/21/14			
Houston ES	1st Floor, in Teachers' Lounge	1/21/14			
Houston ES	1st Floor, by Room 105	1/21/14			
Houston ES	1st Floor, by Room 105	1/21/14			
Houston ES	1st Floor, by Room 112	1/21/14			
Houston ES	1st Floor, by Room 112	1/21/14			
Houston ES	2nd Floor, by Room 212	1/21/14			
Houston ES	2nd Floor, by Room 212	1/21/14			

Houston ES	2nd Floor, by Library	1/21/14			
Houston ES	2nd Floor, by Library	1/21/14			
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Hyde/Addison ES	Hyde 1st Floor, Next to Main Office	3/6/13	< 1		
Hyde/Addison ES	Hyde 1st Floor, Next to Main Office	3/6/13	< 1		
Hyde/Addison ES	Hyde 2nd Floor, Next to Teachers' Lounge	3/6/13	< 1		
Hyde/Addison ES	Hyde 2nd Floor, Next to Teachers' Lounge	3/6/13	< 1		
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (Low)	3/6/13	< 1		
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (Low)	3/6/13	< 1		
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (High)	3/6/13	< 1		
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (High)	3/6/13	< 1		
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (Low)	3/6/13	< 1		
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (Low)	3/6/13	< 1		
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (High)	3/6/13	< 1		
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (High)	3/6/13	< 1		
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (Low)	3/6/13	< 1		
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (Low)	3/6/13	< 1		
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (High)	3/6/13	< 1		
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (High)	3/6/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
J.O. Wilson ES	3rd Floor Hallway, Across from Room 301	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 301	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Next to Custodian's Closet (Room 312)	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Next to Custodian's Closet (Room 312)	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 309	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 309	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 329	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 329	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 328	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 328	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 321	5/20/13	< 1		
J.O. Wilson ES	3rd Floor Hallway, Across from Room 321	5/20/13	< 1		
J.O. Wilson ES	3rd Floor, Inside Room 322	5/20/13	< 1		
J.O. Wilson ES	3rd Floor, Inside Room 322	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Across from Room 201	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Across from Room 201	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Next to Custodian's Closet (Room 214)	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Next to Custodian's Closet (Room 214)	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Across from Room 223	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Across from Room 223	5/20/13	< 1		
J.O. Wilson ES	2nd Floor, Inside Room 222	5/20/13	< 1		
J.O. Wilson ES	2nd Floor, Inside Room 222	5/20/13	< 1		
J.O. Wilson ES	2nd Floor, Inside Room 221	5/20/13	< 1		
J.O. Wilson ES	2nd Floor, Inside Room 221	5/20/13	< 1		
J.O. Wilson ES	2nd Floor, Inside Room 220	5/20/13	< 1		
J.O. Wilson ES	2nd Floor, Inside Room 220	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Across from Room 220	5/20/13	< 1		
J.O. Wilson ES	2nd Floor Hallway, Across from Room 220	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Room 121	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Room 121	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 121	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 121	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 123	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 123	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Room 110	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Room 110	5/20/13	< 1		

J.O. Wilson ES	1st Floor, Inside Room 110	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 110	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 111	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 111	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 109	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 109	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 112	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Room 112	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Custodian's Closet (Room 114)	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Custodian's Closet (Room 114)	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Across from Main Office	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Across from Main Office	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Cafeteria	5/20/13	< 1		
J.O. Wilson ES	1st Floor, Inside Cafeteria	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Cafeteria	5/20/13	< 1		
J.O. Wilson ES	1st Floor Hallway, Next to Cafeteria	5/20/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Janney ES	1st Floor Hallway, Across from Office	2/11/13	< 1		
Janney ES	1st Floor Hallway, Across from Office	2/11/13	< 1		
Janney ES	1st Floor, Inside Health Suite	2/11/13	< 1		
Janney ES	1st Floor, Inside Health Suite	2/11/13	< 1		
Janney ES	1st Floor Hallway, Next to Room 107	2/11/13	< 1		
Janney ES	1st Floor Hallway, Next to Room 107	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 106	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 106	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 107	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 107	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 108	2/11/13	1.6		
Janney ES	1st Floor, Inside Room 108	2/11/13	1.2		
Janney ES	1st Floor, Inside Room 109	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 109	2/11/13	< 1		
Janney ES	1st Floor, New Wing, Inside Room 110 (High)	2/11/13	< 1		
Janney ES	1st Floor, New Wing, Inside Room 110 (High)	2/11/13	< 1		
Janney ES	1st Floor, New Wing, Inside Room 110 (Low)	2/11/13	< 1		
Janney ES	1st Floor, New Wing, Inside Room 110 (Low)	2/11/13	< 1		
Janney ES	1st Floor Hallway, Next to Room 110	2/11/13	< 1		
Janney ES	1st Floor Hallway, Next to Room 110	2/11/13	< 1		
Janney ES	1st Floor, New Wing, Inside Room 112	2/11/13	< 1		
Janney ES	1st Floor, New Wing, Inside Room 112	2/11/13	< 1		
Janney ES	Basement Floor Hallway, Across from Stairwell	2/11/13	< 1		
Janney ES	Basement Floor Hallway, Across from Stairwell	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (1)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (1)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (2)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (2)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (3)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (3)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (4)	2/11/13	< 1		
Janney ES	Basement Floor, Inside Room L10 (4)	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 113	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 113	2/11/13	< 1		
Janney ES	1st Floor Hallway, Across from Gymnasium (High)	2/11/13	< 1		
Janney ES	1st Floor Hallway, Across from Gymnasium (High)	2/11/13	< 1		
Janney ES	1st Floor Hallway, Across from Gymnasium (Low)	2/11/13	< 1		
Janney ES	1st Floor Hallway, Across from Gymnasium (Low)	2/11/13	< 1		

Janney ES	1st Floor, Inside Room 115	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 115	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 117	2/11/13	< 1		
Janney ES	1st Floor, Inside Room 117	2/11/13	< 1		
Janney ES	2nd Floor, Inside Teachers' Lounge	2/11/13	< 1		
Janney ES	2nd Floor, Inside Teachers' Lounge	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 212A	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 212A	2/11/13	< 1		
Janney ES	2nd Floor Hallway, Next to Room 210	2/11/13	< 1		
Janney ES	2nd Floor Hallway, Next to Room 210	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 209	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 209	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 208	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 208	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 206	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 206	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 207	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 207	2/11/13	< 1		
Janney ES	2nd Floor Hallway, Next to Room 207	2/11/13	< 1		
Janney ES	2nd Floor Hallway, Next to Room 207	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 202	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 202	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 203	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 203	2/11/13	< 1		
Janney ES	2nd Floor Hallway, Next to Room 203	2/11/13	< 1		
Janney ES	2nd Floor Hallway, Next to Room 203	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 201	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 201	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 200	2/11/13	< 1		
Janney ES	2nd Floor, Inside Room 200	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 300	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 300	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 301	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 301	2/11/13	< 1		
Janney ES	3rd Floor Hallway, Next to Room 303	2/11/13	< 1		
Janney ES	3rd Floor Hallway, Next to Room 303	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 303	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 303	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 302	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 302	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 304	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 304	2/11/13	< 1		
Janney ES	3rd Floor Hallway, Next to Room 307	2/11/13	< 1		
Janney ES	3rd Floor Hallway, Next to Room 307	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 307	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 307	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 306	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 306	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 309	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 309	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 308	2/11/13	< 1		
Janney ES	3rd Floor, Inside Room 308	2/11/13	< 1		
Janney ES	3rd Floor Hallway, Next to Room 310	2/11/13	< 1		
Janney ES	3rd Floor Hallway, Next to Room 310	2/11/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Jefferson MS	1st Floor Hallway, Next to Teachers' Lounge	5/9/13	< 1		
Jefferson MS	1st Floor Hallway, Next to Teachers' Lounge	5/9/13	< 1		
Jefferson MS	1st Floor Hallway, Next to Girls Restroom	5/9/13	< 1		
Jefferson MS	1st Floor Hallway, Next to Girls Restroom	5/9/13	< 1		
Jefferson MS	1st Floor Hallway, Across from Students' Lounge	5/9/13	< 1		
Jefferson MS	1st Floor Hallway, Across from Students' Lounge	5/9/13	< 1		
Jefferson MS	1st Floor, Inside Girls Locker Room	5/9/13	< 1		
Jefferson MS	1st Floor, Inside Girls Locker Room	5/9/13	< 1		
Jefferson MS	1st Floor, Inside Boys Locker Room	5/9/13	< 1		
Jefferson MS	1st Floor, Inside Boys Locker Room	5/9/13	< 1		

Jefferson MS	2nd Floor Hallway, Across from Room 206	5/9/13	< 1		
Jefferson MS	2nd Floor Hallway, Across from Room 206	5/9/13	< 1		
Jefferson MS	2nd Floor Hallway, Across from Room 218	5/9/13	< 1		
Jefferson MS	2nd Floor Hallway, Across from Room 218	5/9/13	< 1		
Jefferson MS	3rd Floor Hallway, Next to Girls Restroom	5/9/13	< 1		
Jefferson MS	3rd Floor Hallway, Next to Girls Restroom	5/9/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Johnson MS	4th Floor, Next to Elevator Area	1/24/13	< 1		
Johnson MS	4th Floor, Next to Elevator Area	1/24/13	< 1		
Johnson MS	4st Floor, by Girls Restroom	1/24/13	< 1		
Johnson MS	4st Floor, by Girls Restroom	1/24/13	< 1		
Johnson MS	3rd Floor, Next to Elevator Area	1/24/13	< 1		
Johnson MS	3rd Floor, Next to Elevator Area	1/24/13	< 1		
Johnson MS	3rd Floor, by Girls Restroom (High)	1/24/13	< 1		
Johnson MS	3rd Floor, by Girls Restroom (High)	1/24/13	< 1		
Johnson MS	3rd Floor, by Girls Restroom (Low)	1/24/13	< 1		
Johnson MS	3rd Floor, by Girls Restroom (Low)	1/24/13	< 1		
Johnson MS	2nd Floor, Next to Elevator Area	1/24/13	< 1		
Johnson MS	2nd Floor, Next to Elevator Area	1/24/13	< 1		
Johnson MS	2nd Floor, by Girls Restroom (High)	1/24/13	< 1		
Johnson MS	2nd Floor, by Girls Restroom (High)	1/24/13	< 1		
Johnson MS	2nd Floor, by Girls Restroom (Low)	1/24/13	< 1		
Johnson MS	2nd Floor, by Girls Restroom (Low)	1/24/13	< 1		
Johnson MS	1st Floor, Auditorium Hallway, by Exit Door	1/24/13	< 1		
Johnson MS	1st Floor, Auditorium Hallway, by Exit Door	1/24/13	< 1		
Johnson MS	1st Floor, by Girls Restroom (High)	1/24/13	< 1		
Johnson MS	1st Floor, by Girls Restroom (High)	1/24/13	< 1		
Johnson MS	1st Floor, by Girls Restroom (Low)	1/24/13	< 1		
Johnson MS	1st Floor, by Girls Restroom (Low)	1/24/13	< 1		
Johnson MS	1st Floor, Girls Locker Room Area	1/24/13	7.3		Filter was installed.
Johnson MS	1st Floor, Girls Locker Room Area	1/24/13	7.3		
Johnson MS	Basement Floor, Cafeteria, by Weight Room Door	1/24/13	< 1		
Johnson MS	Basement Floor, Cafeteria, by Weight Room Door	1/24/13	< 1		
Johnson MS	1st Floor, Adjacent to Gym Entrance	1/24/13	< 1		
Johnson MS	1st Floor, Adjacent to Gym Entrance	1/24/13	< 1		
Johnson MS	Basement Floor, Cafeteria, Outside Kitchen Area	1/24/13	< 1		
Johnson MS	Basement Floor, Cafeteria, Outside Kitchen Area	1/24/13	6.4		Filter was installed.
Johnson MS	Basement Floor, Inside Weight Room	1/24/13		35	Filter was installed.
Johnson MS	Basement Floor, Inside Weight Room	1/24/13	< 1		
Johnson MS	<i>Basement Floor, Inside Weight Room - Retest</i>	<i>2/7/13</i>	<i>< 1</i>		
Johnson MS	<i>Basement Floor, Inside Weight Room - Retest</i>	<i>2/7/13</i>	<i>< 1</i>		
Percentage of Passed Samples					97.06%
Percentage of Failed Samples					2.94%
K.C. Lewis ES	3rd Floor Hallway, Next to Utility Room 303	5/29/13	< 1		
K.C. Lewis ES	3rd Floor Hallway, Next to Utility Room 303	5/29/13	< 1		
K.C. Lewis ES	3rd Floor Hallway, Across from Room 315	5/29/13	< 1		
K.C. Lewis ES	3rd Floor Hallway, Across from Room 315	5/29/13	< 1		
K.C. Lewis ES	2nd Floor Hallway, Next to Room 211	5/29/13	< 1		
K.C. Lewis ES	2nd Floor Hallway, Next to Room 211	5/29/13	< 1		
K.C. Lewis ES	2nd Floor Hallway, Next to Boys Restroom	5/29/13	< 1		
K.C. Lewis ES	2nd Floor Hallway, Next to Boys Restroom	5/29/13	< 1		
K.C. Lewis ES	1st Floor Hallway, Near Storage Room 100	5/29/13	< 1		
K.C. Lewis ES	1st Floor Hallway, Near Storage Room 100	5/29/13	< 1		
K.C. Lewis ES	1st Floor Hallway, Next to Room 108 (Custodian's Closet)	5/29/13	< 1		
K.C. Lewis ES	1st Floor Hallway, Next to Room 108 (Custodian's Closet)	5/29/13	< 1		
K.C. Lewis ES	Inside Nurse's Office	5/29/13		200	Device was replaced.
K.C. Lewis ES	Inside Nurse's Office	5/29/13		70	
Percentage of Passed Samples					85.71%
Percentage of Failed Samples					14.29%

Kelly Miller MS	3rd Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Right of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Right of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Right of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Right of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Left of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Left of Elevator (Low)	5/3/13	< 1	
Kelly Miller MS	1st Floor, Inside Room 135	5/3/13	2.8	
Kelly Miller MS	1st Floor, Inside Room 135	5/3/13	1.4	
Kelly Miller MS	1st Floor, Inside Gymnasium	5/3/13	< 1	
Kelly Miller MS	1st Floor, Inside Gymnasium	5/3/13	< 1	
Kelly Miller MS	1st Floor, Inside Cafeteria	5/3/13	< 1	
Kelly Miller MS	1st Floor, Inside Cafeteria	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (High)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (High)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (Low)	5/3/13	< 1	
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (Low)	5/3/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Kenilworth ES	1st Floor, Inside Kindergarten	1/27/14	< 1	
Kenilworth ES	1st Floor, Inside Kindergarten	1/27/14	< 1	
Kenilworth ES	1st Floor, Inside Pre-K, Room 129	1/27/14	< 1	
Kenilworth ES	1st Floor, Inside Pre-K, Room 129	1/27/14	< 1	
Kenilworth ES	1st Floor Hallway, Outside All-Purpose Room	1/27/14	< 1	
Kenilworth ES	1st Floor Hallway, Outside All-Purpose Room	1/27/14	< 1	
Kenilworth ES	1st Floor, Inside Cafeteria	1/27/14	4	
Kenilworth ES	1st Floor, Inside Cafeteria	1/27/14	6.8	Filter was installed.
Kenilworth ES	1st Floor, Outside Teachers' Lounge	1/27/14	< 1	
Kenilworth ES	1st Floor, Outside Teachers' Lounge	1/27/14	< 1	
Kenilworth ES	1st Floor Hallway, Outside Room 100	1/27/14	< 1	
Kenilworth ES	1st Floor Hallway, Outside Room 100	1/27/14	< 1	
Kenilworth ES	1st Floor Hallway, Outside Room 108	1/27/14	< 1	
Kenilworth ES	1st Floor Hallway, Outside Room 108	1/27/14	< 1	
Kenilworth ES	2nd Floor Hallway, Outside Room 214	1/27/14	< 1	
Kenilworth ES	2nd Floor Hallway, Outside Room 214	1/27/14	< 1	
Kenilworth ES	2nd Floor Hallway, Outside Girls Restroom	1/27/14	< 1	
Kenilworth ES	2nd Floor Hallway, Outside Girls Restroom	1/27/14	< 1	
Kenilworth ES	2nd Floor Hallway, Outside Room 210	1/27/14	< 1	
Kenilworth ES	2nd Floor Hallway, Outside Room 210	1/27/14	< 1	
Kenilworth ES	3rd Floor Hallway, Outside Room 310	1/27/14	< 1	
Kenilworth ES	3rd Floor Hallway, Outside Room 310	1/27/14	< 1	
Kenilworth ES	1st Floor, Inside Health Suite	1/27/14	< 1	
Kenilworth ES	1st Floor, Inside Health Suite	1/27/14	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Ketcham ES	Inside Cafeteria	4/25/13	< 1	
Ketcham ES	Inside Cafeteria	4/25/13	< 1	
Ketcham ES	3rd Floor, Next to Boys Restroom	4/25/13	< 1	

Ketcham ES	3rd Floor, Next to Boys Restroom	4/25/13	1.8		
Ketcham ES	2nd Floor, Next to Boys Restroom	4/25/13	2.3		
Ketcham ES	2nd Floor, Next to Boys Restroom	4/25/13	4.9		
Ketcham ES	1st Floor, Inside Room B109	4/25/13	7.4		Filter was installed.
Ketcham ES	1st Floor, Inside Room B109	4/25/13	3.2		
Ketcham ES	1st Floor Hallway, Next to Room A101	4/25/13	< 1		
Ketcham ES	1st Floor Hallway, Next to Room A101	4/25/13	< 1		
Ketcham ES	1st Floor, Inside Room A1010	4/25/13	1.7		
Ketcham ES	1st Floor, Inside Room A1010	4/25/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Key ES	2nd Floor, Inside Room 201	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 201	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 202	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 202	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 203	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 203	3/8/13	< 1		
Key ES	2nd Floor, by Room 204	3/8/13	< 1		
Key ES	2nd Floor, by Room 204	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 204	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 204	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 206	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 206	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 205	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 205	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 207	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 207	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 208	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 208	3/8/13	< 1		
Key ES	2nd Floor, by Room 207	3/8/13	< 1		
Key ES	2nd Floor, by Room 207	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 210	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 210	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 209	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 209	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 212	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 212	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 211	3/8/13	< 1		
Key ES	2nd Floor, Inside Room 211	3/8/13	< 1		
Key ES	1st Floor, Inside Room 105	3/8/13	< 1		
Key ES	1st Floor, Inside Room 105	3/8/13	< 1		
Key ES	1st Floor, Inside Room 106	3/8/13	< 1		
Key ES	1st Floor, Inside Room 106	3/8/13	< 1		
Key ES	1st Floor, by Room 103	3/8/13	< 1		
Key ES	1st Floor, by Room 103	3/8/13	< 1		
Key ES	1st Floor, by Room 104	3/8/13	< 1		
Key ES	1st Floor, by Room 104	3/8/13	< 1		
Key ES	1st Floor, Inside Room 104	3/8/13	< 1		
Key ES	1st Floor, Inside Room 104	3/8/13	< 1		
Key ES	1st Floor, Inside Room 103	3/8/13	< 1		
Key ES	1st Floor, Inside Room 103	3/8/13	< 1		
Key ES	1st Floor, Inside Room 102	3/8/13	4.5		
Key ES	1st Floor, Inside Room 102	3/8/13	1.9		
Key ES	1st Floor, Inside Room 101	3/8/13	< 1		
Key ES	1st Floor, Inside Room 101	3/8/13	< 1		
Key ES	Basement Floor, Inside Boys Restroom	3/8/13	< 1		
Key ES	Basement Floor, Inside Boys Restroom	3/8/13	< 1		
Key ES	Basement Floor, on the Playground	3/8/13	< 1		
Key ES	Basement Floor, on the Playground	3/8/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Kramer MS	3rd Floor Hallway, Next to Room 317	5/7/13	< 1		
Kramer MS	3rd Floor Hallway, Next to Room 317	5/7/13	< 1		
Kramer MS	3rd Floor Hallway, Near Stairwell C	5/7/13	< 1		
Kramer MS	3rd Floor Hallway, Near Stairwell C	5/7/13	< 1		
Kramer MS	3rd Floor Hallway, Next to Room 306	5/7/13	< 1		
Kramer MS	3rd Floor Hallway, Next to Room 306	5/7/13	< 1		

Kramer MS	3rd Floor Hallway, Next to Room 305	5/7/13	< 1	
Kramer MS	3rd Floor Hallway, Next to Room 305	5/7/13	< 1	
Kramer MS	2nd Floor Hallway, Across from Girls Restroom	5/7/13	< 1	
Kramer MS	2nd Floor Hallway, Across from Girls Restroom	5/7/13	< 1	
Kramer MS	2nd Floor Hallway, Near Stairwell C	5/7/13	< 1	
Kramer MS	2nd Floor Hallway, Near Stairwell C	5/7/13	< 1	
Kramer MS	2nd Floor Hallway, Near Stairwell D	5/7/13	< 1	
Kramer MS	2nd Floor Hallway, Near Stairwell D	5/7/13	< 1	
Kramer MS	1st Floor Hallway, Next to Room 111A	5/7/13	< 1	
Kramer MS	1st Floor Hallway, Next to Room 111A	5/7/13	< 1	
Kramer MS	1st Floor Hallway, Across from Gym	5/7/13	< 1	
Kramer MS	1st Floor Hallway, Across from Gym	5/7/13	< 1	
Kramer MS	1st Floor Hallway, Across from Boys Restroom	5/7/13	< 1	
Kramer MS	1st Floor Hallway, Across from Boys Restroom	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Across from Teachers' Dining Room	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Across from Teachers' Dining Room	5/7/13	< 1	
Kramer MS	Inside Cafeteria at Exit, Near Boiler Room	5/7/13	< 1	
Kramer MS	Inside Cafeteria at Exit, Near Boiler Room	5/7/13	< 1	
Kramer MS	Inside Cafeteria, Other Side	5/7/13	< 1	
Kramer MS	Inside Cafeteria, Other Side	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Across from Storage Room 15	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Across from Storage Room 15	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Next to Storage Room 22	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Next to Storage Room 22	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Next to Custodian's Office	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Next to Custodian's Office	5/7/13	< 1	
Kramer MS	Basement Floor Hallway, Next to Room 14	5/7/13	2.8	
Kramer MS	Basement Floor Hallway, Next to Room 14	5/7/13	1.8	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Lafayette ES	1st Floor, East Learning Center, Behind Counter	4/22/13	< 1	
Lafayette ES	1st Floor, East Learning Center, Behind Counter	4/22/13	< 1	
Lafayette ES	1st Floor, Learning Center, Near Boys Restroom	4/22/13	< 1	
Lafayette ES	1st Floor, Learning Center, Near Boys Restroom	4/22/13	< 1	
Lafayette ES	1st Floor, Learning Center, Near Girls Restroom	4/22/13	< 1	
Lafayette ES	1st Floor, Learning Center, Near Girls Restroom	4/22/13	< 1	
Lafayette ES	1st Floor, West Learning Center, Behind Counter	4/22/13	< 1	
Lafayette ES	1st Floor, West Learning Center, Behind Counter	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, Opposite to Pearls Paradise Caffee	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, Opposite to Pearls Paradise Caffee	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, Opposite to Music Room	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, Opposite to Music Room	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 2	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 2	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 3	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 3	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 1	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 1	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 4	4/22/13	< 1	
Lafayette ES	1st Floor Hallway, by Stairwell 4	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 2	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 2	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 3	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 3	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 1	4/22/13	< 1	

Lafayette ES	2nd Floor Hallway, by Stairwell 1	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 4	4/22/13	< 1	
Lafayette ES	2nd Floor Hallway, by Stairwell 4	4/22/13	< 1	
Lafayette ES	Basement Hallway, by Girls Restroom	4/22/13	< 1	
Lafayette ES	Basement Hallway, by Girls Restroom	4/22/13	< 1	
Lafayette ES	Basement Hallway, by Lobby (High)	4/22/13	< 1	
Lafayette ES	Basement Hallway, by Lobby (High)	4/22/13	< 1	
Lafayette ES	Basement Hallway, by Lobby (Low)	4/22/13	< 1	
Lafayette ES	Basement Hallway, by Lobby (Low)	4/22/13	< 1	
Lafayette ES	1st Floor, Inside Nurse's Suite	4/22/13	< 1	
Lafayette ES	1st Floor, Inside Nurse's Suite	4/22/13	< 1	
Lafayette ES	Trailer Grade 4 Hallway (High)	4/22/13	< 1	
Lafayette ES	Trailer Grade 4 Hallway (High)	4/22/13	< 1	
Lafayette ES	Trailer Grade 4 Hallway (Low)	4/22/13	< 1	
Lafayette ES	Trailer Grade 4 Hallway (Low)	4/22/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Langdon ES	2nd Floor Hallway, by Teachers' and Boys' Restroom	4/12/13	< 1	
Langdon ES	2nd Floor Hallway, by Teachers' and Boys' Restroom	4/12/13	< 1	
Langdon ES	2nd Floor Hallway, by Teachers' and Girls' Restroom	4/12/13	< 1	
Langdon ES	2nd Floor Hallway, by Teachers' and Girls' Restroom	4/12/13	< 1	
Langdon ES	1st Floor Hallway, by Room 117, Custodian's Closet	4/12/13	< 1	
Langdon ES	1st Floor Hallway, by Room 117, Custodian's Closet	4/12/13	< 1	
Langdon ES	1st Floor Hallway, Between Boys and Girls Restroom	4/12/13	< 1	
Langdon ES	1st Floor Hallway, Between Boys and Girls Restroom	4/12/13	< 1	
Langdon ES	1st Floor, Inside Health Suite	4/12/13	< 1	
Langdon ES	1st Floor, Inside Health Suite	4/12/13	< 1	
Langdon ES	1st Floor Hallway, by Teachers' Restroom	4/12/13	< 1	
Langdon ES	1st Floor Hallway, by Teachers' Restroom	4/12/13	< 1	
Langdon ES	1st Floor, Inside Teachers' Lounge	4/12/13	< 1	
Langdon ES	1st Floor, Inside Teachers' Lounge	4/12/13	< 1	
Langdon ES	1st Floor Hallway, by Boys Restroom	4/12/13	< 1	
Langdon ES	1st Floor Hallway, by Boys Restroom	4/12/13	< 1	
Langdon ES	Basement Floor, Inside Lunch Room	4/12/13	< 1	
Langdon ES	Basement Floor, Inside Lunch Room	4/12/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Langley JHS	1st Floor Hallway, Across from Auditorium	1/22/13	< 1	
Langley JHS	1st Floor Hallway, Across from Auditorium	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 149	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 149	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 143	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 143	1/22/13	< 1	
Langley JHS	1st Floor, Inside Reading Class, Next to Room 133	1/22/13	< 1	
Langley JHS	1st Floor, Inside Reading Class, Next to Room 133	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 133	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 133	1/22/13	< 1	
Langley JHS	1st Floor, Teachers' Lounge	1/22/13	< 1	
Langley JHS	1st Floor, Teachers' Lounge	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 125	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 125	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 122	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 122	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 113	1/22/13	< 1	
Langley JHS	1st Floor, Inside Room 113	1/22/13	< 1	
Langley JHS	1st Floor Hallway, Near Room 106	1/22/13	< 1	
Langley JHS	1st Floor Hallway, Near Room 106	1/22/13	< 1	
Langley JHS	2nd Floor Hallway, Adjacent to Room 204	1/22/13	< 1	
Langley JHS	2nd Floor Hallway, Adjacent to Room 204	1/22/13	< 1	
Langley JHS	2nd Floor, Inside Room 208	1/22/13	< 1	

Langley JHS	2nd Floor, Inside Room 208	1/22/13	< 1		
Langley JHS	2nd Floor, Inside Room 211	1/22/13	< 1		
Langley JHS	2nd Floor, Inside Room 211	1/22/13	< 1		
Langley JHS	2nd Floor, Inside Room 217	1/22/13	< 1		
Langley JHS	2nd Floor, Inside Room 217	1/22/13	< 1		
Langley JHS	2nd Floor Hallway, Next to Room 201	1/22/13	< 1		
Langley JHS	2nd Floor Hallway, Next to Room 201	1/22/13	< 1		
Langley JHS	3rd Floor Hallway, Next to Room 301	1/22/13	< 1		
Langley JHS	3rd Floor Hallway, Next to Room 301	1/22/13	< 1		
Langley JHS	3rd Floor Hallway, Next to Room 304	1/22/13	< 1		
Langley JHS	3rd Floor Hallway, Next to Room 304	1/22/13	< 1		
Langley JHS	3rd Floor, Inside Teachers' Room	1/22/13	< 1		
Langley JHS	3rd Floor, Inside Teachers' Room	1/22/13	< 1		
Langley JHS	Basement Floor, Outside Girls Gym	1/22/13	< 1		
Langley JHS	Basement Floor, Outside Girls Gym	1/22/13	< 1		
Langley JHS	Basement Floor, Outside Boys Gym	1/22/13	< 1		
Langley JHS	Basement Floor, Outside Boys Gym	1/22/13	< 1		
Langley JHS	Sub-Basement Hallway, Stairwell 3, Outside Cafeteria	1/22/13	1.3		
Langley JHS	Sub-Basement Hallway, Stairwell 3, Outside Cafeteria	1/22/13	1.3		
Langley JHS	Sub-Basement Hallway, Stairwell 4, Outside Cafeteria	1/22/13	< 1		
Langley JHS	Sub-Basement Hallway, Stairwell 4, Outside Cafeteria	1/22/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Lasalle ES	Ground Floor, Inside Cafeteria	4/25/13	< 1		
Lasalle ES	Ground Floor, Inside Cafeteria	4/25/13	< 1		
Lasalle ES	Ground Floor Hallway, Outside Custodial's Office	4/25/13	< 1		
Lasalle ES	Ground Floor Hallway, Outside Custodial's Office	4/25/13	< 1		
Lasalle ES	3rd Floor, Outside Room 308	4/25/13	1.5		
Lasalle ES	3rd Floor, Outside Room 308	4/25/13	1.4		
Lasalle ES	3rd Floor, Outside Room 307	4/25/13	< 1		
Lasalle ES	3rd Floor, Outside Room 307	4/25/13	< 1		
Lasalle ES	2nd Floor, Outside Room 207	4/25/13	< 1		
Lasalle ES	2nd Floor, Outside Room 207	4/25/13	< 1		
Lasalle ES	2nd Floor, Outside Room 208	4/25/13	< 1		
Lasalle ES	2nd Floor, Outside Room 208	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 109	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 109	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 105	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 105	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 113	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 113	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 120	4/25/13	< 1		
Lasalle ES	1st Floor Hallway, Outside Room 120	4/25/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (Low)	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (Low)	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (High)	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (High)	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 111	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 111	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 113	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 113	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 125	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 125	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 116	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 116	2/12/14	< 1		
Leckie ES	1st Floor, Inside Room 122	2/12/14	1.7		

Leckie ES	1st Floor, Inside Room 122	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Room 122 (Low)	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Room 122 (Low)	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Room 122 (High)	2/12/14	< 1		
Leckie ES	1st Floor Hallway, Next to Room 122 (High)	2/12/14	< 1		
Leckie ES	Basement Floor, Inside Room 28	2/12/14	< 1		
Leckie ES	Basement Floor, Inside Room 28	2/12/14	< 1		
Leckie ES	Basement Floor, Inside Room 16	2/12/14		22	Filter was installed.
Leckie ES	Basement Floor, Inside Room 16	2/12/14	1.3		
Leckie ES	<i>Basement Floor, Inside Room 16</i>		< 1		
Leckie ES	<i>Basement Floor, Inside Room 16</i>		< 1		
Leckie ES	Basement Floor, Inside Room 14	2/12/14	2.3		
Leckie ES	Basement Floor, Inside Room 14	2/12/14	< 1		
Leckie ES	Basement Floor, Inside Room 12	2/12/14	2.7		
Leckie ES	Basement Floor, Inside Room 12	2/12/14	1.6		
Leckie ES	Basement Hallway, Next to Teachers' Restroom (Low)	2/12/14	< 1		
Leckie ES	Basement Hallway, Next to Teachers' Restroom (Low)	2/12/14	< 1		
Leckie ES	Basement Hallway, Next to Teachers' Restroom (High)	2/12/14	< 1		
Leckie ES	Basement Hallway, Next to Teachers' Restroom (High)	2/12/14	< 1		
Leckie ES	1st Floor, Inside Multi-Purpose Room	2/12/14	< 1		
Leckie ES	1st Floor, Inside Multi-Purpose Room	2/12/14	< 1		
Leckie ES	2nd Floor Hallway, Next to Room 212	2/12/14	< 1		
Leckie ES	2nd Floor Hallway, Next to Room 212	2/12/14	< 1		
Leckie ES	3rd Floor Hallway, Next to Room 309	2/12/14	< 1		
Leckie ES	3rd Floor Hallway, Next to Room 309	2/12/14	< 1		
Leckie ES	3rd Floor Hallway, Next to Teachers' Restroom	2/12/14	< 1		
Leckie ES	3rd Floor Hallway, Next to Teachers' Restroom	2/12/14	< 1		
				Percentage of Passed Samples	97.50%
				Percentage of Failed Samples	2.50%
Logan ES	2nd Floor Hallway, Across from Room 211	5/21/13	< 1		
Logan ES	2nd Floor Hallway, Across from Room 211	5/21/13	8.6		Filter was installed.
Logan ES	1st Floor Hallway, Next to Room 109	5/21/13	2.3		
Logan ES	1st Floor Hallway, Next to Room 109	5/21/13	2.8		
Logan ES	Inside Cafeteria	5/21/13	2.5		
Logan ES	Inside Cafeteria	5/21/13	3.9		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Ludlow Taylor ES	1st Floor Hallway, Lobby by Stairs	4/10/13	< 1		
Ludlow Taylor ES	1st Floor Hallway, Lobby by Stairs	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Health Suite	4/10/13	1.9		
Ludlow Taylor ES	1st Floor, Inside Health Suite	4/10/13	2.4		
Ludlow Taylor ES	1st Floor Hallway, by Room 101	4/10/13	< 1		
Ludlow Taylor ES	1st Floor Hallway, by Room 101	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Room 101	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Room 101	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Room 100	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Room 100	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Multi-Service Center	4/10/13	< 1		
Ludlow Taylor ES	1st Floor, Inside Multi-Service Center	4/10/13	< 1		
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 304	4/10/13	< 1		
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 304	4/10/13	< 1		
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 313	4/10/13	< 1		
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 313	4/10/13	< 1		
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 202	4/10/13	< 1		
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 202	4/10/13	< 1		
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 213	4/10/13	< 1		
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 213	4/10/13	< 1		
Ludlow Taylor ES	1st Floor Hallway, Entrance to Multi-Purpose Room	4/10/13	< 1		
Ludlow Taylor ES	1st Floor Hallway, Entrance to Multi-Purpose Room	4/10/13	< 1		
				Percentage of Passed Samples	100.00%

		Percentage of Failed Samples		0.00%	
Luke Moore Academy	2nd Floor Hallway, by Women's Restroom	5/17/13	< 1		
Luke Moore Academy	2nd Floor Hallway, by Women's Restroom	5/17/13	< 1		
Luke Moore Academy	2nd Floor Hallway, by Men's Restroom	5/17/13	< 1		
Luke Moore Academy	2nd Floor Hallway, by Men's Restroom	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, (High)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, (High)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, (Down)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, (Down)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, by Room B22 (High)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, by Room B22 (High)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, by Room B22 (Low)	5/17/13	< 1		
Luke Moore Academy	1st Floor Hallway, by Room B22 (Low)	5/17/13	< 1		
		Percentage of Passed Samples		100.00%	
		Percentage of Failed Samples		0.00%	
M.C. Terrell ES	Upper Ground Floor, Inside Teachers' Lounge	4/30/13	< 1		
M.C. Terrell ES	Upper Ground Floor, Inside Teachers' Lounge	4/30/13	< 1		
M.C. Terrell ES	Upper Ground Floor Hallway, by Storage Room	4/30/13	1.3		
M.C. Terrell ES	Upper Ground Floor Hallway, by Storage Room	4/30/13	1.2		
M.C. Terrell ES	3rd Floor Hallway, by Storage Room 317	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Storage Room 317	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Entrance to Learning Center	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Entrance to Learning Center	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Toilets	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Toilets	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Room 302	4/30/13	< 1		
M.C. Terrell ES	3rd Floor Hallway, by Room 302	4/30/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Stairs	4/30/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Stairs	4/30/13		15	Filter was installed.
M.C. Terrell ES	2nd Floor Hallway, by Room 201 - Retest	5/21/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Room 201 - Retest	5/21/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Room 201	4/30/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Room 201	4/30/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Restrooms	4/30/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Restrooms	4/30/13		16	Filter was installed
M.C. Terrell ES	2nd Floor Hallway, by Restrooms - Retest	5/21/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Restrooms - Retest	5/21/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Learning Area 215	4/30/13	< 1		
M.C. Terrell ES	2nd Floor Hallway, by Learning Area 215	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Storage Room 117	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Storage Room 117	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Learning Area 101	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Learning Area 101	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Restrooms	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Restrooms	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Learning Center 115	4/30/13	< 1		
M.C. Terrell ES	1st Floor Hallway, by Learning Center 115	4/30/13	< 1		
M.C. Terrell ES	Upper Ground, Inside All Purpose Room	4/30/13	< 1		
M.C. Terrell ES	Upper Ground, Inside All Purpose Room	4/30/13	< 1		
M.C. Terrell ES	Upper Ground Gym, Inside Girls Locker Room	4/30/13	2.8		
M.C. Terrell ES	Upper Ground Gym, Inside Girls Locker Room	4/30/13	3.6		
M.C. Terrell ES	Upper Ground Gym, Inside Boys Locker Room	4/30/13	3.3		
M.C. Terrell ES	Upper Ground Gym, Inside Boys Locker Room	4/30/13	2.8		
M.C. Terrell ES	Upper Ground, Inside Room EC2	4/30/13	< 1		
M.C. Terrell ES	Upper Ground, Inside Room EC2	4/30/13	< 1		
M.C. Terrell ES	Upper Ground, Inside Room EC4	4/30/13	< 1		
M.C. Terrell ES	Upper Ground, Inside Room EC4	4/30/13	< 1		
M.C. Terrell ES	Lower Ground Hallway, by Restrooms	4/30/13	< 1		
M.C. Terrell ES	Lower Ground Hallway, by Restrooms	4/30/13	< 1		
		Percentage of Passed Samples		95.00%	
		Percentage of Failed Samples		5.00%	
M.L. King ES	1st Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1		

M.L. King ES	1st Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1		
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (Low)	2/12/13	< 1		
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (Low)	2/12/13	< 1		
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (High)	2/12/13	< 1		
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (High)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Room 208 (Low)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Room 208 (Low)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Room 208 (High)	2/12/13	< 1		
M.L. King ES	2nd Floor Hallway, Next to Room 208 (High)	2/12/13	< 1		
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1		
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1		
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1		
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
MacFarland MS	3rd Floor Hallway, by Room 302	5/2/13	< 1		
MacFarland MS	3rd Floor Hallway, by Room 302	5/2/13	< 1		
MacFarland MS	2nd Floor Hallway, by Room 252	5/2/13	< 1		
MacFarland MS	2nd Floor Hallway, by Room 252	5/2/13	< 1		
MacFarland MS	2nd Floor Hallway, by Room 203	5/2/13	< 1		
MacFarland MS	2nd Floor Hallway, by Room 203	5/2/13	< 1		
MacFarland MS	1st Floor Hallway, by Adult Restroom	5/2/13	< 1		
MacFarland MS	1st Floor Hallway, by Adult Restroom	5/2/13	< 1		
MacFarland MS	1st Floor Hallway, by Room 152	5/2/13	< 1		
MacFarland MS	1st Floor Hallway, by Room 152	5/2/13	< 1		
MacFarland MS	1st Floor Hallway, by Room 158	5/2/13	< 1		
MacFarland MS	1st Floor Hallway, by Room 158	5/2/13	< 1		
MacFarland MS	Basement Floor, Inside Cafeteria	5/2/13	< 1		
MacFarland MS	Basement Floor, Inside Cafeteria	5/2/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Malcolm X ES	4th Floor, by Girls Restroom	4/15/13	< 1		
Malcolm X ES	4th Floor, by Girls Restroom	4/15/13	< 1		
Malcolm X ES	4th Floor, by Boys Restroom	4/15/13	< 1		
Malcolm X ES	4th Floor, by Boys Restroom	4/15/13	< 1		
Malcolm X ES	4th Floor, Inside Teachers' Lounge	4/15/13	7.5		Filter was installed.
Malcolm X ES	4th Floor, Inside Teachers' Lounge	4/15/13	7.1		
Malcolm X ES	3rd Floor, by Girls Restroom	4/15/13	< 1		
Malcolm X ES	3rd Floor, by Girls Restroom	4/15/13	< 1		
Malcolm X ES	3rd Floor, by Boys Restroom	4/15/13	< 1		
Malcolm X ES	3rd Floor, by Boys Restroom	4/15/13	< 1		
Malcolm X ES	3rd Floor, Inside Teachers' Lounge	4/15/13	1.2		
Malcolm X ES	3rd Floor, Inside Teachers' Lounge	4/15/13	< 1		
Malcolm X ES	2nd Floor, by Girls Restroom	4/15/13	< 1		
Malcolm X ES	2nd Floor, by Girls Restroom	4/15/13	< 1		
Malcolm X ES	2nd Floor, by Boys Restroom	4/15/13	< 1		
Malcolm X ES	2nd Floor, by Boys Restroom	4/15/13	< 1		
Malcolm X ES	1st Floor, by Restroom	4/15/13	< 1		
Malcolm X ES	1st Floor, by Restroom	4/15/13	< 1		
Malcolm X ES	1st Floor, In Open Space	4/15/13	< 1		

Malcolm X ES	1st Floor, In Open Space	4/15/13	< 1	
Malcolm X ES	1st Floor, by Lunch Room	4/15/13	< 1	
Malcolm X ES	1st Floor, by Lunch Room	4/15/13	< 1	
Malcolm X ES	1st Floor, by Main Lobby	4/15/13	< 1	
Malcolm X ES	1st Floor, by Main Lobby	4/15/13	< 1	
Malcolm X ES	1st Floor, Inside Health Suite	4/15/13	< 1	
Malcolm X ES	1st Floor, Inside Health Suite	4/15/13	< 1	
Malcolm X ES	1st Floor, by Exit	4/15/13	< 1	
Malcolm X ES	1st Floor, by Exit	4/15/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Mamie D Lee ES	1st Floor, Inside Room 11	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 11	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 13	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 13	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 10	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 10	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 12	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 12	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 15	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 15	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 17	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 17	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 14	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 14	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Teachers' Lounge	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Teachers' Lounge	1/16/13	< 1	
Mamie D Lee ES	2nd Floot, Inside Room 28	1/16/13	< 1	
Mamie D Lee ES	2nd Floot, Inside Room 28	1/16/13	< 1	
Mamie D Lee ES	2nd Floot, Inside Room 29	1/16/13	< 1	
Mamie D Lee ES	2nd Floot, Inside Room 29	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 26	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 26	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 24	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 24	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 27	1/16/13	1.8	
Mamie D Lee ES	2nd Floor, Inside Room 27	1/16/13	1.7	
Mamie D Lee ES	2nd Floor Hallway, Adjacent to Room 27	1/16/13	< 1	
Mamie D Lee ES	2nd Floor Hallway, Adjacent to Room 27	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 22	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 22	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 23	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 23	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 20	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 20	1/16/13	< 1	
Mamie D Lee ES	2nd Floor, Inside Room 21	1/16/13	2.3	
Mamie D Lee ES	2nd Floor, Inside Room 21	1/16/13	2.1	
Mamie D Lee ES	1st Floor, Inside Room 18	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 18	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 19	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Room 19	1/16/13	< 1	
Mamie D Lee ES	1st Floor Hallway, Outside Cafeteria	1/16/13	1.7	
Mamie D Lee ES	1st Floor Hallway, Outside Cafeteria	1/16/13	1.2	
Mamie D Lee ES	1st Floor, Cafeteria Kitchen	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Cafeteria Kitchen	1/16/13	< 1	
Mamie D Lee ES	1st Floor Hallway, Across from Room 15	1/16/13	1.3	
Mamie D Lee ES	1st Floor Hallway, Across from Room 15	1/16/13	1.3	
Mamie D Lee ES	1st Floor Cafeteria	1/16/13	< 1	
Mamie D Lee ES	1st Floor Cafeteria	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Health Suite	1/16/13	< 1	
Mamie D Lee ES	1st Floor, Inside Health Suite	1/16/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Mann ES	1st Floor Hallway, Next to Room 101	2/14/13	< 1	
Mann ES	1st Floor Hallway, Next to Room 101	2/14/13	< 1	
Mann ES	1st Floor Hallway, Across from Room 100	2/14/13	< 1	
Mann ES	1st Floor Hallway, Across from Room 100	2/14/13	< 1	

Mann ES	2nd Floor Hallway, Across from Room 200	2/14/13	< 1	
Mann ES	2nd Floor Hallway, Across from Room 200	2/14/13	2.2	
Mann ES	2nd Floor Hallway, Next to Room 205	2/14/13	< 1	
Mann ES	2nd Floor Hallway, Next to Room 205	2/14/13	< 1	
Mann ES	Community Center, Lunch Room	2/14/13	< 1	
Mann ES	Community Center, Lunch Room	2/14/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Marie Reed ES	2nd Floor Hallway, by Stairs and Toilet	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Stairs and Toilet	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #6	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #6	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #5	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #5	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #8	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #8	5/21/13	2.8	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #3	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #3	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #1	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #1	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #2	5/21/13	< 1	
Marie Reed ES	2nd Floor Hallway, by Arts & Science #2	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Storage #11	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Storage #11	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Girls Restroom	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Girls Restroom	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Lunch Room	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Lunch Room	5/21/13	1.1	
Marie Reed ES	1st Floor Hallway, by Men's Restroom and Stairs	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, by Men's Restroom and Stairs	5/21/13	< 1	
Marie Reed ES	1st Floor, Inside Teachers' Lounge	5/21/13	2	
Marie Reed ES	1st Floor, Inside Teachers' Lounge	5/21/13	2	
Marie Reed ES	1st Floor Hallway, Outside Main Office	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, Outside Main Office	5/21/13	< 1	
Marie Reed ES	1st Floor Hallway, Inside Main Office	5/21/13	1.2	
Marie Reed ES	1st Floor Hallway, Inside Main Office	5/21/13	1.9	
Marie Reed ES	1st Floor Halway, by Main Entrance	5/21/13	< 1	
Marie Reed ES	1st Floor Halway, by Main Entrance	5/21/13	< 1	
Marie Reed ES	Ground Floor, Inside Gym	5/21/13	< 1	
Marie Reed ES	Ground Floor, Inside Gym	5/21/13	< 1	
Marie Reed ES	Ground Floor Hallway, by Boys Restroom	5/21/13	4.6	
Marie Reed ES	Ground Floor Hallway, by Boys Restroom	5/21/13	2.7	
Marie Reed ES	Ground Floor, Gym Hallway, by Exit Door	5/21/13	< 1	
Marie Reed ES	Ground Floor, Gym Hallway, by Exit Door	5/21/13	< 1	
Marie Reed ES	Ground Floor Clinic Hallway, by Receptionist	5/21/13	< 1	
Marie Reed ES	Ground Floor Clinic Hallway, by Receptionist	5/21/13	< 1	
Marie Reed ES	Ground Floor Clinic Hallway, by Women's Restroom	5/21/13	2.6	
Marie Reed ES	Ground Floor Clinic Hallway, by Women's Restroom	5/21/13	1.4	
Marie Reed ES	Ground Floor Auditorium, by Stage	5/21/13	1.4	
Marie Reed ES	Ground Floor Auditorium, by Stage	5/21/13	1.8	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Marshall ES	Mezzanine Level, Next to Women's Restroom	5/31/13	< 1	
Marshall ES	Mezzanine Level, Next to Women's Restroom	5/31/13	< 1	
Marshall ES	Mezzanine Level, Next to Stairs	5/31/13	< 1	
Marshall ES	Mezzanine Level, Next to Stairs	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 1	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 1	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 2	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 2	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 5	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 5	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 4	5/31/13	< 1	
Marshall ES	Above Plaza Level, Next to Stairwell 4	5/31/13	< 1	
Marshall ES	Plaza Level, in Common Area (High)	5/31/13	< 1	

Marshall ES	Plaza Level, in Common Area (High)	5/31/13	< 1		
Marshall ES	Plaza Level, in Common Area (Low)	5/31/13	< 1		
Marshall ES	Plaza Level, in Common Area (Low)	5/31/13	< 1		
Marshall ES	Plaza Level, Inside Health Clinic, Next to Boys Restroom	5/31/13	< 1		
Marshall ES	Plaza Level, Inside Health Clinic, Next to Boys Restroom	5/31/13	< 1		
Marshall ES	Plaza Level, Stage 1, Next to Teacher's Restroom	5/31/13	< 1		
Marshall ES	Plaza Level, Stage 1, Next to Teacher's Restroom	5/31/13	< 1		
Marshall ES	Plaza Level, Stage 1, Next to Steps	5/31/13	< 1		
Marshall ES	Plaza Level, Stage 1, Next to Steps	5/31/13	< 1		
Marshall ES	Below Plaza Level, Next Boys Restroom (High)	5/31/13	< 1		
Marshall ES	Below Plaza Level, Next Boys Restroom (High)	5/31/13	< 1		
Marshall ES	Below Plaza Level, Next Boys Restroom (Low)	5/31/13	< 1		
Marshall ES	Below Plaza Level, Next Boys Restroom (Low)	5/31/13	< 1		
					100.00%
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Maury ES	1st Floor, Inside Cafeteria	1/28/14	< 1		
Maury ES	1st Floor, Inside Cafeteria	1/28/14	< 1		
Maury ES	1st Floor Main Hallway, Next to Room E125	1/28/14	< 1		
Maury ES	1st Floor Main Hallway, Next to Room E125	1/28/14	< 1		
Maury ES	1st Floor, Inside Room E125	1/28/14	< 1		
Maury ES	1st Floor, Inside Room E125	1/28/14	< 1		
Maury ES	1st Floor, Inside Room E140	1/28/14	< 1		
Maury ES	1st Floor, Inside Room E140	1/28/14	< 1		
Maury ES	1st Floor, Inside Room E135	1/28/14	< 1		
Maury ES	1st Floor, Inside Room E135	1/28/14	< 1		
Maury ES	2nd Floor, Inside Room E240	1/28/14	< 1		
Maury ES	2nd Floor, Inside Room E240	1/28/14	< 1		
Maury ES	2nd Floor, Inside Room E230	1/28/14	< 1		
Maury ES	2nd Floor, Inside Room E230	1/28/14	< 1		
Maury ES	2nd Floor Hallway, Across from Room E220 (Art Room)	1/28/14	< 1		
Maury ES	2nd Floor Hallway, Across from Room E220 (Art Room)	1/28/14	< 1		
Maury ES	2nd Floor, West Wing Hallway Stairwell	1/28/14	< 1		
Maury ES	2nd Floor, West Wing Hallway Stairwell	1/28/14	< 1		
Maury ES	1st Floor, West Wing Hallway Stairwell	1/28/14	< 1		
Maury ES	1st Floor, West Wing Hallway Stairwell	1/28/14	< 1		
Maury ES	Basement Floor, Inside Room W030 (West Wing)	1/28/14	< 1		
Maury ES	Basement Floor, Inside Room W030 (West Wing)	1/28/14	< 1		
Maury ES	Basement Floor, Inside Room W010 (West Wing)	1/28/14	< 1		
Maury ES	Basement Floor, Inside Room W010 (West Wing)	1/28/14	< 1		
Maury ES	Basement Hallway, Next to Room W022 (West Wing, High)	1/28/14	< 1		
Maury ES	Basement Hallway, Next to Room W022 (West Wing, High)	1/28/14	< 1		
Maury ES	Basement Hallway, Next to Room W022 (West Wing, Low)	1/28/14	< 1		
Maury ES	Basement Hallway, Next to Room W022 (West Wing, Low)	1/28/14	< 1		
					100.00%
Percentage of Failed Samples					0.00%
McKinley SHS	3rd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1		
McKinley SHS	3rd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1		
McKinley SHS	3rd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1		
McKinley SHS	3rd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1		
McKinley SHS	2nd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1		

McKinley SHS	2nd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1		
McKinley SHS	2nd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1		
McKinley SHS	2nd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1		
McKinley SHS	1st Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1		
McKinley SHS	1st Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1		
McKinley SHS	Inside Gym (Low)	6/11/13	< 1		
McKinley SHS	Inside Gym (Low)	6/11/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Meyer ES	2nd Floor Hallway, Next to Room 225	1/30/13	< 1		
Meyer ES	2nd Floor Hallway, Next to Room 225	1/30/13	< 1		
Meyer ES	2nd Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1		
Meyer ES	2nd Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1		
Meyer ES	2nd Floor Hallway, Next to Room 215	1/30/13	< 1		
Meyer ES	2nd Floor Hallway, Next to Room 215	1/30/13	< 1		
Meyer ES	1st Floor Hallway, Next to Room 115	1/30/13	< 1		
Meyer ES	1st Floor Hallway, Next to Room 115	1/30/13	< 1		
Meyer ES	1st Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1		
Meyer ES	1st Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1		
Meyer ES	1st Floor Hallway, Next to Health Suite	1/30/13	< 1		
Meyer ES	1st Floor Hallway, Next to Health Suite	1/30/13	< 1		
Meyer ES	Ground Floor, Between Boys and Girls Restroom	1/30/13	< 1		
Meyer ES	Ground Floor, Between Boys and Girls Restroom	1/30/13	< 1		
Meyer ES	Ground Floor, Across from Room G13	1/30/13	< 1		
Meyer ES	Ground Floor, Across from Room G13	1/30/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Miner ES	2nd Floor, by Boys Restroom (Low)	1/30/14	< 1		
Miner ES	2nd Floor, by Boys Restroom (Low)	1/30/14	< 1		
Miner ES	2nd Floor, by Boys Restroom (High)	1/30/14	< 1		
Miner ES	2nd Floor, by Boys Restroom (High)	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 209	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 209	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 211	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 211	1/30/14	< 1		
Miner ES	2nd Floor, by Room 211	1/30/14	< 1		
Miner ES	2nd Floor, by Room 211	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 213	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 213	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 215	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 215	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 217	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 217	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 219	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 219	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 225	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 225	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 227	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 227	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 229	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 229	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 231	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 231	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 233	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 233	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 241	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 241	1/30/14	< 1		
Miner ES	2nd Floor, Inside Room 243	1/30/14	< 1		

Moten ES	3rd Floor Hallway, by Room 327	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 327	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 317	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 317	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 314 (High)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 314 (High)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 314 (Low)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 314 (Low)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 301 (High)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 301 (High)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 301 (Low)	4/11/13	< 1		
Moten ES	3rd Floor Hallway, by Room 301 (Low)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 202 (High)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 202 (High)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 202 (Low)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 202 (Low)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 211 (High)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 211 (High)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 211 (Low)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 211 (Low)	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 219	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 219	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 224B	4/11/13	< 1		
Moten ES	2nd Floor Hallway, by Room 224B	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 134	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 134	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 124	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 124	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 129 (High)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 129 (High)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 129 (Low)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 129 (Low)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 103 (High)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 103 (High)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 103 (Low)	4/11/13	< 1		
Moten ES	1st Floor Hallway, by Room 103 (Low)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G06 (High)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G06 (High)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G06 (Low)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G06 (Low)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G10 (High)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G10 (High)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G10 (Low)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G10 (Low)	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G25	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G25	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G31	4/11/13	< 1		
Moten ES	Ground Floor Hallway, by Room G31	4/11/13	< 1		
Moten ES	Basement Floor Hallway, by Room B10	4/11/13	< 1		
Moten ES	Basement Floor Hallway, by Room B10	4/11/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Murch ES	1st Floor, Next to Room 104	2/8/13	< 1		
Murch ES	1st Floor, Next to Room 104	2/8/13	< 1		
Murch ES	1st Floor, Next to Room 102	2/8/13	< 1		
Murch ES	1st Floor, Next to Room 102	2/8/13	< 1		
Murch ES	2nd Floor Hallway, by Room 200A	2/8/13	< 1		
Murch ES	2nd Floor Hallway, by Room 200A	2/8/13	< 1		
Murch ES	2nd Floor Hallway, by Room 208	2/8/13	< 1		
Murch ES	2nd Floor Hallway, by Room 208	2/8/13	< 1		
Murch ES	2nd Floor Hallway, by Room 205	2/8/13	< 1		
Murch ES	2nd Floor Hallway, by Room 205	2/8/13	< 1		
Murch ES	1st Floor Hallway, by Room 101	2/8/13	< 1		
Murch ES	1st Floor Hallway, by Room 101	2/8/13	< 1		
Murch ES	1st Floor, Inside Gymnasium	2/8/13	< 1		
Murch ES	1st Floor, Inside Gymnasium	2/8/13	< 1		
Murch ES	Annex Building, Next to Room K3	2/8/13	< 1		

Murch ES	Annex Building, Next to Room K3	2/8/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Nalle ES	2nd Floor Hallway, Outside Room 214 (High)	3/25/13	< 1		
Nalle ES	2nd Floor Hallway, Outside Room 214 (High)	3/25/13	< 1		
Nalle ES	2nd Floor Hallway, Outside Room 214 (Low)	3/25/13	< 1		
Nalle ES	2nd Floor Hallway, Outside Room 214 (Low)	3/25/13	< 1		
Nalle ES	2nd Floor Hallway, by Boys Restroom	3/25/13	< 1		
Nalle ES	2nd Floor Hallway, by Boys Restroom	3/25/13	< 1		
Nalle ES	1st Floor Hallway, by Boys Restroom	3/25/13	< 1		
Nalle ES	1st Floor Hallway, by Boys Restroom	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 130	3/25/13	3.2		
Nalle ES	1st Floor, Inside Room 130	3/25/13	1.3		
Nalle ES	1st Floor, Inside Room 132	3/25/13	2		
Nalle ES	1st Floor, Inside Room 132	3/25/13	1.3		
Nalle ES	1st Floor, Inside Room 123	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 123	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 104	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 104	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 107	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 107	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 110	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 110	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 106	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 106	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 112	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 112	3/25/13	< 1		
Nalle ES	1st Floor Hallway, Opposite to Room 112 (High)	3/25/13	< 1		
Nalle ES	1st Floor Hallway, Opposite to Room 112 (High)	3/25/13	< 1		
Nalle ES	1st Floor Hallway, Opposite to Room 112 (Low)	3/25/13	< 1		
Nalle ES	1st Floor Hallway, Opposite to Room 112 (Low)	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 118	3/25/13	6.7		Filter was installed.
Nalle ES	1st Floor, Inside Room 118	3/25/13	4.8		
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (High)	3/25/13	< 1		
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (High)	3/25/13	< 1		
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (Low)	3/25/13	< 1		
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (Low)	3/25/13	< 1		
Nalle ES	1st Floor, Inside Room 128	3/25/13	3.9		
Nalle ES	1st Floor, Inside Room 128	3/25/13	2.8		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Noyes ES	1st Floor, Inside Room 134	3/12/13	4.4		
Noyes ES	1st Floor, Inside Room 134	3/12/13	1.1		
Noyes ES	1st Floor, Inside Room 132	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 132	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 133	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 133	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 135	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 135	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 131	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 131	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 129	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 129	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 128	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 128	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 130	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 130	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 116 (High)	3/12/13	2.2		
Noyes ES	1st Floor Hallway, Next to Room 116 (High)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 116 (Low)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 116 (Low)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Auditorium (High)	3/12/13	< 1		

Noyes ES	1st Floor Hallway, Next to Auditorium (High)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Auditorium (Low)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Auditorium (Low)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 108 (High)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 108 (High)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 108 (Low)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Room 108 (Low)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Elevator (High)	3/12/13	< 1		
Noyes ES	1st Floor Hallway, Next to Elevator (High)	3/12/13	1		
Noyes ES	1st Floor Hallway, Next to Elevator (Low)	3/12/13	3.6		
Noyes ES	1st Floor Hallway, Next to Elevator (Low)	3/12/13	< 1		
Noyes ES	2nd Floor Hallway, Next to Room 202 (High)	3/12/13	< 1		
Noyes ES	2nd Floor Hallway, Next to Room 202 (High)	3/12/13	< 1		
Noyes ES	2nd Floor Hallway, Next to Room 202 (Low)	3/12/13	< 1		
Noyes ES	2nd Floor Hallway, Next to Room 202 (Low)	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Ms. Lilly's Room, Next to Room 205	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Ms. Lilly's Room, Next to Room 205	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 205	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 205	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Ms. Dorth's Room, Next to Room 204	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Ms. Dorth's Room, Next to Room 204	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 204	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 204	3/12/13	1.9		
Noyes ES	2nd Floor, Inside Room 213	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 213	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 216	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 216	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 214	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 214	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 112	3/12/13	< 1		
Noyes ES	1st Floor, Inside Room 112	3/12/13	< 1		
Noyes ES	2nd Floor, Inside Room 212	3/12/13	1.1		
Noyes ES	2nd Floor, Inside Room 212	3/12/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Orr ES	4th Floor Hallway, Next to Boys Restroom	1/31/13	< 1		
Orr ES	4th Floor Hallway, Next to Boys Restroom	1/31/13	< 1		
Orr ES	4th Floor Hallway, Next to Girls Restroom	1/31/13	< 1		
Orr ES	4th Floor Hallway, Next to Girls Restroom	1/31/13	< 1		
Orr ES	3rd Floor Hallway, Next to Boys Restroom	1/31/13	< 1		
Orr ES	3rd Floor Hallway, Next to Boys Restroom	1/31/13	< 1		
Orr ES	3rd Floor Hallway, Next to Girls Restroom	1/31/13	< 1		
Orr ES	3rd Floor Hallway, Next to Girls Restroom	1/31/13	< 1		
Orr ES	2nd Floor Hallway, Next to Boys Restroom	1/31/13	< 1		
Orr ES	2nd Floor Hallway, Next to Boys Restroom	1/31/13	< 1		
Orr ES	2nd Floor Hallway, Next to Girls Restroom	1/31/13	< 1		
Orr ES	2nd Floor Hallway, Next to Girls Restroom	1/31/13	< 1		
Orr ES	1st Floor Hallway, Next to Parents' Resource Room	1/31/13	< 1		
Orr ES	1st Floor Hallway, Next to Parents' Resource Room	1/31/13	< 1		
Orr ES	1st Floor, Inside Gym, Next to Supply Room	1/31/13	< 1		
Orr ES	1st Floor, Inside Gym, Next to Supply Room	1/31/13	< 1		
Orr ES	1st Floor, Inside Gym, Next to Girls Restroom	1/31/13	< 1		
Orr ES	1st Floor, Inside Gym, Next to Girls Restroom	1/31/13	< 1		
Orr ES	1st Floor, Inside Gym, Next to Kitchen	1/31/13	< 1		
Orr ES	1st Floor, Inside Gym, Next to Kitchen	1/31/13	< 1		
Orr ES	1st Floor Hallway, Next to Teachers' Lounge	1/31/13	< 1		
Orr ES	1st Floor Hallway, Next to Teachers' Lounge	1/31/13	< 1		
Orr ES	1st Floor, Inside Kindergarten Room 135	1/31/13	< 1		
Orr ES	1st Floor, Inside Kindergarten Room 135	1/31/13	< 1		
Orr ES	1st Floor, Inside Kindergarten Room 131	1/31/13	< 1		
Orr ES	1st Floor, Inside Kindergarten Room 131	1/31/13	< 1		

Orr ES	1st Floor, Inside Pre-K Room 124	1/31/13	1.5	
Orr ES	1st Floor, Inside Pre-K Room 124	1/31/13	1.6	
Orr ES	1st Floor, Inside Pre-K Room 121	1/31/13	< 1	
Orr ES	1st Floor, Inside Pre-K Room 121	1/31/13	< 1	
Orr ES	1st Floor, Across from Main Office	1/31/13	< 1	
Orr ES	1st Floor, Across from Main Office	1/31/13	< 1	
Orr ES	1st Floor, Inside Health Suite	1/31/13	< 1	
Orr ES	1st Floor, Inside Health Suite	1/31/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Oyster ES	4th Floor, Inside Room 415	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 415	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 412	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 412	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 410	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 410	3/12/13	< 1	
Oyster ES	4th Floor, by Room 409 (Low)	3/12/13	< 1	
Oyster ES	4th Floor, by Room 409 (Low)	3/12/13	< 1	
Oyster ES	4th Floor, by Room 409 (High)	3/12/13	< 1	
Oyster ES	4th Floor, by Room 409 (High)	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 407	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 407	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 405	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 405	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 401	3/12/13	< 1	
Oyster ES	4th Floor, Inside Room 401	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 316	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 316	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 313	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 313	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 309	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 309	3/12/13	< 1	
Oyster ES	3rd Floor, by Room 309 (Low)	3/12/13	< 1	
Oyster ES	3rd Floor, by Room 309 (Low)	3/12/13	< 1	
Oyster ES	3rd Floor, by Room 309 (High)	3/12/13	< 1	
Oyster ES	3rd Floor, by Room 309 (High)	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 308	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 308	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 304	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 304	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 301	3/12/13	< 1	
Oyster ES	3rd Floor, Inside Room 301	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 211	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 211	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 210	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 210	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 202	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 202	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 201	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Room 201	3/12/13	< 1	
Oyster ES	2nd Floor, by Room 206 (Low)	3/12/13	< 1	
Oyster ES	2nd Floor, by Room 206 (Low)	3/12/13	< 1	
Oyster ES	2nd Floor, by Room 206 (High)	3/12/13	< 1	
Oyster ES	2nd Floor, by Room 206 (High)	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Gymnasium (Low)	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Gymnasium (Low)	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Gymnasium (High)	3/12/13	< 1	
Oyster ES	2nd Floor, Inside Gymnasium (High)	3/12/13	< 1	
Oyster ES	1st Floor, Inside Room 104	3/12/13	< 1	
Oyster ES	1st Floor, Inside Room 104	3/12/13	< 1	
Oyster ES	1st Floor, by Room 105 (Low)	3/12/13	< 1	
Oyster ES	1st Floor, by Room 105 (Low)	3/12/13	< 1	
Oyster ES	1st Floor, by Room 105 (High)	3/12/13	< 1	
Oyster ES	1st Floor, by Room 105 (High)	3/12/13	< 1	
Oyster ES	1st Floor, Inside Room 107	3/12/13	< 1	
Oyster ES	1st Floor, Inside Room 107	3/12/13	< 1	
Percentage of Passed Samples				100.00%

		Percentage of Failed Samples			0.00%
Parkview ES	2nd Floor, by Room 213	3/15/13	< 1		
Parkview ES	2nd Floor, by Room 213	3/15/13	< 1		
Parkview ES	2nd Floor, by Room 201	3/15/13	< 1		
Parkview ES	2nd Floor, by Room 201	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 121	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 121	3/15/13	< 1		
Parkview ES	1st Floor, by Main Office	3/15/13	< 1		
Parkview ES	1st Floor, by Main Office	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 122	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 122	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 123	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 123	3/15/13	< 1		
Parkview ES	1st Floor, by Room 127	3/15/13	< 1		
Parkview ES	1st Floor, by Room 127	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 126	3/15/13	< 1		
Parkview ES	1st Floor, Inside Room 126	3/15/13	< 1		
Parkview ES	1st Floor, by Room 134	3/15/13	< 1		
Parkview ES	1st Floor, by Room 134	3/15/13	< 1		
Parkview ES	2nd Floor, Inside Room 221	3/15/13	< 1		
Parkview ES	2nd Floor, Inside Room 221	3/15/13	< 1		
Parkview ES	Basement Floor, by Gymnasium	3/15/13	< 1		
Parkview ES	Basement Floor, by Gymnasium	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 21	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 21	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 22	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 22	3/15/13	< 1		
Parkview ES	Basement Floor, by Room 21	3/15/13	< 1		
Parkview ES	Basement Floor, by Room 21	3/15/13	1.1		
Parkview ES	Basement Floor, Inside Room 24	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 24	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 06	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 06	3/15/13	< 1		
Parkview ES	Basement Floor, by Room 06	3/15/13	< 1		
Parkview ES	Basement Floor, by Room 06	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 07	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 07	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 08	3/15/13	< 1		
Parkview ES	Basement Floor, Inside Room 08	3/15/13	< 1		
Parkview ES	Basement Floor, by Lunch Room	3/15/13	< 1		
Parkview ES	Basement Floor, by Lunch Room	3/15/13	< 1		
		Percentage of Passed Samples			100.00%
		Percentage of Failed Samples			0.00%
Patterson MS	3rd Floor, Inside Room 323	2/21/13	< 1		
Patterson MS	3rd Floor, Inside Room 323	2/21/13	< 1		
Patterson MS	3rd Floor, Inside Room 324	2/21/13	< 1		
Patterson MS	3rd Floor, Inside Room 324	2/21/13	< 1		
Patterson MS	3rd Floor, Inside Room 317	2/21/13	< 1		
Patterson MS	3rd Floor, Inside Room 317	2/21/13	< 1		
Patterson MS	3rd Floor, Inside Room 316	2/21/13	5.9		
Patterson MS	3rd Floor, Inside Room 316	2/21/13	7.3		Filter was installed.
Patterson MS	3rd Floor, Inside Room 307	2/21/13	2.4		
Patterson MS	3rd Floor, Inside Room 307	2/21/13	1.5		
Patterson MS	3rd Floor, Inside Room 312	2/21/13	1.7		
Patterson MS	3rd Floor, Inside Room 312	2/21/13	1.9		
Patterson MS	3rd Floor, Inside Room 311	2/21/13	3		
Patterson MS	3rd Floor, Inside Room 311	2/21/13		25	Filter was installed.
Patterson MS	<i>3rd Floor, Inside Room 311 - Retest</i>	<i>2/27/13</i>	< 1		
Patterson MS	<i>3rd Floor, Inside Room 311 - Retest</i>	<i>2/27/13</i>	< 1		
Patterson MS	3rd Floor, by Room 302 (High)	2/21/13	< 1		
Patterson MS	3rd Floor, by Room 302 (High)	2/21/13	< 1		
Patterson MS	3rd Floor, by Room 302 (Low)	2/21/13	< 1		
Patterson MS	3rd Floor, by Room 302 (Low)	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 222	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 222	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 223	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 223	2/21/13	< 1		

Patterson MS	2nd Floor, Inside Room 221	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 221	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 224	2/21/13	1.1		
Patterson MS	2nd Floor, Inside Room 224	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 225	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 225	2/21/13	1.3		
Patterson MS	2nd Floor, Inside Room 230	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 230	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 232	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 232	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 213	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 213	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 216	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 216	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 214	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 214	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 215	2/21/13	< 1		
Patterson MS	2nd Floor, Inside Room 215	2/21/13	< 1		
Patterson MS	2nd Floor, Opposite to Room 208B (High)	2/21/13	< 1		
Patterson MS	2nd Floor, Opposite to Room 208B (High)	2/21/13	< 1		
Patterson MS	2nd Floor, Opposite to Room 208B (Low)	2/21/13	< 1		
Patterson MS	2nd Floor, Opposite to Room 208B (Low)	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 119	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 119	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 120	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 120	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 123	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 123	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 115	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 115	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 125	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 125	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 132	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 132	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 131	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 131	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 127	2/21/13	< 1		
Patterson MS	1st Floor, inside Room 127	2/21/13	< 1		
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1		
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1		
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1		
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1		
				Percentage of Passed Samples	98.61%
				Percentage of Failed Samples	1.39%
Payne ES	1st Floor Hallway, Next to Room 27	3/21/13	< 1		
Payne ES	1st Floor Hallway, Next to Room 27	3/21/13	< 1		
Payne ES	1st Floor, Inside Room 12	3/21/13	1.2		
Payne ES	1st Floor, Inside Room 12	3/21/13	1.8		
Payne ES	1st Floor, Inside Lunch Room	3/21/13	< 1		
Payne ES	1st Floor, Inside Lunch Room	3/21/13	< 1		
Payne ES	1st Floor, Inside Room 64	3/21/13	4.1		
Payne ES	1st Floor, Inside Room 64	3/21/13	1.9		
Payne ES	1st Floor, Inside Room 110	3/21/13	1.4		
Payne ES	1st Floor, Inside Room 110	3/21/13	1.6		
Payne ES	1st Floor, Inside Room 104	3/21/13	2.4		
Payne ES	1st Floor, Inside Room 104	3/21/13	1.9		
Payne ES	2nd Floor, Next to Room 132	3/21/13	< 1		
Payne ES	2nd Floor, Next to Room 132	3/21/13	< 1		
Payne ES	2nd Floor, Next to Room 142	3/21/13	< 1		
Payne ES	2nd Floor, Next to Room 142	3/21/13	< 1		
Payne ES	1st Floor, Next to Room 90	3/21/13	< 1		
Payne ES	1st Floor, Next to Room 90	3/21/13	< 1		
Payne ES	1st Floor, Next to Room 114	3/21/13	< 1		
Payne ES	1st Floor, Next to Room 114	3/21/13	< 1		
Payne ES	3rd Floor, Next to Room 169	3/21/13	< 1		
Payne ES	3rd Floor, Next to Room 169	3/21/13	< 1		
Payne ES	3rd Floor, Next to Room 174	3/21/13	< 1		

Payne ES	3rd Floor, Next to Room 174	3/21/13	< 1		
Payne ES	2nd Floor, Next to Room 129	3/21/13	< 1		
Payne ES	2nd Floor, Next to Room 129	3/21/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Peabody ES	3rd Floor Hallway, Outside Room 10	3/5/13	< 1		
Peabody ES	3rd Floor Hallway, Outside Room 10	3/5/13	< 1		
Peabody ES	2nd Floor Hallway, Outside Teachers' Lounge	3/5/13	< 1		
Peabody ES	2nd Floor Hallway, Outside Teachers' Lounge	3/5/13	< 1		
Peabody ES	1st Floor Hallway, Outside Main Office	3/5/13	< 1		
Peabody ES	1st Floor Hallway, Outside Main Office	3/5/13	< 1		
Peabody ES	Basement Floor, at Entrance to Boys Restroom	3/5/13	< 1		
Peabody ES	Basement Floor, at Entrance to Boys Restroom	3/5/13	< 1		
Peabody ES	Basement Floor, at Entrance to Girls Restroom	3/5/13	< 1		
Peabody ES	Basement Floor, at Entrance to Girls Restroom	3/5/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Phelps HS	1st Floor Hallway, by Room C108	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room C108	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room C110	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room C110	6/5/13	< 1		
Phelps HS	2nd Floor Hallway, by Room C211	6/5/13	< 1		
Phelps HS	2nd Floor Hallway, by Room C211	6/5/13	< 1		
Phelps HS	2nd Floor Hallway, by Room C207	6/5/13	< 1		
Phelps HS	2nd Floor Hallway, by Room C207	6/5/13	< 1		
Phelps HS	2nd Floor Hallway, by Room C206	6/5/13	< 1		
Phelps HS	2nd Floor Hallway, by Room C206	6/5/13	< 1		
Phelps HS	Basement Floor Hallway, by Room S005	6/5/13	< 1		
Phelps HS	Basement Floor Hallway, by Room S005	6/5/13	< 1		
Phelps HS	Basement Floor Hallway, by Room S001	6/5/13	< 1		
Phelps HS	Basement Floor Hallway, by Room S001	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room T104	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room T104	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room T106	6/5/13	< 1		
Phelps HS	1st Floor Hallway, by Room T106	6/5/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Plummer ES	1st Floor Hallway, Outside Main Office	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Main Office	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Room 134	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Room 134	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Girls Restroom	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Girls Restroom	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Room 139	5/13/13	< 1		
Plummer ES	1st Floor Hallway, Outside Room 139	5/13/13	< 1		
Plummer ES	3rd Floor Hallway, by Room 219	5/13/13	< 1		
Plummer ES	3rd Floor Hallway, by Room 219	5/13/13	3.5		
Plummer ES	3rd Floor Hallway, by Teachers' Restroom	5/13/13	1.8		
Plummer ES	3rd Floor Hallway, by Teachers' Restroom	5/13/13	2.4		
Plummer ES	3rd Floor Hallway, by Boys Restroom	5/13/13	1.2		
Plummer ES	3rd Floor Hallway, by Boys Restroom	5/13/13	2.4		
Plummer ES	3rd Floor Hallway, by Room 212	5/13/13	< 1		
Plummer ES	3rd Floor Hallway, by Room 212	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, Outside Library	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, Outside Library	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, by Room 127	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, by Room 127	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, by Boys Restroom	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, by Boys Restroom	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, by Room 132	5/13/13	< 1		
Plummer ES	2nd Floor Hallway, by Room 132	5/13/13	< 1		
Plummer ES	2nd Floor, Inside Pre-K Room 116	5/13/13	6.1		Filter was installed.
Plummer ES	2nd Floor, Inside Pre-K Room 116	5/13/13	1.6		
Plummer ES	2nd Floor, Inside Pre-K Room 109	5/13/13	< 1		
Plummer ES	2nd Floor, Inside Pre-K Room 109	5/13/13	< 1		

Plummer ES	2nd Floor, Inside Lunch Room	5/13/13	< 1		
Plummer ES	2nd Floor, Inside Lunch Room	5/13/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Powell ES	1st Floor, Inside Room 108	4/17/13	< 1		
Powell ES	1st Floor, Inside Room 108	4/17/13	< 1		
Powell ES	1st Floor Hallway, by Janitor's Closet	4/17/13	< 1		
Powell ES	1st Floor Hallway, by Janitor's Closet	4/17/13	< 1		
Powell ES	2nd Floor, Hallway, by Janitor's Closet	4/17/13	< 1		
Powell ES	2nd Floor, Hallway, by Janitor's Closet	4/17/13	< 1		
Powell ES	2nd Floor Hallway, by Room 219	4/17/13	< 1		
Powell ES	2nd Floor Hallway, by Room 219	4/17/13	< 1		
Powell ES	2nd Floor Hallway, by Room 203	4/17/13	< 1		
Powell ES	2nd Floor Hallway, by Room 203	4/17/13	< 1		
Powell ES	1st Floor, Inside Cafeteria	4/17/13	< 1		
Powell ES	1st Floor, Inside Cafeteria	4/17/13	< 1		
Powell ES	1st Floor, Inside Health Suite	4/17/13	< 1		
Powell ES	1st Floor, Inside Health Suite	4/17/13	< 1		
Powell ES	1st Floor Hallway, Outside Room 108	4/17/13	< 1		
Powell ES	1st Floor Hallway, Outside Room 108	4/17/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Prospect LC	Basement Floor Hallway, Next to Custodian's Closet	5/15/13	< 1		
Prospect LC	Basement Floor Hallway, Next to Custodian's Closet	5/15/13	< 1		
Prospect LC	Basement Floor, Inside Cafeteria	5/15/13	< 1		
Prospect LC	Basement Floor, Inside Cafeteria	5/15/13	< 1		
Prospect LC	4th Floor Hallway, Next to Room 403	5/15/13	< 1		
Prospect LC	4th Floor Hallway, Next to Room 403	5/15/13	< 1		
Prospect LC	4th Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1		
Prospect LC	4th Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1		
Prospect LC	3rd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1		
Prospect LC	3rd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1		
Prospect LC	3rd Floor Hallway, Next to Teachers' Restroom	5/15/13	2		
Prospect LC	4th Floor Hallway, Next to Room 303	5/15/13	< 1		
Prospect LC	4th Floor Hallway, Next to Room 303	5/15/13	< 1		
Prospect LC	2nd Floor Hallway, Next to Room 203	5/15/13	< 1		
Prospect LC	2nd Floor Hallway, Next to Room 203	5/15/13	< 1		
Prospect LC	2nd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1		
Prospect LC	2nd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1		
Prospect LC	1st Floor Hallway, Next to Custodian's Closet	5/15/13	< 1		
Prospect LC	1st Floor Hallway, Next to Custodian's Closet	5/15/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Randle Highlands ES	2nd Floor Hallway, by Elevator (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor Hallway, by Elevator (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor Hallway, by Elevator (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor Hallway, by Elevator (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2231 (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2231 (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2231 (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2231 (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2226 (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2226 (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2226 (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2226 (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2224 (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2224 (High)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2224 (Low)	5/22/13	< 1		
Randle Highlands ES	2nd Floor, In Vestibule 2224 (Low)	5/22/13	< 1		
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (High)	5/22/13	< 1		
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (High)	5/22/13	< 1		
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (Low)	5/22/13	< 1		

Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (Low)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2131 (High)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2131 (High)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2131 (Low)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2131 (Low)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2126 (High)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2126 (High)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2126 (Low)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2126 (Low)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2121 (High)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2121 (High)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2121 (Low)	5/22/13	< 1	
Randle Highlands ES	1st Floor, In Vestibule 2121 (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2031 (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2031 (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2031 (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2031 (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2026 (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2026 (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2026 (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule 2026 (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (High)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (Low)	5/22/13	< 1	
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (Low)	5/22/13	< 1	
Randle Highlands ES	Gym Hallway, by Room 3001 Music Room	5/22/13	< 1	
Randle Highlands ES	Gym Hallway, by Room 3001 Music Room	5/22/13	< 1	
Randle Highlands ES	Basement Hallway, by Elevator (High)	5/22/13	< 1	
Randle Highlands ES	Basement Hallway, by Elevator (High)	5/22/13	< 1	
Randle Highlands ES	Basement Hallway, by Elevator (Low)	5/22/13	< 1	
Randle Highlands ES	Basement Hallway, by Elevator (Low)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B31 (High)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B31 (High)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B31 (Low)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B31 (Low)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B26 (Low)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B26 (Low)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B21 (High)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B21 (High)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B21 (Low)	5/22/13	< 1	
Randle Highlands ES	Basement, In Vestibule 2B21 (Low)	5/22/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Raymond ES	1st Floor Hallway, Across from Kitchen	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Across from Kitchen	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Next to Health Suite	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Next to Health Suite	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Next to Room 116	1/25/13	< 1	
Raymond ES	1st Floor Hallway, Next to Room 116	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 110	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 110	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 111	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 111	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 113	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 113	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 115	1/25/13	< 1	

Raymond ES	1st Floor, Inside Room 115	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 117	1/25/13	1	
Raymond ES	1st Floor, Inside Room 117	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 116	1/25/13	< 1	
Raymond ES	1st Floor, Inside Room 116	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Across from Room 209	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Across from Room 209	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Across from Room 217	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Across from Room 217	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Next to Room 26	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Next to Room 26	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Next to Room 22	1/25/13	< 1	
Raymond ES	2nd Floor Hallway, Next to Room 22	1/25/13	< 1	
Raymond ES	3rd Floor Hallway, Next to Room 30	1/25/13	< 1	
Raymond ES	3rd Floor Hallway, Next to Room 30	1/25/13	< 1	
Raymond ES	3rd Floor Hallway, Next to Room 36	1/25/13	< 1	
Raymond ES	3rd Floor Hallway, Next to Room 36	1/25/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Ron Brown MS	1st Floor Hallway, Across from Room 1124	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Across from Room 1124	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Across from Room 1126	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Across from Room 1126	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Across from Incinerator, Room 1137	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Across from Incinerator, Room 1137	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Next to Room 1175	5/10/13	< 1	
Ron Brown MS	1st Floor Hallway, Next to Room 1175	5/10/13	< 1	
Ron Brown MS	1st Floor, Cafeteria, Next to Room 2133D	5/10/13	< 1	
Ron Brown MS	1st Floor, Cafeteria, Next to Room 2133D	5/10/13	< 1	
Ron Brown MS	1st Floor, Cafeteria, Next to Supply/Storage Room 2131	5/10/13	< 1	
Ron Brown MS	1st Floor, Cafeteria, Next to Supply/Storage Room 2131	5/10/13	< 1	
Ron Brown MS	1st Floor, Multi-Purpose Room, Next to Supply Room 2127	5/10/13	< 1	
Ron Brown MS	1st Floor, Multi-Purpose Room, Next to Supply Room 2127	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym Hallway, Next to Girls Restroom 2208	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym Hallway, Next to Girls Restroom 2208	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym Hallway, Next to Boys Restroom 2223	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym Hallway, Next to Boys Restroom 2223	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym, Next to Supply Room 2209	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym, Next to Supply Room 2209	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym, In Wall B Area	5/10/13	< 1	
Ron Brown MS	2nd Floor, Gym, In Wall B Area	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Near Room 1206	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Near Room 1206	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Next to Teachers' Lounge 1247	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Next to Teachers' Lounge 1247	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Near Room 1218	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Near Room 1218	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Across from Room 1222	5/10/13	< 1	
Ron Brown MS	2nd Floor Hallway, Across from Room 1222	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Across from Room 1320	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Across from Room 1320	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Near Room 1316	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Near Room 1316	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Across from Room 1309	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Across from Room 1309	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Near Room 1306	5/10/13	< 1	
Ron Brown MS	3rd Floor Hallway, Near Room 1306	5/10/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Roosevelt SHS	3rd Floor Hallway, Across from 301 (Main Office)	6/10/13	< 1	

Roosevelt SHS	3rd Floor Hallway, Across from 301 (Main Office)	6/10/13	< 1		
Roosevelt SHS	3rd Floor Hallway, Next to Room 331	6/10/13	< 1		
Roosevelt SHS	3rd Floor Hallway, Next to Room 331	6/10/13	< 1		
Roosevelt SHS	2nd Floor Hallway, Next to Room 230	6/10/13	< 1		
Roosevelt SHS	2nd Floor Hallway, Next to Room 230	6/10/13	< 1		
Roosevelt SHS	2nd Floor Hallway, Next to Room 236	6/10/13	< 1		
Roosevelt SHS	2nd Floor Hallway, Next to Room 236	6/10/13	< 1		
Roosevelt SHS	2nd Floor Hallway, Next to Room 200	6/10/13	< 1		
Roosevelt SHS	2nd Floor Hallway, Next to Room 200	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, at Entrance to Auditorium	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, at Entrance to Auditorium	6/10/13	< 1		
Roosevelt SHS	Inside Library	6/10/13	1.1		
Roosevelt SHS	Inside Library	6/10/13	2.5		
Roosevelt SHS	1st Floor Hallway, Across from Room 194	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, Across from Room 194	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, Next to Room 132	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, Next to Room 132	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, Next to Room 138	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, Next to Room 138	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, at Entrance to Gym	6/10/13	< 1		
Roosevelt SHS	1st Floor Hallway, at Entrance to Gym	6/10/13	< 1		
Roosevelt SHS	Basement Hallway, Across from Old Elevator	6/10/13	< 1		
Roosevelt SHS	Basement Hallway, Across from Old Elevator	6/10/13	< 1		
Roosevelt SHS	Basement Hallway, Across from Cafeteria	6/10/13	< 1		
Roosevelt SHS	Basement Hallway, Across from Cafeteria	6/10/13	< 1		
Roosevelt SHS	Inside Kitchen	6/10/13	1.1		
Roosevelt SHS	Inside Kitchen	6/10/13	1.9		
Roosevelt SHS	Inside Kitchen, Near Office 12-A	6/10/13		99	Filter was installed.
Roosevelt SHS	Inside Kitchen, Near Office 12-A	6/10/13		810	
Roosevelt SHS	<i>Inside Kitchen, Near Office 12-A - Retest</i>	6/26/13	1.3		
Roosevelt SHS	<i>Inside Kitchen, Near Office 12-A - Retest</i>	6/26/13	1.5		
Roosevelt SHS	Basement Hallway, Next to Room B-16	6/10/13	1		
Roosevelt SHS	Basement Hallway, Next to Room B-16	6/10/13		19	Filter was installed.
Roosevelt SHS	<i>Basement Hallway, Next to Room B-16 - Retest</i>	6/26/13	1.2		
Roosevelt SHS	<i>Basement Hallway, Next to Room B-16 - Retest</i>	6/26/13	1.6		
Percentage of Passed Samples				90.63%	
Percentage of Failed Samples				9.38%	
Ross ES	Basement Hallway, Outside Adult Restroom (High)	2/3/14			
Ross ES	Basement Hallway, Outside Adult Restroom (High)	2/3/14			
Ross ES	Basement Hallway, Outside Adult Restroom (Low)	2/3/14			
Ross ES	Basement Hallway, Outside Adult Restroom (Low)	2/3/14			
Ross ES	Basement Floor, Inside Lunch Room (High)	2/3/14			
Ross ES	Basement Floor, Inside Lunch Room (High)	2/3/14			
Ross ES	Basement Floor, Inside Lunch Room (Low)	2/3/14			
Ross ES	Basement Floor, Inside Lunch Room (Low)	2/3/14			
Ross ES	1st Floor Hallway, Outside Room 105 (High)	2/3/14			
Ross ES	1st Floor Hallway, Outside Room 105 (High)	2/3/14			
Ross ES	1st Floor Hallway, Outside Room 105 (Low)	2/3/14			
Ross ES	1st Floor Hallway, Outside Room 105 (Low)	2/3/14			
Ross ES	2nd Floor Hallway, (High)	2/3/14			
Ross ES	2nd Floor Hallway, (High)	2/3/14			
Ross ES	2nd Floor Hallway, (Low)	2/3/14			
Ross ES	2nd Floor Hallway, (Low)	2/3/14			
Ross ES	Bubbler, Outside by Playground/School Entrance	2/3/14			
Ross ES	Bubbler, Outside by Playground/School Entrance	2/3/14			
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Savoy ES	3rd Floor Hallway, Across from Room 300 (High)	5/23/13	< 1		
Savoy ES	3rd Floor Hallway, Across from Room 300 (High)	5/23/13	< 1		
Savoy ES	3rd Floor Hallway, Across from Room 300 (Low)	5/23/13	< 1		

Savoy ES	3rd Floor Hallway, Across from Room 300 (Low)	5/23/13	< 1		
Savoy ES	3rd Floor Hallway, Across from Girls Room (High)	5/23/13	< 1		
Savoy ES	3rd Floor Hallway, Across from Girls Room (High)	5/23/13	< 1		
Savoy ES	3rd Floor Hallway, Across from Girls Room (Low)	5/23/13	< 1		
Savoy ES	3rd Floor Hallway, Across from Girls Room (Low)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, at Entrance to Gym (High)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, at Entrance to Gym (High)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, at Entrance to Gym (Low)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, at Entrance to Gym (Low)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (High)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (High)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (Low)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (Low)	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 113	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 113	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 115	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 115	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 120	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 120	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 122	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 122	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 109	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 109	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 111	5/23/13	< 1		
Savoy ES	1st Floor, Inside Room 111	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (High)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (High)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (Low)	5/23/13	< 1		
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (Low)	5/23/13	< 1		
Savoy ES	Inside Library (High)	5/23/13	< 1		
Savoy ES	Inside Library (High)	5/23/13	< 1		
Savoy ES	Inside Library (Low)	5/23/13	< 1		
Savoy ES	Inside Library (Low)	5/23/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
School without Walls	3rd Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	3rd Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	3rd Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	3rd Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	2nd Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	2nd Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	2nd Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	2nd Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	1st Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	1st Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	1st Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	1st Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	Basement Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	Basement Floor, by Elevator (High)	6/4/13	< 1		
School without Walls	Basement Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	Basement Floor, by Elevator (Low)	6/4/13	< 1		
School without Walls	Lower Level, by Elevator (High)	6/4/13	< 1		
School without Walls	Lower Level, by Elevator (High)	6/4/13	< 1		
School without Walls	Lower Level, by Elevator (Low)	6/4/13	< 1		
School without Walls	Lower Level, by Elevator (Low)	6/4/13	< 1		
Percentage of Passed Samples				100.00%	
Percentage of Failed Samples				0.00%	
Seaton ES	3rd Floor, Inside Room 309	2/7/14			
Seaton ES	3rd Floor, Inside Room 309	2/7/14			
Seaton ES	3rd Floor Hallway, by Girls Restroom	2/7/14			

Seaton ES	3rd Floor Hallway, by Girls Restroom	2/7/14		
Seaton ES	3rd Floor Hallway, by Boys Restroom	2/7/14		
Seaton ES	3rd Floor Hallway, by Boys Restroom	2/7/14		
Seaton ES	2nd Floor Hallway, by Girls Restroom	2/7/14		
Seaton ES	2nd Floor Hallway, by Girls Restroom	2/7/14		
Seaton ES	3rd Floor Hallway, by Room 206	2/7/14		
Seaton ES	3rd Floor Hallway, by Room 206	2/7/14		
Seaton ES	1st Floor, Inside Room 122	2/7/14		
Seaton ES	1st Floor, Inside Room 122	2/7/14		
Seaton ES	1st Floor, Inside Room 125	2/7/14		
Seaton ES	1st Floor, Inside Room 125	2/7/14		
Seaton ES	1st Floor, Inside Room 124	2/7/14		
Seaton ES	1st Floor, Inside Room 124	2/7/14		
Seaton ES	1st Floor, Inside Room 127	2/7/14		
Seaton ES	1st Floor, Inside Room 127	2/7/14		
Seaton ES	1st Floor, Inside Multi-Purpose Room	2/7/14		
Seaton ES	1st Floor, Inside Multi-Purpose Room	2/7/14		
Seaton ES	1st Floor Hallway, by Room 106	2/7/14		
Seaton ES	1st Floor Hallway, by Room 106	2/7/14		
Seaton ES	1st Floor, Inside Room 109	2/7/14		
Seaton ES	1st Floor, Inside Room 109	2/7/14		
Seaton ES	1st Floor, Inside Room 111	2/7/14		
Seaton ES	1st Floor, Inside Room 111	2/7/14		
Seaton ES	3rd Floor, Inside Room 307	2/7/14		
Seaton ES	3rd Floor, Inside Room 307	2/7/14		
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Shadd ES	1st Floor Hallway, Across from Room 108	6/14/13	< 1	
Shadd ES	1st Floor Hallway, Across from Room 108	6/14/13	< 1	
Shadd ES	1st Floor Hallway, Across from Lunch Room	6/14/13	< 1	
Shadd ES	1st Floor Hallway, Across from Lunch Room	6/14/13	< 1	
Shadd ES	1st Floor Hallway, Across from Room 105	6/14/13	< 1	
Shadd ES	1st Floor Hallway, Across from Room 105	6/14/13	< 1	
Shadd ES	2nd Floor Hallway, Next to Main Office	6/14/13	< 1	
Shadd ES	2nd Floor Hallway, Next to Main Office	6/14/13	< 1	
Shadd ES	2nd Floor Hallway, Across from Main Office	6/14/13	< 1	
Shadd ES	2nd Floor Hallway, Across from Main Office	6/14/13	< 1	
Shadd ES	2nd Floor Hallway, Next to Library	6/14/13	< 1	
Shadd ES	2nd Floor Hallway, Next to Library	6/14/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Sharpe Health School	1st Floor Hallway, Across from Room 201	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Across from Room 201	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Play Room	5/6/13	1.5	
Sharpe Health School	1st Floor Hallway, Next to Play Room	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Room 207	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Room 207	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Across from Dining Room	5/6/13	1.8	
Sharpe Health School	1st Floor Hallway, Across from Dining Room	5/6/13	< 1	
Sharpe Health School	1st Floor, Inside Dining Room	5/6/13	< 1	
Sharpe Health School	1st Floor, Inside Dining Room	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Room 108	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Room 108	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Across from Men's Locker Room	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Across from Men's Locker Room	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Room 102	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Next to Room 102	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Across from Kitchen	5/6/13	< 1	
Sharpe Health School	1st Floor Hallway, Across from Kitchen	5/6/13	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Shepherd ES	1st Floor, Inside Room 132	4/8/13	< 1	
Shepherd ES	1st Floor, Inside Room 132	4/8/13	< 1	
Shepherd ES	1st Floor, Inside Room 101	4/8/13	< 1	
Shepherd ES	1st Floor, Inside Room 101	4/8/13	< 1	
Shepherd ES	Basement Floor, Inside Lunch Room	4/8/13	< 1	

Shepherd ES	Basement Floor, Inside Lunch Room	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 214	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 214	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 220	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 220	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Counselor's Office	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Counselor's Office	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Room 122	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Room 122	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 204	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 204	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 200	4/8/13	< 1		
Shepherd ES	2nd Floor Hallway, Next to Room 200	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Room 100	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Room 100	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Room 102	4/8/13	< 1		
Shepherd ES	1st Floor Hallway, Next to Room 102	4/8/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Simon ES	1st Floor Hallway, by Room 116	3/1/13	< 1		
Simon ES	1st Floor Hallway, by Room 116	3/1/13	< 1		
Simon ES	1st Floor Hallway, by Room 106	3/1/13	< 1		
Simon ES	1st Floor Hallway, by Room 106	3/1/13	< 1		
Simon ES	2nd Floor Hallway, by Room 206	3/1/13	< 1		
Simon ES	2nd Floor Hallway, by Room 206	3/1/13	< 1		
Simon ES	2nd Floor Hallway, by Room 211	3/1/13	< 1		
Simon ES	2nd Floor Hallway, by Room 211	3/1/13	< 1		
Simon ES	3rd Floor Hallway, by Room 307	3/1/13	< 1		
Simon ES	3rd Floor Hallway, by Room 307	3/1/13	< 1		
Simon ES	3rd Floor Hallway, by Room 304	3/1/13	< 1		
Simon ES	3rd Floor Hallway, by Room 304	3/1/13	< 1		
Simon ES	Ground Floor Hallway, by Room 005	3/1/13	< 1		
Simon ES	Ground Floor Hallway, by Room 005	3/1/13	< 1		
Simon ES	Ground Floor Hallway, by Room 013	3/1/13	< 1		
Simon ES	Ground Floor Hallway, by Room 013	3/1/13	< 1		
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Smothers ES	3rd Floor Hallway, Next to Room 310	1/24/14			
Smothers ES	3rd Floor Hallway, Next to Room 310	1/24/14			
Smothers ES	3rd Floor Hallway, Next to Room 301	1/24/14			
Smothers ES	3rd Floor Hallway, Next to Room 301	1/24/14			
Smothers ES	2nd Floor Hallway, Next to Room 202	1/24/14			
Smothers ES	2nd Floor Hallway, Next to Room 202	1/24/14			
Smothers ES	2nd Floor Hallway, Next to Room 212	1/24/14			
Smothers ES	2nd Floor Hallway, Next to Room 212	1/24/14			
Smothers ES	1st Floor Hallway, Next to Room 111	1/24/14			
Smothers ES	1st Floor Hallway, Next to Room 111	1/24/14			
Smothers ES	1st Floor Hallway, Next to Room 104	1/24/14			
Smothers ES	1st Floor Hallway, Next to Room 104	1/24/14			
				Percentage of Passed Samples	100.00%
				Percentage of Failed Samples	0.00%
Sousa ES	1st Floor Corridor, Next to Room B122 (High)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room B122 (High)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room B122 (Low)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room B122 (Low)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room A102 (High)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room A102 (High)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room A102 (Low)	2/5/13	< 1		
Sousa ES	1st Floor Corridor, Next to Room A102 (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room B104 (1st unit, from right hand side)	2/5/13	2.7		
Sousa ES	1st Floor, Inside Room B104 (1st unit, from right hand side)	2/5/13	< 1		

Sousa ES	1st Floor, Inside Room B104 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room B104 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room B104 (3rd unit, from right hand side)	2/5/13	4.7		
Sousa ES	1st Floor, Inside Room B104 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room B104 (4th unit, from right hand side)	2/5/13	1.6		
Sousa ES	1st Floor, Inside Room B104 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room B104 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room B104 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (1st unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (1st unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (2nd unit, from right hand side)	2/5/13	1.4		
Sousa ES	1st Floor, Inside Room A109 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (6th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Room A109 (6th unit, from right hand side)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room C101 (High)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room C101 (High)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room C101 (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room C101 (Low)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (1st unit, from right hand side)	2/5/13	1.9		
Sousa ES	3rd Floor, Inside Room B304 (1st unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (4th unit, from right hand side)	2/5/13	2		
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side)	2/5/13		16	This is a science lab. Sinks are rarely used, and not used for drinking water.
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side)	2/5/13	1.1		
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side) - Retest	2/20/13	< 1		

Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side) - Retest	2/20/13	< 1		
Sousa ES	3rd Floor, Inside Room B304 (6th unit, from right hand side)	2/5/13	3		
Sousa ES	3rd Floor, Inside Room B304 (6th unit, from right hand side)	2/5/13	3		
Sousa ES	3rd Floor, Inside Room B309 (1st unit, from right hand side)	2/5/13	1.9		
Sousa ES	3rd Floor, Inside Room B309 (1st unit, from right hand side)	2/5/13	2.6		
Sousa ES	3rd Floor, Inside Room B309 (2nd unit, from right hand side)	2/5/13	1		
Sousa ES	3rd Floor, Inside Room B309 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B309 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B309 (3rd unit, from right hand side)	2/5/13	1		
Sousa ES	3rd Floor, Inside Room B309 (4th unit, from right hand side)	2/5/13	2.5		
Sousa ES	3rd Floor, Inside Room B309 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B309 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B309 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor, Inside Room B309 (6th unit, from right hand side)	2/5/13	1.3		
Sousa ES	3rd Floor, Inside Room B309 (6th unit, from right hand side)	2/5/13	< 1		
Sousa ES	3rd Floor Corridor, Next to Room C301	2/5/13	< 1		
Sousa ES	3rd Floor Corridor, Next to Room C301	2/5/13	< 1		
Sousa ES	3rd Floor Corridor, Next to Room A301 (High)	2/5/13	< 1		
Sousa ES	3rd Floor Corridor, Next to Room A301 (High)	2/5/13	< 1		
Sousa ES	3rd Floor Corridor, Next to Room A301 (Low)	2/5/13	< 1		
Sousa ES	3rd Floor Corridor, Next to Room A301 (Low)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (1st unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (1st unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (3rd unit, from right hand side)	2/5/13	2		
Sousa ES	2nd Floor, Inside Room A204 (3rd unit, from right hand side)	2/5/13	1.4		
Sousa ES	2nd Floor, Inside Room A204 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (6th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A204 (6th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (1st unit, from right hand side)	2/5/13	1.9		
Sousa ES	2nd Floor, Inside Room A209 (1st unit, from right hand side)	2/5/13	1.7		

Sousa ES	2nd Floor, Inside Room A209 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (2nd unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (3rd unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (4th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (5th unit, from right hand side)	2/5/13	< 1		
Sousa ES	2nd Floor, Inside Room A209 (6th unit, from right hand side)	2/5/13	3.2		
Sousa ES	2nd Floor, Inside Room A209 (6th unit, from right hand side)	2/5/13	1.5		
Sousa ES	2nd Floor Corridor, Next to Room A201 (High)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room A201 (High)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room A201 (Low)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room A201 (Low)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room C201 (High)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room C201 (High)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room C201 (Low)	2/5/13	< 1		
Sousa ES	2nd Floor Corridor, Next to Room C201 (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Boys Locker Room (High)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Boys Locker Room (High)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Boys Locker Room (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Boys Locker Room (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Girls Locker Room (High)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Girls Locker Room (High)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Girls Locker Room (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Inside Girls Locker Room (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D101 (High)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D101 (High)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D101 (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D101 (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D104 (High)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D104 (High)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D104 (Low)	2/5/13	< 1		
Sousa ES	1st Floor, Next to Room D104 (Low)	2/5/13	< 1		
				Percentage of Passed Samples	99.11%
				Percentage of Failed Samples	0.89%
Spingarn SHS	3rd Floor Hallway, Outside Room 307	5/9/13	< 1		
Spingarn SHS	3rd Floor Hallway, Outside Room 307	5/9/13	< 1		
Spingarn SHS	3rd Floor Hallway, Outside Room 308	5/9/13	2.7		
Spingarn SHS	3rd Floor Hallway, Outside Room 308	5/9/13	2.8		
Spingarn SHS	2nd Floor, Outside Room 207	5/9/13	< 1		
Spingarn SHS	2nd Floor, Outside Room 207	5/9/13	< 1		
Spingarn SHS	2nd Floor, Outside Room 208	5/9/13	< 1		
Spingarn SHS	2nd Floor, Outside Room 208	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 111	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 111	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 123	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 123	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 126	5/9/13	< 1		

Spingarn SHS	1st Floor Hallway, Outside Room 126	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 108	5/9/13	< 1		
Spingarn SHS	1st Floor Hallway, Outside Room 108	5/9/13	< 1		
Spingarn SHS	Basement Floor, Inside Cafeteria	5/9/13	< 1		
Spingarn SHS	Basement Floor, Inside Cafeteria	5/9/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1		
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1		
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1		
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 227 (1)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 227 (1)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 227 (2)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 227 (2)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 227 (3)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 227 (3)	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 244	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 244	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 245	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 245	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 246	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 246	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 247	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 247	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 230	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 230	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 231	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 231	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 232	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 232	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 233	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 233	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 234	2/21/13	< 1		
Stoddert ES	2nd Floor, Inside Room 234	2/21/13	< 1		
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1		
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1		
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1		
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 142	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 142	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 144	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 144	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 145	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 145	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 146	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 146	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 147	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 147	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 131	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 131	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 132	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 132	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 133	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 133	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 134	2/21/13	< 1		
Stoddert ES	1st Floor, Inside Room 134	2/21/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%

Stuart Hobson MS	3rd Floor Hallway, Next to Room 303	5/1/13	< 1		
Stuart Hobson MS	3rd Floor Hallway, Next to Room 303	5/1/13	< 1		
Stuart Hobson MS	2nd Floor Hallway, Next to Room 203	5/1/13	< 1		
Stuart Hobson MS	2nd Floor Hallway, Next to Room 203	5/1/13	< 1		
Stuart Hobson MS	2nd Floor Hallway, Next to Room 204	5/1/13	< 1		
Stuart Hobson MS	2nd Floor Hallway, Next to Room 204	5/1/13	< 1		
Stuart Hobson MS	1st Floor Hallway, Next to Room 104	5/1/13	< 1		
Stuart Hobson MS	1st Floor Hallway, Next to Room 104	5/1/13	< 1		
Stuart Hobson MS	1st Floor Hallway, Next to Room 103	5/1/13	< 1		
Stuart Hobson MS	1st Floor Hallway, Next to Room 103	5/1/13	< 1		
Stuart Hobson MS	Basement Floor, Inside Cafeteria	5/1/13	< 1		
Stuart Hobson MS	Basement Floor, Inside Cafeteria	5/1/13	< 1		
Stuart Hobson MS	Basement Floor Hallway, Next to Boys Restroom	5/1/13	< 1		
Stuart Hobson MS	Basement Floor Hallway, Next to Boys Restroom	5/1/13	< 1		
Stuart Hobson MS	Basement Floor Hallway, Next to Custodian's Office	5/1/13	< 1		
Stuart Hobson MS	Basement Floor Hallway, Next to Custodian's Office	5/1/13	< 1		
Stuart Hobson MS	3rd Floor Hallway, Next to Room 304	5/1/13	< 1		
Stuart Hobson MS	3rd Floor Hallway, Next to Room 304	5/1/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Takoma EC	3rd Floor Hallway, Next to Elevator (High)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Elevator (High)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Room 327 (High)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Room 327 (High)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Room 327 (Low)	5/28/13	< 1		
Takoma EC	3rd Floor Hallway, Next to Room 327 (Low)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Elevator (High)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Elevator (High)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Room 234 (High)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Room 234 (High)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Room 234 (Low)	5/28/13	< 1		
Takoma EC	2nd Floor Hallway, Next to Room 234 (Low)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Next to Room 133 (High)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Next to Room 133 (High)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Next to Room 133 (Low)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Next to Room 133 (Low)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Across from Elevator (High)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Across from Elevator (High)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Across from Elevator (Low)	5/28/13	< 1		
Takoma EC	1st Floor Hallway, Across from Elevator (Low)	5/28/13	< 1		
Takoma EC	In Gym Area, Next to Boys Locker Room	5/28/13	2.6		
Takoma EC	In Gym Area, Next to Boys Locker Room	5/28/13	< 1		
Takoma EC	In Gym Area, Next to Girls Locker Room	5/28/13	< 1		
Takoma EC	In Gym Area, Next to Girls Locker Room	5/28/13	< 1		
Percentage of Passed Samples					100.00%
Percentage of Failed Samples					0.00%
Thomas ES	1st Floor, Main Lobby, Next to Multi-Purpose Room	1/23/14			
Thomas ES	1st Floor, Main Lobby, Next to Multi-Purpose Room	1/23/14			
Thomas ES	1st Floor Hallway, Outside Multi-Purpose Room	1/23/14			
Thomas ES	1st Floor Hallway, Outside Multi-Purpose Room	1/23/14			
Thomas ES	1st Floor, Inside Multi-Purpose Room	1/23/14			
Thomas ES	1st Floor, Inside Multi-Purpose Room	1/23/14			
Thomas ES	1st Floor, Inside Cafeteria	1/23/14			
Thomas ES	1st Floor, Inside Cafeteria	1/23/14			
Thomas ES	1st Floor, Next to Room 109 (Low)	1/23/14			
Thomas ES	1st Floor, Next to Room 109 (Low)	1/23/14			
Thomas ES	1st Floor, Next to Room 109 (High)	1/23/14			

Thomas ES	1st Floor, Next to Room 109 (High)	1/23/14		
Thomas ES	1st Floor, Next to Health Suite (Low)	1/23/14		
Thomas ES	1st Floor, Next to Health Suite (Low)	1/23/14		
Thomas ES	1st Floor, Next to Health Suite (High)	1/23/14		
Thomas ES	1st Floor, Next to Health Suite (High)	1/23/14		
Thomas ES	1st Floor, Inside Health Suite	1/23/14		
Thomas ES	1st Floor, Inside Health Suite	1/23/14		
Thomas ES	2nd Floor, Next to Room 215	1/23/14		
Thomas ES	2nd Floor, Next to Room 215	1/23/14		
Thomas ES	2nd Floor Hallway, Between Boys and Girls Restroom	1/23/14		
Thomas ES	2nd Floor Hallway, Between Boys and Girls Restroom	1/23/14		
Thomas ES	2nd Floor, Across from Room 209 (Low)	1/23/14		
Thomas ES	2nd Floor, Across from Room 209 (Low)	1/23/14		
Thomas ES	2nd Floor, Across from Room 209 (High)	1/23/14		
Thomas ES	2nd Floor, Across from Room 209 (High)	1/23/14		
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Thomson ES	3rd Floor Hallway, Next to Room 316	2/5/14	< 1	
Thomson ES	3rd Floor Hallway, Next to Room 316	2/5/14	< 1	
Thomson ES	2nd Floor Hallway, Next to Room 227	2/5/14	< 1	
Thomson ES	2nd Floor Hallway, Next to Room 227	2/5/14	< 1	
Thomson ES	1st Floor Hallway, Next to Room 130	2/5/14	< 1	
Thomson ES	1st Floor Hallway, Next to Room 130	2/5/14	< 1	
Thomson ES	1st Floor Hallway, Next to Room 129	2/5/14	< 1	
Thomson ES	1st Floor Hallway, Next to Room 129	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 127	2/5/14	2.8	
Thomson ES	1st Floor, Inside Room 127	2/5/14	1.8	
Thomson ES	1st Floor, Inside Room 123	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 123	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 124	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 124	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 126	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 126	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 112	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 112	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 115	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 115	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 113	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 113	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 114	2/5/14	< 1	
Thomson ES	1st Floor, Inside Room 114	2/5/14	< 1	
Thomson ES	Inside Cafeteria (High)	2/5/14	< 1	
Thomson ES	Inside Cafeteria (High)	2/5/14	< 1	
Thomson ES	Inside Cafeteria (Low)	2/5/14	< 1	
Thomson ES	Inside Cafeteria (Low)	2/5/14	< 1	
Percentage of Passed Samples				100.00%
Percentage of Failed Samples				0.00%
Truesdell ES	Basement Floor, Inside Health Suite	3/13/13	< 1	
Truesdell ES	Basement Floor, Inside Health Suite	3/13/13	< 1	
Truesdell ES	Basement Hallway, by Room 012	3/13/13	< 1	
Truesdell ES	Basement Hallway, by Room 012	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, by Staff Restroom	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, by Staff Restroom	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, by Stairwell, Opposite to Room 218	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, by Stairwell, Opposite to Room 218	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, Opposite to Library	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, Opposite to Library	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, by Staff Restroom	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, by Staff Restroom	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, by Roof Door	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, by Roof Door	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, by Room 300	3/13/13	< 1	
Truesdell ES	3rd Floor Hallway, by Room 300	3/13/13	< 1	
Truesdell ES	2nd Floor, Inside Room 216	3/13/13	< 1	

Truesdell ES	2nd Floor, Inside Room 216	3/13/13	< 1	
Truesdell ES	2nd Floor, Inside Room 217	3/13/13	< 1	
Truesdell ES	2nd Floor, Inside Room 217	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, by Room 212	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, by Room 212	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, Outside Room 200	3/13/13	< 1	
Truesdell ES	2nd Floor Hallway, Outside Room 200	3/13/13	< 1	
Truesdell ES	2nd Floor, Inside Room 201	3/13/13	< 1	
Truesdell ES	2nd Floor, Inside Room 201	3/13/13	< 1	
Truesdell ES	2nd Floor, Inside Room 200	3/13/13	1.7	
Truesdell ES	2nd Floor, Inside Room 200	3/13/13	1.3	
Truesdell ES	1st Floor, Inside Room 100	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 100	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 101	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 101	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 106	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 106	3/13/13	< 1	
Truesdell ES	1st Floor, Outside Parents' Center	3/13/13	< 1	
Truesdell ES	1st Floor, Outside Parents' Center	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 114	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 114	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 113	3/13/13	< 1	
Truesdell ES	1st Floor, Inside Room 113	3/13/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Tubman ES	3rd Floor Hallway, Across from Room 311	2/6/14	< 1	
Tubman ES	3rd Floor Hallway, Across from Room 311	2/6/14	< 1	
Tubman ES	3rd Floor Hallway, Across from Room 306	2/6/14	< 1	
Tubman ES	3rd Floor Hallway, Across from Room 306	2/6/14	< 1	
Tubman ES	3rd Floor Hallway, Across from Room 301	2/6/14	< 1	
Tubman ES	3rd Floor Hallway, Across from Room 301	2/6/14	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 211	2/6/14	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 211	2/6/14	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 206	2/6/14	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 206	2/6/14	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 201	2/6/14	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 201	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Across from Room 115	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Across from Room 115	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 115	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 115	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Next to Room 110	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Next to Room 110	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 110	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 110	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 113	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 113	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 111	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 111	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 108	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 108	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Across from Room 101	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Across from Room 101	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Next to Room 132	2/6/14	< 1	
Tubman ES	1st Floor Hallway, Next to Room 132	2/6/14	< 1	
Tubman ES	1st Floor, Across from Cafeteria	2/6/14	< 1	
Tubman ES	1st Floor, Across from Cafeteria	2/6/14	< 1	
Tubman ES	1st Floor, Inside Cafeteria	2/6/14	< 1	
Tubman ES	1st Floor, Inside Cafeteria	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 122	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 122	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 121	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 121	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 120	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 120	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 119	2/6/14	< 1	
Tubman ES	1st Floor, Inside Room 119	2/6/14	< 1	

Tubman ES	1st Floor, Inside Health Suite	2/6/14	5.2		
Tubman ES	1st Floor, Inside Health Suite	2/6/14	6.4		Filter was installed.
Tubman ES	1st Floor, Inside Room 114	2/6/14	7.6		
Tubman ES	1st Floor, Inside Room 114	2/6/14		30	Filter was installed.
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>			16	
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>			68	Device was replaced.
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>		< 1		
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>		< 1		
				Percentage of Passed Samples	97.83%
				Percentage of Failed Samples	2.17%
Turner ES	3rd Floor Hallway, by Room 316 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 316 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 316 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 316 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 324 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 324 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 324 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 324 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 313 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 313 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 313 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 313 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 303 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 303 (High)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 303 (Low)	5/3/13	< 1		
Turner ES	3rd Floor Hallway, by Room 303 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 203 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 203 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 203 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 203 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 209 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 209 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 209 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 209 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 213 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 213 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 213 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 213 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 221 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 221 (High)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 221 (Low)	5/3/13	< 1		
Turner ES	2nd Floor Hallway, by Room 221 (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 109 (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 109 (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 109 (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 109 (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 102 (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 102 (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 102 (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Room 102 (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Elevator (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Elevator (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Elevator (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, by Elevator (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, Opposite to Main Office (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, Opposite to Main Office (High)	5/3/13	< 1		
Turner ES	1st Floor Hallway, Opposite to Main Office (Low)	5/3/13	< 1		
Turner ES	1st Floor Hallway, Opposite to Main Office (Low)	5/3/13	< 1		
Turner ES	1st Floor, Inside Room 117	5/3/13	1.5		
Turner ES	1st Floor, Inside Room 117	5/3/13	< 1		
Turner ES	1st Floor, Inside Room 116	5/3/13		88	Filter was installed.
Turner ES	1st Floor, Inside Room 116	5/3/13	4.7		
Turner ES	<i>1st Floor, Inside Room 116</i>	<i>5/21/13</i>	1.2		
Turner ES	<i>1st Floor, Inside Room 116</i>	<i>5/21/13</i>	1.3		
Turner ES	1st Floor, Inside Room 113	5/3/13	< 1		

Turner ES	1st Floor, Inside Room 113	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 112	5/3/13	1.3	
Turner ES	1st Floor, Inside Room 112	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 109	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 109	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 108	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 108	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 107	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 107	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 106	5/3/13	< 1	
Turner ES	1st Floor, Inside Room 106	5/3/13	< 1	
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance Door (High)	5/3/13	< 1	
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance Door (High)	5/3/13	< 1	
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance Door (Low)	5/3/13	< 1	
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance Door (Low)	5/3/13	< 1	
			Percentage of Passed Samples	98.53%
			Percentage of Failed Samples	1.47%
Tyler ES	3rd Floor Hallway, by Room 303	5/20/13	< 1	
Tyler ES	3rd Floor Hallway, by Room 303	5/20/13	< 1	
Tyler ES	3rd Floor Hallway, by Room 306	5/20/13	< 1	
Tyler ES	3rd Floor Hallway, by Room 306	5/20/13	< 1	
Tyler ES	2nd Floor Hallway, by Restroom	5/20/13	< 1	
Tyler ES	2nd Floor Hallway, by Restroom	5/20/13	< 1	
Tyler ES	2nd Floor Hallway, by Media Center	5/20/13	< 1	
Tyler ES	2nd Floor Hallway, by Media Center	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 138 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 138 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 138 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 138 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 142 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 142 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 142 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 142 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 103 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 103 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 103 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 103 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 120 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 120 (High)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 120 (Low)	5/20/13	< 1	
Tyler ES	1st Floor Hallway, by Room 120 (Low)	5/20/13	< 1	
Tyler ES	Basement Floor, Inside Cafeteria	5/20/13	< 1	
Tyler ES	Basement Floor, Inside Cafeteria	5/20/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Van Ness ES	3rd Floor Hallway, Across from Room 302	6/4/13	< 1	
Van Ness ES	3rd Floor Hallway, Across from Room 302	6/4/13	< 1	
Van Ness ES	2nd Floor Hallway, Across from Room 202	6/4/13	< 1	
Van Ness ES	2nd Floor Hallway, Across from Room 202	6/4/13	< 1	
Van Ness ES	2nd Floor Hallway, Next to Room 207	6/4/13	< 1	
Van Ness ES	2nd Floor Hallway, Next to Room 207	6/4/13	< 1	
Van Ness ES	1st Floor Hallway, Across from Room 3	6/4/13	< 1	
Van Ness ES	1st Floor Hallway, Across from Room 3	6/4/13	< 1	
Van Ness ES	1st Floor Hallway, Across from Assembly Room	6/4/13	< 1	
Van Ness ES	1st Floor Hallway, Across from Assembly Room	6/4/13	< 1	
Van Ness ES	1st Floor Hallway, Across from Room 13	6/4/13	< 1	
Van Ness ES	1st Floor Hallway, Across from Room 13	6/4/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Walker Jones ES	Basement Floor, Inside Room 036	1/23/13	2.2	
Walker Jones ES	Basement Floor, Inside Room 036	1/23/13	1.6	
Walker Jones ES	Basement Floor, Therapy Room	1/23/13	< 1	
Walker Jones ES	Basement Floor, Therapy Room	1/23/13	< 1	

Walker Jones ES	2nd Floor Hallway, Across from Room 214 (High)	1/23/13	< 1		
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (High)	1/23/13	< 1		
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (Low)	1/23/13	< 1		
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (Low)	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 212	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 212	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 210	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 210	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 205	1/23/13	5.2		
Walker Jones ES	2nd Floor, Inside Room 205	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 203	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 203	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 208	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 208	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 206	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 206	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 201	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 201	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 220	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 220	1/23/13	< 1		
Walker Jones ES	2nd Floor, Inside Room 300	1/23/13	< 1		
Walker Jones ES	3rd Floor, Inside Room 300	1/23/13	< 1		
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (High)	1/23/13	< 1		
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (High)	1/23/13	< 1		
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (Low)	1/23/13	< 1		
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (Low)	1/23/13	< 1		
Walker Jones ES	3rd Floor, Inside Room 320 (1st Bubbler)	1/23/13	2.4		
Walker Jones ES	3rd Floor, Inside Room 320 (1st Bubbler)	1/23/13	1.7		
Walker Jones ES	3rd Floor, Inside Room 320 (2nd Bubbler)	1/23/13	1.1		
Walker Jones ES	3rd Floor, Inside Room 320 (2nd Bubbler)	1/23/13	6.6		This is a science lab. Sinks are rarely used, and not used for drinking water.
Walker Jones ES	3rd Floor, Inside Room 320 (3rd Bubbler)	1/23/13	5.5		
Walker Jones ES	3rd Floor, Inside Room 320 (3rd Bubbler)	1/23/13	4.8		
Walker Jones ES	3rd Floor, Inside Room 320 (4th Bubbler)	1/23/13	7.6		
Walker Jones ES	3rd Floor, Inside Room 320 (4th Bubbler)	1/23/13		15	This is a science lab. Sinks are rarely used, and not used for drinking water.
Walker Jones ES	3rd Floor, Inside Room 320 (4th Bubbler) - Retest	2/7/13	13		
Walker Jones ES	3rd Floor, Inside Room 320 (4th Bubbler) - Retest	2/7/13	4.5		
Walker Jones ES	3rd Floor, Inside Room 324 (1st Bubbler)	1/23/13	< 1		This is a science lab. Sinks are rarely used, and not used for drinking water.
Walker Jones ES	3rd Floor, Inside Room 324 (1st Bubbler)	1/23/13	5.8		
Walker Jones ES	3rd Floor, Inside Room 324 (2nd Bubbler)	1/23/13	8.1		This is a science lab. Sinks are rarely used, and not used for drinking water.
Walker Jones ES	3rd Floor, Inside Room 324 (2nd Bubbler)	1/23/13	3.9		
Walker Jones ES	3rd Floor, Inside Room 324 (3rd Bubbler)	1/23/13	< 1		
Walker Jones ES	3rd Floor, Inside Room 324 (3rd Bubbler)	1/23/13	14		This is a science lab. Sinks are rarely used, and not used for drinking water.
Walker Jones ES	3rd Floor, Inside Room 324 (4th Bubbler)	1/23/13	< 1		
Walker Jones ES	3rd Floor, Inside Room 324 (4th Bubbler)	1/23/13	1.3		
Percentage of Passed Samples					99.04%

			Percentage of Failed Samples		0.96%
Watkins ES	4th Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	4th Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	4th Floor Hallway, Across from Room 403	5/17/13	< 1		
Watkins ES	4th Floor Hallway, Across from Room 403	5/17/13	< 1		
Watkins ES	4th Floor Hallway, Next to Room 407	5/17/13	< 1		
Watkins ES	4th Floor Hallway, Next to Room 407	5/17/13	< 1		
Watkins ES	3rd Floor Hallway, Next to Room 307	5/17/13	< 1		
Watkins ES	3rd Floor Hallway, Next to Room 307	5/17/13	< 1		
Watkins ES	3rd Floor Hallway, Across from Room 303	5/17/13	< 1		
Watkins ES	3rd Floor Hallway, Across from Room 303	5/17/13	< 1		
Watkins ES	3rd Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	3rd Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	2nd Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	2nd Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	2nd Floor Hallway, Across from Room 203	5/17/13	< 1		
Watkins ES	2nd Floor Hallway, Across from Room 203	5/17/13	< 1		
Watkins ES	2nd Floor Hallway, Next to Library Room 205	5/17/13	< 1		
Watkins ES	2nd Floor Hallway, Next to Library Room 205	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Next to Room 112	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Next to Room 112	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Across from Room 108	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Across from Room 108	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Across from Elevator	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Next to Recreation Center Office	5/17/13	< 1		
Watkins ES	1st Floor Hallway, Next to Recreation Center Office	5/17/13	< 1		
			Percentage of Passed Samples		100.00%
			Percentage of Failed Samples		0.00%
West ES	1st Floor Hallway, Between Women's and Men's Restroom	3/28/13	< 1		
West ES	1st Floor Hallway, Between Women's and Men's Restroom	3/28/13	< 1		
West ES	1st Floor, Kindergarten, Next to Boys Restroom	3/28/13	< 1		
West ES	1st Floor, Kindergarten, Next to Boys Restroom	3/28/13	< 1		
West ES	1st Floor, Pre-K, Next to Uni-Sex Restroom	3/28/13	< 1		
West ES	1st Floor, Pre-K, Next to Uni-Sex Restroom	3/28/13	< 1		
West ES	1st Floor Hallway, Outside Main Office	3/28/13	< 1		
West ES	1st Floor Hallway, Outside Main Office	3/28/13	< 1		
West ES	1st Floor, Inside Health Suite	3/28/13	< 1		
West ES	1st Floor, Inside Health Suite	3/28/13	< 1		
West ES	1st Floor Hallway, Next to Trash Chute	3/28/13	< 1		
West ES	1st Floor Hallway, Next to Trash Chute	3/28/13	< 1		
West ES	1st Floor, Inside Daycare, Next to Restroom	3/28/13	< 1		
West ES	1st Floor, Inside Daycare, Next to Restroom	3/28/13	< 1		
West ES	2nd Floor, Inside Gym on South Wall (Right)	3/28/13	< 1		
West ES	2nd Floor, Inside Gym on South Wall (Right)	3/28/13	< 1		
West ES	2nd Floor, Inside Gym on South Wall (Left)	3/28/13	< 1		
West ES	2nd Floor, Inside Gym on South Wall (Left)	3/28/13	< 1		
West ES	2nd Floor Hallway, Outside Gym (Right)	3/28/13	< 1		
West ES	2nd Floor Hallway, Outside Gym (Right)	3/28/13	< 1		
West ES	2nd Floor Hallway, Outside Gym (Left)	3/28/13	< 1		
West ES	2nd Floor Hallway, Outside Gym (Left)	3/28/13	< 1		
West ES	2nd Floor, Inside Cafeteria, Next to Kitchen	3/28/13	< 1		
West ES	2nd Floor, Inside Cafeteria, Next to Kitchen	3/28/13	< 1		
West ES	2nd Floor Hallway, Outside Teachers' Lounge	3/28/13	< 1		
West ES	2nd Floor Hallway, Outside Teachers' Lounge	3/28/13	< 1		
West ES	2nd Floor, Inside Teachers' Lounge	3/28/13	< 1		
West ES	2nd Floor, Inside Teachers' Lounge	3/28/13	< 1		
West ES	2nd Floor Hallway, Next to Book Storage Room (Right)	3/28/13	< 1		
West ES	2nd Floor Hallway, Next to Book Storage Room (Right)	3/28/13	< 1		
West ES	2nd Floor Hallway, Next to Book Storage Room (Left)	3/28/13	< 1		
West ES	2nd Floor Hallway, Next to Book Storage Room (Left)	3/28/13	< 1		

West ES	2nd Floor Hallway, Next to Computer Lab (Right)	3/28/13	< 1	
West ES	2nd Floor Hallway, Next to Computer Lab (Right)	3/28/13	< 1	
West ES	2nd Floor Hallway, Next to Computer Lab (Left)	3/28/13	< 1	
West ES	2nd Floor Hallway, Next to Computer Lab (Left)	3/28/13	< 1	
West ES	Mezzanine Level, Inside Library	3/28/13	< 1	
West ES	Mezzanine Level, Inside Library	3/28/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Wheatley ES	2nd Floor Hallway, by Room 205 (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Room 205 (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Room 205 (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Room 205 (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 213	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 213	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 211	5/31/13	1.7	
Wheatley ES	2nd Floor, Inside Room 211	5/31/13	8.1	Filter was installed.
Wheatley ES	2nd Floor, Inside Room 203	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 203	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 215	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 215	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 207	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 207	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 234	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 234	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 229	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 229	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 227	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 227	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 225	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 225	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 224	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 224	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 222	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 222	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 103	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 103	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 111	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 111	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 115	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 115	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 113	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 113	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 114	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 114	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 107	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 107	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 136	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 136	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 135	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 135	5/31/13	< 1	

Wheatley ES	1st Floor, Inside Room 131	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 131	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 128	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 128	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 125	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 125	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 123	5/31/13	< 1	
Wheatley ES	1st Floor, Inside Room 123	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G05	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G05	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G31	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G31	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G51	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G51	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G54	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G54	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G57	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G57	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G59	5/31/13	< 1	
Wheatley ES	Ground Floor, Inside Room G59	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G46 (High)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G46 (High)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G46 (Low)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G46 (Low)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G15 (High)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G15 (High)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G15 (Low)	5/31/13	< 1	
Wheatley ES	Ground Floor Hallway, by Room G15 (Low)	5/31/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Whittier ES	3rd Floor Hallway, Next to Room 311	2/19/13	< 1	
Whittier ES	3rd Floor Hallway, Next to Room 311	2/19/13	< 1	
Whittier ES	3rd Floor Hallway, Next to Room 308	2/19/13	< 1	
Whittier ES	3rd Floor Hallway, Next to Room 308	2/19/13	< 1	
Whittier ES	2nd Floor Hallway, Next Health Suite	2/19/13	< 1	
Whittier ES	2nd Floor Hallway, Next Health Suite	2/19/13	< 1	
Whittier ES	2nd Floor Hallway, Next to Room 211	2/19/13	1.4	
Whittier ES	2nd Floor Hallway, Next to Room 211	2/19/13	1.4	
Whittier ES	2nd Floor Hallway, Across from Room 201	2/19/13	< 1	
Whittier ES	2nd Floor Hallway, Across from Room 201	2/19/13	< 1	
Whittier ES	1st Floor Hallway, Between Custodial Closet and Main Office	2/19/13	< 1	
Whittier ES	1st Floor Hallway, Between Custodial Closet and Main Office	2/19/13	< 1	
Whittier ES	2nd Floor Hallway, Across from Room 115	2/19/13	1.9	
Whittier ES	2nd Floor Hallway, Across from Room 115	2/19/13	< 1	
Whittier ES	Basement Floor Hallway, Across from Room 15	2/19/13	< 1	
Whittier ES	Basement Floor Hallway, Across from Room 15	2/19/13	< 1	
			Percentage of Passed Samples	100.00%
			Percentage of Failed Samples	0.00%
Wilson SHS	3rd Floor Hallway, Next to Room 331	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 331	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 303	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 303	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 321	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 321	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 322	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 322	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 314 (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 314 (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 312	6/5/13	< 1	
Wilson SHS	3rd Floor Hallway, Next to Room 312	6/5/13	< 1	
Wilson SHS	4th Floor Hallway, Next to Room 421	6/5/13	< 1	
Wilson SHS	4th Floor Hallway, Next to Room 421	6/5/13	< 1	

Wilson SHS	4th Floor Hallway, Next to Room 422	6/5/13	< 1	
Wilson SHS	4th Floor Hallway, Next to Room 422	6/5/13	< 1	
Wilson SHS	4th Floor Hallway, Next to Room 414 (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	4th Floor Hallway, Next to Room 414 (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	4st Floor Hallway, Next to Room 412	6/5/13	< 1	
Wilson SHS	4st Floor Hallway, Next to Room 412	6/5/13	< 1	
Wilson SHS	4st Floor Hallway, Next to Room 403	6/5/13	< 1	
Wilson SHS	4st Floor Hallway, Next to Room 403	6/5/13	< 1	
Wilson SHS	4st Floor Hallway, Next to Room 431	6/5/13	< 1	
Wilson SHS	4st Floor Hallway, Next to Room 431	6/5/13	< 1	
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-308 (Electrical Closet)	6/5/13	< 1	
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-308 (Electrical Closet)	6/5/13	< 1	
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-301 (Storage Room)	6/5/13	< 1	
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-301 (Storage Room)	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 202	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 202	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 232	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 232	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 223	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 223	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 222	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 222	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 213 (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 213 (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 211	6/5/13	< 1	
Wilson SHS	2nd Floor Hallway, Next to Room 211	6/5/13	< 1	
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-202 (Storage Room)	6/5/13	< 1	
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-202 (Storage Room)	6/5/13	< 1	
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-209 (Electrical Closet)	6/5/13	< 1	
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-209 (Electrical Closet)	6/5/13	< 1	
Wilson SHS	1st Floor Hallway, Next to Room 119 (Staff Lounge)	6/5/13	< 1	
Wilson SHS	1st Floor Hallway, Next to Room 119 (Staff Lounge)	6/5/13	< 1	
Wilson SHS	2nd Floor, A Wing Hallway, Next to Room A-203B (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	2nd Floor, A Wing Hallway, Next to Room A-203B (Custodian's Closet)	6/5/13	< 1	
Wilson SHS	Inside Gym (High)	6/5/13	< 1	
Wilson SHS	Inside Gym (High)	6/5/13	< 1	
Wilson SHS	Inside Gym (Low)	6/5/13	< 1	
Wilson SHS	Inside Gym (Low)	6/5/13	< 1	
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-102 (Book Distribution)	6/5/13	< 1	
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-102 (Book Distribution)	6/5/13	< 1	
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-109 (Storage Room)	6/5/13	< 1	
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-109 (Storage Room)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (High)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (High)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (Low)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (Low)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (High)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (High)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (Low)	6/5/13	< 1	
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (Low)	6/5/13	< 1	

Percentage of Passed Samples 100.00%

		Percentage of Failed Samples			0.00%
Winston ES	3rd Floor, Next to Men's and Women's Restroom	1/28/13	< 1		
Winston ES	3rd Floor, Next to Men's and Women's Restroom	1/28/13	< 1		
Winston ES	3rd Floor, by Room 368	1/28/13	< 1		
Winston ES	3rd Floor, by Room 368	1/28/13	< 1		
Winston ES	3rd Floor, Inside Health Suite	1/28/13	1.1		
Winston ES	3rd Floor, Inside Health Suite	1/28/13	1.4		
Winston ES	3rd Floor, by Storage Room 359	1/28/13	< 1		
Winston ES	3rd Floor, by Storage Room 359	1/28/13	< 1		
Winston ES	3rd Floor, by Storage Room 353	1/28/13	< 1		
Winston ES	3rd Floor, by Storage Room 353	1/28/13	< 1		
Winston ES	2nd Floor, by Room 86	1/28/13	< 1		
Winston ES	2nd Floor, by Room 86	1/28/13	< 1		
Winston ES	2nd Floor, by Room 74	1/28/13	1.9		
Winston ES	2nd Floor, by Room 74	1/28/13	1.3		
Winston ES	2nd Floor, by Room 78	1/28/13	< 1		
Winston ES	2nd Floor, by Room 78	1/28/13	< 1		
Winston ES	2nd Floor, by Room 102	1/28/13	< 1		
Winston ES	2nd Floor, by Room 102	1/28/13	< 1		
Winston ES	2nd Floor, by Room 107	1/28/13	< 1		
Winston ES	2nd Floor, by Room 107	1/28/13	< 1		
Winston ES	2nd Floor, by Room 111	1/28/13	< 1		
Winston ES	2nd Floor, by Room 111	1/28/13	< 1		
Winston ES	2nd Floor, by Room 114	1/28/13	< 1		
Winston ES	2nd Floor, by Room 114	1/28/13	< 1		
Winston ES	1st Floor, by Room 64	1/28/13	< 1		
Winston ES	1st Floor, by Room 64	1/28/13	< 1		
Winston ES	1st Floor, by Room 60	1/28/13	< 1		
Winston ES	1st Floor, by Room 60	1/28/13	< 1		
Winston ES	1st Floor, by Room 58	1/28/13	< 1		
Winston ES	1st Floor, by Room 58	1/28/13	< 1		
Winston ES	1st Floor, by Room 25	1/28/13	< 1		
Winston ES	1st Floor, by Room 25	1/28/13	< 1		
Winston ES	1st Floor, by Room 21	1/28/13	< 1		
Winston ES	1st Floor, by Room 21	1/28/13	< 1		
Winston ES	1st Floor, by Room 38	1/28/13	< 1		
Winston ES	1st Floor, by Room 38	1/28/13	< 1		
Winston ES	1st Floor, by Room 34	1/28/13	< 1		
Winston ES	1st Floor, by Room 34	1/28/13	< 1		
		Percentage of Passed Samples			100.00%
		Percentage of Failed Samples			0.00%
Woodson SHS	3rd Floor, Next to Room 342	4/29/13	1		
Woodson SHS	3rd Floor, Next to Room 342	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 333	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 333	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 307 (High)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 307 (High)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 307 (Low)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 307 (Low)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 315 (High)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 315 (High)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 315 (Low)	4/29/13	< 1		
Woodson SHS	3rd Floor, Next to Room 315 (Low)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 238 (High)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 238 (High)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 238 (Low)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 238 (Low)	4/29/13	2.5		
Woodson SHS	2nd Floor, Next to Room 237 (High)	4/29/13	1.7		
Woodson SHS	2nd Floor, Next to Room 237 (High)	4/29/13	2		
Woodson SHS	2nd Floor, Next to Room 237 (Low)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 237 (Low)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 209B (High)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 209B (High)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 209B (Low)	4/29/13	< 1		
Woodson SHS	2nd Floor, Next to Room 209B (Low)	4/29/13	< 1		

